

N'DJAMENA INTL, Chad

WMO: 647000

Lat: 12.134N

Lon: 15.034E

Elev: 295

StdP: 97.83

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.3	14.9	-11.0	1.5	29.1	-8.9	1.8	28.6	9.8	24.1	8.8	23.9	2.5	40	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	15.0	43.1	21.6	42.2	21.7	41.2	21.5	28.3	34.4	27.6	33.7	27.0	33.2	3.8	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	23.5	31.0	26.1	22.3	30.4	25.7	21.8	30.0	93.0	34.3	89.9	34.2	87.3	33.3	33.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	7.9	7.1	DB	10.3	44.5	2.0	0.9	8.9	45.2	7.7	45.8	6.6	46.3	5.1	47.0	(4)
(5)			WB	4.6	29.8	1.0	1.2	3.9	30.7	3.3	31.4	2.8	32.1	2.0	33.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.1	23.9	27.4	31.1	34.2	34.1	31.8	28.8	27.1	28.5	30.0	28.0	24.6	(6)	
	DBStd	3.79	2.82	3.03	2.20	1.72	1.92	2.16	1.99	1.51	1.70	1.43	1.86	2.39	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6978	431	487	655	725	746	654	583	530	554	620	539	454	(10)	
	CDD18.3	3937	173	254	397	475	487	404	324	272	304	362	289	196	(11)	
	CDH23.3	53170	2137	3366	5988	7852	7815	5798	3693	2531	3303	4609	3748	2330	(12)	
(13)	CDH26.7	32098	1137	2038	3956	5539	5389	3562	1771	941	1544	2659	2304	1258	(13)	
(14)	Wind	WSAvg	3.4	3.7	4.1	4.2	3.4	3.3	3.5	3.3	2.6	2.6	3.4	3.7	(14)	
(15) Precipitation	PrecAvg	503	0	0	0	7	26	55	155	185	87	21	0	0	(15)	
	PrecMax	780	0	0	7	47	109	116	302	340	243	82	12	0	(16)	
	PrecMin	225	0	0	0	0	0	2	17	34	14	0	0	0	(17)	
	PrecStd	132	0	0	1	11	24	29	60	62	44	23	2	0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.1	41.8	43.1	44.2	44.1	41.9	38.8	34.9	37.8	39.9	39.8	38.1	(19)	
		MCWB	18.3	19.7	19.8	21.0	22.1	24.1	25.7	26.5	24.8	21.2	20.0	18.7	(20)	
	2%	DB	37.0	40.1	41.9	43.2	43.0	40.2	36.9	33.2	36.0	38.9	38.8	36.7	(21)	
		MCWB	17.4	19.0	19.8	21.2	22.8	24.6	25.7	26.2	25.5	21.0	19.5	17.9	(22)	
	5%	DB	35.0	38.5	40.9	42.8	42.0	39.2	35.2	32.2	34.8	37.9	37.8	35.0	(23)	
		MCWB	16.5	18.1	19.1	21.3	22.9	24.9	25.5	26.0	25.8	21.1	19.1	17.0	(24)	
	10%	DB	32.9	36.6	39.7	41.7	40.9	38.0	33.8	31.1	33.2	36.9	36.7	33.2	(25)	
		MCWB	15.5	17.2	18.6	21.2	23.2	25.0	25.5	25.7	25.9	21.8	18.4	16.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.0	21.1	24.9	27.2	28.4	28.7	28.8	28.5	28.7	28.5	24.2	20.2	(27)	
		MCDB	36.4	39.2	37.4	37.9	38.3	37.3	34.6	32.4	33.3	33.8	33.3	35.7	(28)	
	2%	WB	18.5	20.1	21.9	26.2	27.2	27.8	27.8	27.4	27.7	27.1	22.1	19.0	(29)	
		MCDB	34.6	38.4	37.7	37.2	37.3	36.2	33.1	31.1	32.2	32.7	33.4	34.6	(30)	
	5%	WB	17.2	19.1	20.2	25.2	26.4	27.0	26.9	26.7	27.0	26.1	20.8	17.9	(31)	
		MCDB	32.8	36.5	38.6	36.7	36.3	35.1	32.1	30.4	31.6	31.4	34.1	33.0	(32)	
	10%	WB	16.1	17.8	19.2	24.1	25.7	26.2	26.2	26.1	26.4	25.5	19.5	16.9	(33)	
		MCDB	31.5	34.6	37.8	36.1	35.5	34.0	31.1	29.7	30.9	30.9	33.9	31.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	17.6	17.3	16.7	15.0	13.2	11.7	9.7	8.2	9.9	13.9	17.6	17.6	(35)	
		MCDBR	19.5	18.9	18.0	16.4	14.7	13.3	11.7	9.6	11.7	16.1	18.3	18.9	(36)	
	5% WB	MCWBR	8.4	8.2	7.3	7.2	6.4	5.4	5.0	4.6	4.9	6.3	7.6	8.4	(37)	
		MCWBR	19.0	18.2	16.8	13.3	12.7	12.1	10.4	8.8	10.3	12.2	17.5	18.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.529	0.622	0.692	0.697	0.667	0.661	0.618	0.565	0.566	0.560	0.487	0.488	(40)	
		taud	1.821	1.621	1.505	1.543	1.630	1.688	1.814	1.948	1.925	1.888	1.952	1.918	(41)	
	Ebn at Noon		772	718	681	674	682	677	710	760	763	759	805	798	(42)	
		Edh at Noon	209	264	302	289	260	242	215	191	196	200	181	185	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.88	6.24	6.57	6.65	6.39	5.90	5.46	5.17	5.85	6.15	6.04	5.70	(44)	
	RadStd		0.13	0.17	0.29	0.27	0.33	0.30	0.25	0.26	0.21	0.22	0.16	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.41	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page