

YAOUNDE, Cameroon

WMO: 649500

Lat: 3.723N

Lon: 11.553E

Elev: 2278

StdP: 13.53

Time Zone: 1.00 (E01)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	62.5	64.5	53.6	66.6	77.5	58.8	80.4	74.0	12.2	76.6	11.5	76.7	0.5	0	0.205

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.4	89.9	72.9	89.2	73.0	87.8	73.4	78.3	84.1	77.4	83.2	76.8	82.6	4.5	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.0	153.3	82.4	75.6	146.0	80.6	75.3	144.3	80.2	44.0	84.3	43.1	83.8	42.3	83.0	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.5	8.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			56.1	78.4	4.0	2.8	53.2	80.4	50.8	82.0	48.6	83.5	45.7	85.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.2	76.9	78.4	78.2	77.7	76.7	75.3	74.2	74.0	74.8	75.9	76.3	76.3
	DBStd	2.50	2.44	2.49	2.22	2.32	2.14	2.19	1.89	1.81	1.88	1.69	1.78	1.81
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9568	835	794	876	831	828	758	750	745	743	803	788	817
	CDD65	4093	370	374	411	381	363	308	285	280	293	338	338	352
	CDH74	22595	2610	2689	2775	2541	2112	1332	948	869	1124	1543	1794	2258
	CDH80	6868	933	1056	1054	918	651	255	109	88	184	374	512	734
Wind	WSAvg	3.5	3.0	3.8	3.9	3.3	2.8	3.5	4.4	4.7	4.1	3.4	2.8	2.5
Precipitation	PrecAvg	65.0	0.9	2.0	5.2	7.3	8.0	5.2	3.9	5.1	8.9	11.4	5.9	1.3
	PrecMax	76.5	2.1	6.7	8.4	10.5	12.5	7.7	7.0	9.6	13.3	14.0	11.7	3.6
	PrecMin	51.0	0.1	0.2	2.2	4.4	5.0	2.3	1.3	0.8	5.0	8.7	1.7	0.2
	PrecStd	7.0	0.5	1.3	1.6	1.5	1.5	1.3	1.6	2.2	2.0	1.5	2.2	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.8	91.8	91.7	91.4	89.5	86.4	84.5	84.4	86.1	87.7	87.9	88.1
		MCWB	70.2	71.6	73.4	74.3	74.4	74.1	73.5	73.3	72.7	73.9	74.2	71.5
	2%	DB	88.1	89.9	89.8	89.4	87.7	84.6	82.6	82.4	84.1	85.9	86.2	86.4
		MCWB	70.9	71.7	73.8	74.9	74.5	74.1	73.2	73.0	73.5	73.6	73.7	71.2
	5%	DB	87.4	88.2	87.9	87.7	86.0	82.7	80.8	80.6	82.3	84.1	84.6	85.9
		MCWB	71.0	72.6	74.4	75.2	74.8	73.9	72.7	72.5	73.0	73.6	73.9	71.3
	10%	DB	85.7	86.3	86.1	85.8	84.1	80.9	79.0	78.8	80.5	82.3	83.8	84.3
		MCWB	71.2	73.3	74.8	75.3	75.0	73.3	72.1	71.9	72.8	73.1	73.9	72.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.9	78.9	79.1	79.2	78.8	77.0	76.1	75.6	76.4	76.5	77.8	77.5
		MCDB	83.0	85.1	85.3	84.6	83.7	81.7	80.3	80.3	81.1	83.3	83.3	82.3
	2%	WB	75.9	77.3	77.7	78.1	77.5	75.8	74.8	74.7	75.4	75.3	76.5	76.3
		MCDB	81.9	83.5	84.3	84.2	82.8	81.1	79.5	79.4	80.3	82.5	82.2	81.5
	5%	WB	74.6	76.4	76.6	77.1	76.5	74.9	73.8	73.6	74.4	74.4	75.6	75.3
		MCDB	81.2	82.5	83.3	83.6	82.1	80.5	78.9	78.5	79.6	81.4	81.4	81.1
	10%	WB	73.6	75.4	75.5	76.0	75.5	73.9	72.8	72.6	73.2	73.5	74.6	74.2
		MCDB	80.3	81.2	82.3	82.5	81.3	79.6	77.7	77.3	78.6	80.3	80.6	80.3
Mean Daily Temperature Range	5% DB	MDBR	19.1	18.4	17.8	17.6	16.4	13.4	11.6	11.5	13.7	15.7	16.3	18.3
		MCDBR	20.5	20.4	20.0	20.0	18.7	15.8	13.7	13.5	15.5	17.6	17.8	19.7
		MCWBR	6.8	6.9	7.5	8.0	7.9	6.7	5.9	5.9	6.7	7.5	7.7	7.4
	5% WB	MCDBR	17.0	17.9	18.1	17.3	16.3	14.5	12.8	12.3	14.3	16.3	16.3	16.9
		MCWBR	6.9	7.8	8.8	8.7	9.1	7.3	6.3	6.5	7.6	7.6	8.4	8.1
Clear-Sky Solar Irradiance	taub	0.676	0.731	0.704	0.489	0.435	0.440	0.447	0.427	0.400	0.414	0.501	0.628	
	taud	1.665	1.592	1.650	2.200	2.378	2.348	2.307	2.351	2.440	2.414	2.133	1.764	
	Ebn at Noon	217	209	216	263	271	266	265	276	288	286	260	226	
	Edh at Noon	81	89	84	47	38	39	41	40	37	38	50	72	
All-Sky Solar Radiation	RadAvg	1638	1564	1553	1576	1492	1258	1163	1151	1341	1407	1481	1573	
	RadStd	88	92	71	51	63	86	78	90	62	46	50	75	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page