

KANDI, Benin

WMO: 653060

Lat: 11.133N

Lon: 2.933E

Elev: 292

StdP: 97.87

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.3	17.4	-4.6	2.6	28.8	-2.9	3.1	28.3	10.0	27.3	8.6	28.5	0.4	40	0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.7	39.9	21.8	39.0	21.9	38.1	22.0	27.3	32.8	26.9	32.5	26.6	32.2	3.1	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.0	22.1	30.4	25.5	21.4	30.0	25.1	20.9	29.8	88.4	33.0	86.5	32.5	84.9	32.4	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.3	5.3	13.4	41.8	0.9	1.3	12.7	42.7	12.2	43.4	11.6	44.2	11.0	45.1		
(5)			7.8	29.2	0.7	1.0	7.2	29.9	6.8	30.5	6.4	31.0	5.9	31.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.3	25.3	28.7	32.1	32.7	30.6	28.5	27.0	26.3	26.8	28.2	27.7	25.7
	DBStd	2.89	2.18	2.44	1.78	1.77	1.96	1.72	1.41	1.25	1.25	1.24	1.56	1.91
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6673	475	523	686	681	638	554	526	504	505	564	531	486
	CDD18.3	3632	217	289	427	431	379	304	268	246	255	306	281	228
	CDH23.3	44600	2409	3837	6504	6671	5379	3704	2642	2054	2388	3286	3227	2499
	CDH26.7	23408	1171	2214	4177	4320	3062	1707	909	572	834	1473	1727	1242
Wind	WSAvg	1.8	2.1	2.2	2.3	2.6	2.4	1.9	1.5	1.3	1.1	1.3	1.5	1.9
Precipitation	PrecAvg	1008	0	2	7	36	115	153	202	266	190	41	0	0
	PrecMax	1436	8	35	58	157	236	256	390	548	337	205	15	8
	PrecMin	655	0	0	0	1	8	61	93	128	67	0	0	0
	PrecStd	162	1	5	12	34	53	48	58	83	60	38	2	1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.0	40.0	40.7	41.2	39.1	36.3	33.7	32.2	33.5	35.7	37.2	36.7
		MCWB	17.9	20.7	20.9	21.8	24.6	25.7	26.1	26.2	26.6	23.7	20.1	19.0
	2%	DB	35.3	38.1	39.8	40.0	37.6	34.8	32.5	31.2	32.3	34.6	36.2	35.4
		MCWB	17.4	20.3	21.0	22.6	25.2	25.7	25.8	25.9	26.4	24.4	20.6	18.3
	5%	DB	33.9	36.9	39.0	39.1	36.5	33.8	31.6	30.4	31.4	33.6	35.3	34.1
		MCWB	17.1	19.3	20.9	22.8	25.5	25.7	25.6	25.6	26.2	24.8	20.4	17.7
	10%	DB	32.5	35.6	38.2	38.1	35.4	32.8	30.7	29.6	30.6	32.7	34.2	32.6
		MCWB	16.8	18.6	20.8	23.4	25.5	25.6	25.3	25.3	26.0	25.0	20.7	17.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.1	25.1	26.5	27.3	27.7	27.3	27.0	27.2	27.9	27.4	25.6	22.6
		MCDB	32.1	34.8	35.5	36.1	34.4	33.0	32.0	31.0	31.5	32.1	33.0	32.1
	2%	WB	20.3	23.6	24.9	26.6	27.1	26.7	26.3	26.4	27.2	26.9	24.7	20.7
		MCDB	30.0	33.3	34.5	35.7	34.1	32.5	31.2	30.2	31.0	31.7	31.6	31.6
	5%	WB	18.1	22.1	24.2	26.0	26.6	26.4	25.9	25.9	26.6	26.4	23.8	19.0
		MCDB	31.9	32.3	34.0	35.2	33.6	32.1	30.7	29.6	30.5	31.4	30.5	32.0
	10%	WB	17.1	20.3	23.5	25.4	26.2	26.0	25.5	25.5	26.1	26.0	22.9	17.9
		MCDB	31.6	33.7	33.6	34.4	33.1	31.7	29.9	29.0	30.0	31.1	29.5	30.9
Mean Daily Temperature Range	5% DB	MDBR	14.5	13.7	12.5	10.7	9.0	8.1	7.0	6.3	7.6	9.9	14.7	15.2
		MCDBR	16.5	14.9	13.5	12.2	10.5	9.2	8.2	7.6	8.8	11.1	15.4	16.7
		MCWBR	6.5	6.2	5.9	4.4	3.1	3.0	3.1	3.3	4.4	3.7	4.9	6.0
	5% WB	MCDBR	15.2	11.9	11.2	10.3	8.9	8.4	7.8	7.1	8.5	9.5	12.5	15.7
		MCWBR	7.4	6.3	5.7	3.6	3.5	3.7	3.4	3.6	4.6	4.2	4.9	6.6
Clear-Sky Solar Irradiance	taub	0.645	0.722	0.787	0.730	0.645	0.592	0.539	0.522	0.530	0.608	0.564	0.552	
	taud	1.674	1.528	1.443	1.607	1.749	1.881	2.063	2.104	2.059	1.833	1.844	1.853	
	Ebn at Noon	681	649	619	653	696	725	768	793	793	724	741	745	
	Edh at Noon	244	291	322	271	231	199	167	163	171	212	204	200	
All-Sky Solar Radiation	RadAvg	5.51	5.76	5.98	6.10	5.89	5.55	5.10	4.76	5.30	5.80	5.74	5.47	
	RadStd	0.22	0.22	0.28	0.20	0.20	0.21	0.18	0.23	0.23	0.20	0.15	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page