

BOHICON, Benin

WMO: 653380

Lat: 7.167N

Lon: 2.067E

Elev: 548

StdP: 14.41

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	70.4	71.3	43.7	42.8	82.5	48.8	52.0	83.3	12.9	78.7	11.8	78.9	2.2	0	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.0	96.5	76.2	94.9	76.7	93.4	77.1	81.0	90.8	80.6	90.1	80.0	89.0	3.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	152.7	84.8	78.2	149.6	84.2	77.8	147.6	83.9	45.3	91.6	44.6	90.4	44.1	89.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	10.1	8.9	67.6	99.9	1.7	1.6	66.3	101.0	65.3	101.9	64.4	102.8	63.2	104.0
			54.4	82.1	2.3	1.0	52.7	82.8	51.3	83.4	50.0	84.0	48.3	84.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	83.0	85.4	85.2	84.1	82.3	80.2	78.7	77.9	79.2	80.6	83.1	83.3	(6)
	DBStd	3.18	2.58	2.18	2.31	2.63	2.45	2.12	1.55	1.59	1.61	1.89	1.71	1.70	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	11642	1022	991	1092	1022	1001	907	890	865	876	950	993	1033	(10)
	CDD65	6167	557	571	627	572	536	457	425	400	426	485	543	568	(11)
	CDH74	61367	6260	6910	7403	6502	5595	3994	2991	2556	3167	4112	5629	6248	(12)
	CDH80	24032	2833	3349	3424	2819	2107	1192	637	485	780	1318	2309	2779	(13)
(14) Wind	WSAvg	3.5	2.8	3.7	4.5	4.3	3.4	3.4	4.2	4.5	3.7	2.7	2.8	2.5	(14)
(15) Precipitation	PrecAvg	45.1	0.2	1.3	2.8	5.0	5.7	6.6	6.2	4.5	6.1	4.8	1.1	0.6	(15)
	PrecMax	73.7	2.0	7.6	6.5	11.4	11.0	15.4	20.5	11.7	14.2	10.7	6.4	5.5	(16)
	PrecMin	21.7	0.0	0.0	0.0	1.0	1.4	2.6	0.6	0.2	0.8	1.1	0.0	0.0	(17)
	PrecStd	9.9	0.5	1.4	1.6	2.6	2.3	2.7	3.8	3.0	2.8	2.4	1.1	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.7	99.1	99.0	96.8	93.7	91.1	88.0	87.6	89.0	91.5	94.5	95.6	(19)
		MCWB	73.9	75.0	78.0	80.0	79.9	79.5	78.0	77.1	78.2	79.2	77.8	74.3	(20)
	2%	DB	94.2	96.7	96.1	94.3	91.6	89.0	86.2	85.5	87.2	89.7	92.7	93.5	(21)
		MCWB	74.2	74.8	77.8	79.9	79.8	78.9	77.4	76.5	77.7	78.7	77.8	74.7	(22)
	5%	DB	92.3	94.7	93.9	92.5	90.1	87.3	84.9	84.2	85.7	88.1	91.3	91.9	(23)
		MCWB	74.6	75.4	78.5	79.6	79.6	78.3	77.0	76.1	77.3	78.4	77.9	75.1	(24)
	10%	DB	90.7	92.8	92.0	90.8	88.6	86.0	83.6	82.8	84.4	86.5	89.7	90.4	(25)
		MCWB	74.5	76.3	78.7	79.2	79.2	77.9	76.6	75.8	76.9	78.1	77.9	75.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.3	81.0	81.6	82.1	81.9	80.5	79.2	78.3	79.2	80.3	80.9	80.0	(27)
		MCDB	90.6	92.3	92.4	92.8	90.5	89.0	86.0	85.0	86.3	88.7	90.2	89.6	(28)
	2%	WB	79.2	80.1	80.7	81.0	80.9	79.5	78.2	77.4	78.3	79.5	79.9	79.2	(29)
		MCDB	88.1	90.1	91.3	91.0	89.2	87.1	84.6	83.7	85.3	87.7	89.0	88.5	(30)
	5%	WB	78.3	79.5	80.0	80.2	80.1	78.8	77.5	76.8	77.8	78.9	79.2	78.7	(31)
		MCDB	86.5	88.7	89.8	89.5	87.9	85.9	83.5	82.7	84.5	86.7	88.0	87.6	(32)
	10%	WB	77.8	78.9	79.5	79.7	79.5	78.2	76.9	76.1	77.2	78.3	78.8	78.1	(33)
		MCDB	85.6	87.3	88.5	88.3	86.8	84.6	82.6	81.7	83.5	85.4	87.3	86.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	17.1	17.0	15.9	14.8	13.2	12.0	10.7	10.3	11.4	13.4	15.5	17.0	(35)
		MCDBR	19.2	19.8	17.9	16.4	15.0	14.0	12.5	12.7	13.3	15.1	17.0	18.7	(36)
	5% WB	MCWBR	5.6	5.2	4.9	4.8	5.1	5.4	5.2	5.3	5.3	6.0	4.9	5.0	(37)
		MCWBR	15.8	16.6	16.1	15.5	14.2	13.3	11.7	11.5	12.5	14.5	15.8	15.6	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.803	0.818	0.821	0.663	0.558	0.516	0.505	0.501	0.481	0.522	0.596	0.677	(40)
		taud	1.514	1.507	1.492	1.782	2.000	2.134	2.177	2.181	2.251	2.111	1.872	1.716	(41)
	Ebn at Noon	Ebn at Noon	186	189	191	221	240	247	251	257	265	255	232	210	(42)
		Edh at Noon	93	96	98	72	56	49	47	48	45	52	64	75	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1580	1589	1665	1684	1596	1421	1323	1245	1384	1577	1629	1561	(44)
	RadStd	RadStd	43	60	71	59	63	75	71	75	64	46	37	47	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (5 neighbors)	+0.50	+0.56	N/A	+0.65	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page