

BOHICON, Benin

WMO: 653380

Lat: 7.167N

Lon: 2.067E

Elev: 167

StdP: 99.33

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.3	21.8	6.5	6.1	28.0	9.3	7.4	28.5	5.8	26.0	5.3	26.0	1.0	0	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.5	35.9	24.6	34.9	24.9	34.1	25.1	27.2	32.7	27.0	32.3	26.7	31.7	1.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.8	29.3	25.7	21.4	29.0	25.5	21.1	28.8	87.4	33.1	86.0	32.5	84.7	32.0	32.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.3	4.5	4.0	19.8	37.7	0.9	0.9	19.1	38.3	18.5	38.9	18.0	39.3	17.3	40.0		
(5)			12.4	27.8	1.3	0.6	11.5	28.2	10.7	28.6	10.0	28.9	9.1	29.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	28.3	29.7	29.6	28.9	27.9	26.8	25.9	25.5	26.2	27.0	28.4	28.5
	DBStd	1.77	1.44	1.21	1.28	1.46	1.36	1.18	0.86	0.88	0.90	1.05	0.95	0.95
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6468	568	551	607	568	556	504	494	481	487	528	552	574
	CDD18.3	3426	309	317	348	318	298	254	236	222	237	269	302	316
	CDH23.3	34093	3478	3839	4113	3612	3108	2219	1662	1420	1759	2284	3127	3471
CDH26.7	13351	1574	1861	1902	1566	1171	662	354	269	433	732	1283	1544	
Wind	WSAvg	1.6	1.2	1.7	2.0	1.9	1.5	1.5	1.9	2.0	1.6	1.2	1.2	1.1
Precipitation	PrecAvg	1146	6	32	71	128	145	167	158	114	155	121	28	15
	PrecMax	1872	50	192	164	289	279	392	520	297	360	272	163	139
	PrecMin	552	0	0	1	26	36	66	15	4	21	27	0	0
	PrecStd	252	12	36	40	65	59	69	97	75	72	62	29	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.9	37.3	37.2	36.0	34.3	32.9	31.1	30.9	31.7	33.0	34.7	35.3
		MCWB	23.3	23.9	25.6	26.7	26.6	26.4	25.6	25.1	25.7	26.2	25.4	23.5
	2%	DB	34.5	36.0	35.6	34.6	33.1	31.6	30.1	29.7	30.7	32.1	33.7	34.2
		MCWB	23.4	23.8	25.4	26.6	26.5	26.0	25.2	24.7	25.4	26.0	25.4	23.7
	5%	DB	33.5	34.8	34.4	33.6	32.3	30.7	29.4	29.0	29.8	31.2	33.0	33.3
		MCWB	23.7	24.1	25.8	26.5	26.4	25.7	25.0	24.5	25.2	25.8	25.5	23.9
	10%	DB	32.6	33.8	33.4	32.7	31.5	30.0	28.7	28.2	29.1	30.3	32.0	32.4
		MCWB	23.6	24.6	25.9	26.2	26.2	25.5	24.8	24.3	24.9	25.6	25.5	24.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.2	27.6	27.9	27.7	26.9	26.2	25.7	26.2	26.8	27.1	26.7
		MCDB	32.6	33.5	33.6	33.8	32.5	31.7	30.0	29.5	30.2	31.5	32.3	32.0
	2%	WB	26.2	26.7	27.1	27.2	27.1	26.4	25.7	25.2	25.7	26.4	26.6	26.2
		MCDB	31.2	32.3	32.9	32.8	31.8	30.6	29.2	28.7	29.6	30.9	31.7	31.4
	5%	WB	25.7	26.4	26.7	26.8	26.7	26.0	25.3	24.9	25.4	26.1	26.2	25.9
		MCDB	30.3	31.5	32.1	31.9	31.0	30.0	28.6	28.2	29.2	30.4	31.1	30.9
	10%	WB	25.5	26.1	26.4	26.5	26.4	25.7	24.9	24.5	25.1	25.7	26.0	25.6
		MCDB	29.8	30.7	31.4	31.3	30.4	29.2	28.1	27.6	28.6	29.7	30.7	30.0
Mean Daily Temperature Range	5% DB	MDBR	9.5	9.5	8.8	8.2	7.4	6.7	5.9	5.7	6.3	7.4	8.6	9.5
		MCDBR	10.7	11.0	9.9	9.1	8.3	7.8	7.0	7.1	7.4	8.4	9.5	10.4
		MCWBR	3.1	2.9	2.7	2.7	2.9	3.0	2.9	2.9	3.0	3.3	2.7	2.8
	5% WB	MCDBR	8.8	9.2	8.9	8.6	7.9	7.4	6.5	6.4	7.0	8.1	8.8	8.7
		MCWBR	2.4	2.4	2.9	2.9	3.1	3.1	2.9	2.9	3.0	3.4	3.0	2.2
Clear-Sky Solar Irradiance	taub	0.803	0.818	0.821	0.663	0.558	0.516	0.505	0.501	0.481	0.522	0.596	0.677	
	taud	1.514	1.507	1.492	1.782	2.000	2.134	2.177	2.181	2.251	2.111	1.872	1.716	
	Ebn at Noon	587	597	603	697	756	778	792	809	836	803	731	662	
	Edh at Noon	293	302	309	228	178	153	148	151	142	163	203	235	
All-Sky Solar Radiation	RadAvg	4.98	5.01	5.25	5.31	5.03	4.48	4.17	3.93	4.36	4.97	5.13	4.92	
	RadStd	0.13	0.19	0.22	0.18	0.20	0.23	0.22	0.24	0.20	0.14	0.12	0.15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+0.28	+0.31	N/A	+0.36	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page