

LOME, Togo

WMO: 653870

Lat: 6.166N

Lon: 1.255E

Elev: 22

StdP: 101.06

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.8	22.4	10.1	7.7	28.7	14.9	10.6	27.1	9.2	27.6	8.7	27.5	1.7	0	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.3	33.2	26.1	33.0	26.3	32.5	26.4	28.2	30.8	28.0	30.5	27.7	30.3	4.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.9	24.0	29.3	27.2	23.0	29.2	27.1	22.9	29.1	91.3	31.1	90.1	30.3	88.5	30.5	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.6	7.1	DB	19.9	35.6	1.0	1.3	19.2	36.5	18.6	37.2	18.0	37.9	17.3	38.9	(4)
(5)			WB	14.6	29.4	2.2	0.7	13.0	29.9	11.7	30.3	10.4	30.7	8.8	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	28.2	29.2	29.4	29.0	28.3	26.9	26.3	25.9	26.7	27.5	28.5	28.5
	DBStd	1.51	1.21	1.02	1.11	1.25	1.25	1.07	0.76	0.72	0.82	0.89	0.79	0.95
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6519	564	538	601	571	567	508	504	494	501	542	554	574
	CDD18.3	3478	306	304	343	321	309	258	246	236	251	284	304	316
	CDH23.3	36537	3348	3677	4269	3916	3558	2420	1874	1536	2054	2801	3488	3595
CDH26.7	12742	1264	1562	1896	1678	1359	579	276	197	390	795	1320	1426	
Wind	WSAvg	3.4	2.8	3.6	3.8	3.5	2.9	3.2	4.2	4.6	4.1	3.2	2.8	2.7
Precipitation	PrecAvg	856	8	20	53	102	150	221	88	30	65	83	23	7
	PrecMax	1524	60	170	154	212	393	700	318	163	407	231	114	44
	PrecMin	440	0	0	0	0	25	44	0	0	0	0	0	0
	PrecStd	258	16	35	37	52	78	137	82	37	70	61	23	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	34.0	34.0	33.8	33.2	32.0	30.1	29.9	31.0	32.1	33.2	33.5
		MCWB	21.0	24.1	26.7	27.4	27.2	26.9	25.7	25.1	26.1	26.6	26.9	24.3
	2%	DB	32.8	33.1	33.2	33.0	32.3	31.0	29.2	29.1	30.1	31.2	32.3	32.9
		MCWB	23.9	26.0	27.0	27.3	27.0	26.6	25.3	24.9	25.8	26.3	26.7	25.2
	5%	DB	32.0	32.6	32.8	32.2	31.9	30.1	28.9	28.2	29.3	30.9	32.0	32.2
		MCWB	24.9	26.2	27.0	27.0	26.9	26.2	25.2	24.5	25.4	26.2	26.6	25.7
	10%	DB	31.2	32.0	32.1	31.9	31.1	29.2	28.1	27.9	28.9	30.1	31.2	31.8
		MCWB	25.3	26.3	26.8	27.0	26.8	25.9	24.8	24.4	25.2	25.9	26.5	25.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.4	28.5	28.7	28.3	27.9	26.7	26.1	27.0	27.5	28.1	28.1
		MCDB	30.2	31.0	31.3	31.7	31.0	30.0	28.5	28.2	29.6	30.5	31.0	30.6
	2%	WB	27.4	28.0	28.0	28.2	27.8	27.1	26.2	25.5	26.2	26.8	27.6	27.6
		MCDB	29.7	30.3	30.6	30.8	30.6	29.4	28.0	27.6	28.7	29.8	30.5	30.2
	5%	WB	27.1	27.6	27.7	27.8	27.4	26.7	25.8	25.1	25.9	26.5	27.2	27.1
		MCDB	29.4	30.1	30.3	30.4	30.2	28.9	27.6	27.3	28.3	29.3	30.2	29.9
	10%	WB	26.7	27.3	27.5	27.5	27.1	26.2	25.4	24.8	25.6	26.2	26.8	26.8
		MCDB	29.1	29.8	30.2	30.2	29.9	28.4	27.2	26.8	27.9	28.8	29.8	29.5
Mean Daily Temperature Range	5% DB	MDBR	7.8	6.7	6.3	6.3	6.3	5.3	4.6	4.6	5.1	6.2	6.9	7.7
		MCDBR	8.2	7.1	6.5	6.5	6.7	6.2	5.2	5.0	5.6	6.8	7.3	8.0
		MCWBR	3.7	3.0	2.6	2.8	2.9	3.1	2.4	2.4	2.6	3.0	3.0	3.3
	5% WB	MCDBR	6.5	6.1	6.2	6.3	6.4	5.7	4.7	4.7	5.5	6.4	7.1	7.0
		MCWBR	2.7	2.6	2.8	3.0	3.2	3.2	2.6	2.5	2.8	3.1	3.1	3.0
Clear-Sky Solar Irradiance	taub	0.817	0.817	0.812	0.646	0.544	0.519	0.527	0.525	0.488	0.501	0.589	0.698	
	taud	1.520	1.530	1.533	1.838	2.072	2.159	2.128	2.131	2.262	2.218	1.932	1.709	
	Ebn at Noon	581	600	609	708	766	775	772	789	832	822	740	651	
	Edh at Noon	292	296	297	215	166	149	155	158	141	147	192	238	
All-Sky Solar Radiation	RadAvg	5.10	5.09	5.33	5.37	4.94	4.24	4.45	4.47	4.77	5.23	5.30	5.09	
	RadStd	0.16	0.22	0.24	0.22	0.27	0.26	0.29	0.28	0.20	0.23	0.14	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+0.28	+0.31	N/A	+0.36	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page