

ACCRA, Ghana

WMO: 654720

Lat: 5.605N

Lon: 0.167W

Elev: 63

StdP: 100.58

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.4	22.9	11.8	8.7	28.7	15.9	11.4	27.5	10.1	26.9	9.4	26.9	3.4	270	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.8	33.7	25.7	33.1	25.8	32.8	25.8	27.6	30.6	27.2	30.3	27.0	30.1	5.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.5	29.2	26.2	21.8	29.0	26.1	21.7	28.9	87.9	30.8	86.4	30.8	85.1	30.9	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.4	8.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			15.7	28.3	3.8	0.5	13.0	28.7	10.8	28.9	8.6	29.2	5.9	29.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	28.8	29.3	29.3	29.0	28.3	26.9	26.2	25.8	26.8	27.6	28.4	28.6
	DBStd	1.51	0.74	0.84	1.04	1.21	1.25	1.06	0.83	0.77	0.78	0.82	0.83	0.99
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6534	582	539	598	570	567	507	501	491	503	546	553	578
	CDD18.3	3493	323	306	340	320	309	257	242	232	253	287	303	320
	CDH23.3	36084	3589	3638	4139	3847	3481	2347	1761	1444	1987	2823	3402	3624
	CDH26.7	12298	1357	1502	1791	1616	1288	534	228	173	383	807	1238	1382
Wind	WSAvg	4.3	3.7	4.6	4.4	4.3	3.8	4.1	4.9	5.2	5.1	4.1	3.6	3.4
Precipitation	PrecAvg	799	14	25	55	93	133	203	73	25	58	62	33	27
	PrecMax	1415	113	167	203	269	278	715	371	121	276	160	115	126
	PrecMin	333	0	0	2	6	41	17	1	0	0	1	0	0
	PrecStd	243	24	33	42	63	66	134	76	27	56	40	28	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	34.0	34.2	34.2	33.4	32.1	30.2	30.0	31.2	32.2	33.1	33.2
		MCWB	21.9	26.2	25.8	26.9	26.4	25.9	24.7	24.3	25.4	25.9	26.1	24.6
	2%	DB	33.0	33.1	33.2	33.2	32.8	31.0	29.2	29.1	30.2	31.7	32.3	32.8
		MCWB	23.7	26.1	26.2	26.5	26.2	25.9	24.3	24.0	25.0	25.7	26.0	25.0
	5%	DB	32.2	32.7	32.9	32.8	32.0	30.0	28.8	28.2	29.8	31.0	31.9	32.1
		MCWB	24.4	26.1	26.2	26.4	26.1	25.6	24.2	23.7	24.8	25.6	25.9	25.1
	10%	DB	31.7	32.0	32.1	32.0	31.2	29.2	28.0	27.8	28.9	30.2	31.2	31.6
		MCWB	24.5	26.0	26.0	26.2	26.1	25.2	24.0	23.6	24.6	25.5	25.9	25.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.7	27.7	28.2	27.4	26.7	25.6	24.9	26.6	27.5	27.2	27.2
		MCDB	29.9	30.3	30.5	31.6	30.9	29.6	28.2	28.0	29.6	30.5	31.0	30.7
	2%	WB	26.7	27.2	27.2	27.6	27.0	26.2	25.1	24.5	25.6	26.4	26.7	26.7
		MCDB	29.4	29.9	30.3	30.8	30.4	29.0	27.5	27.3	28.7	29.6	30.3	30.1
	5%	WB	26.5	26.9	27.0	27.1	26.6	26.0	24.7	24.2	25.1	26.1	26.5	26.5
		MCDB	29.3	29.7	30.2	30.3	30.0	28.7	27.0	26.7	28.0	29.1	30.0	29.7
	10%	WB	26.2	26.7	26.7	26.7	26.4	25.7	24.6	24.0	24.8	25.7	26.2	26.2
		MCDB	29.0	29.6	29.9	29.9	29.7	28.3	26.8	26.2	27.4	28.7	29.6	29.4
Mean Daily Temperature Range	5% DB	MDBR	7.2	6.6	6.8	6.7	6.4	5.3	4.5	4.5	5.3	6.3	6.6	7.1
		MCDBR	7.6	7.1	7.1	7.3	7.0	6.2	5.3	5.2	6.2	7.0	7.2	7.5
		MCWBR	3.3	2.3	2.6	2.4	2.4	2.4	1.8	1.8	2.2	2.4	2.5	2.9
	5% WB	MCDBR	6.8	6.5	6.8	6.8	6.7	5.8	4.6	4.7	5.7	6.6	6.8	7.0
		MCWBR	2.6	2.2	2.6	2.6	2.6	2.5	1.8	1.8	2.3	2.6	2.6	2.6
Clear-Sky Solar Irradiance	taub		0.811	0.797	0.791	0.620	0.528	0.516	0.527	0.523	0.486	0.489	0.572	0.694
	taud		1.522	1.560	1.559	1.895	2.116	2.155	2.110	2.123	2.255	2.255	1.972	1.720
	Ebn at Noon		587	614	623	727	778	776	772	790	834	834	755	656
	Edh at Noon		293	287	289	203	158	150	158	159	142	141	185	236
All-Sky Solar Radiation	RadAvg		5.18	5.24	5.39	5.42	4.98	4.24	4.50	4.53	4.85	5.36	5.36	5.10
	RadStd		0.15	0.17	0.20	0.20	0.21	0.23	0.29	0.25	0.18	0.18	0.12	0.11

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page