

DORI, Burkina Faso

WMO: 655010

Lat: 14.033N

Lon: 0.033W

Elev: 909

StdP: 14.22

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	57.6	60.1	15.2	12.3	85.5	18.6	14.5	85.3	12.3	83.2	11.4	82.2	0.2	0	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	20.3	108.7	70.6	107.2	70.3	105.6	70.1	79.9	92.7	79.1	92.0	78.6	91.3	3.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.0	145.6	84.7	76.2	141.7	84.4	75.5	138.2	84.1	44.2	92.7	43.4	92.1	42.8	91.4	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.2	9.5	7.8	53.1	113.0	1.6	1.1	52.0	113.8	51.0	114.5	50.1	115.1	49.0	116.0
			42.6	82.8	1.4	1.5	41.6	83.9	40.7	84.8	39.9	85.7	38.9	86.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	85.6	74.8	81.1	88.1	93.4	95.3	90.8	85.9	83.2	85.8	88.7	83.5	76.6	(6)
(7)		DBStd	7.09	3.67	5.01	4.72	3.75	3.56	4.27	3.87	3.20	3.37	2.75	3.30	3.81	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12999	770	872	1181	1303	1403	1225	1112	1029	1074	1200	1006	824	(10)
(11)		CDD65	7524	305	452	716	853	938	775	647	564	624	735	556	359	(11)
(12)		CDH74	107112	3408	5776	10839	14104	15628	11956	8667	6699	8179	10467	7352	4037	(12)
(13)		CDH80	65509	1564	3322	7100	9929	11188	7750	4634	2981	4287	6310	4456	1988	(13)
(14)	Wind	WSAvg	2.4	2.3	2.6	2.8	2.8	3.5	3.7	3.0	2.2	1.9	1.5	1.4	1.9	(14)
(15)	Precipitation	PrecAvg	18.4	0.0	0.0	0.1	0.2	1.0	2.4	4.6	6.5	2.9	0.7	0.0	0.0	(15)
(16)		PrecMax	28.5	0.4	0.1	1.0	3.5	3.7	7.8	8.1	10.3	6.3	2.4	0.1	0.0	(16)
(17)		PrecMin	11.3	0.0	0.0	0.0	0.0	0.0	1.0	1.8	2.8	0.6	0.0	0.0	0.0	(17)
(18)		PrecStd	4.1	0.1	0.0	0.2	0.7	1.0	1.5	1.4	1.9	1.3	0.7	0.0	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.4	105.3	108.4	110.7	111.2	107.3	102.2	97.0	101.7	103.9	102.5	98.9	(19)
(20)			MCWB	62.3	64.6	66.7	70.0	71.1	75.4	76.2	78.4	76.5	71.9	67.4	64.0	(20)
(21)		2%	DB	94.1	101.9	106.6	108.7	109.0	104.8	99.7	94.6	98.9	102.3	101.1	95.4	(21)
(22)			MCWB	60.3	64.3	66.2	69.3	72.3	76.0	76.4	77.9	77.2	71.7	66.6	62.1	(22)
(23)		5%	DB	91.3	99.0	104.9	107.1	107.4	102.6	97.1	92.7	96.7	100.8	99.6	93.0	(23)
(24)			MCWB	59.3	63.6	65.7	69.0	72.7	76.0	76.3	77.7	77.6	72.2	65.9	60.6	(24)
(25)		10%	DB	88.4	95.7	102.7	105.2	105.5	100.3	94.9	90.9	94.4	99.0	97.6	90.4	(25)
(26)			MCWB	58.3	62.2	65.0	68.7	73.0	76.0	76.4	77.3	77.4	72.8	65.0	60.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.8	70.6	74.8	77.3	79.9	79.9	79.9	80.4	81.0	80.1	73.4	67.4	(27)
(28)			MCD B	89.3	87.8	94.3	97.1	98.6	96.7	91.6	91.5	92.7	94.4	92.0	90.8	(28)
(29)		2%	WB	62.7	67.6	71.3	75.7	78.5	78.6	78.8	79.4	79.9	78.3	70.7	64.7	(29)
(30)			MCD B	88.3	94.9	97.1	98.0	98.1	95.8	90.9	90.1	91.5	92.7	92.5	90.3	(30)
(31)		5%	WB	61.0	65.3	68.4	74.6	77.4	77.9	78.1	78.8	79.1	77.4	69.1	62.8	(31)
(32)			MCD B	87.8	94.9	99.3	97.6	97.2	95.1	90.1	89.1	90.9	91.8	92.2	88.4	(32)
(33)		10%	WB	59.3	63.6	66.5	73.6	76.5	77.3	77.4	78.1	78.4	76.5	67.4	61.2	(33)
(34)			MCD B	86.2	93.7	99.2	96.4	96.5	94.5	89.3	87.9	90.1	90.9	91.5	87.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	27.9	28.0	27.8	24.1	20.3	17.9	16.0	14.2	16.8	21.9	29.9	28.5	(35)
(36)			MCDBR	32.4	32.3	30.2	26.3	22.6	20.0	18.8	16.5	19.9	24.1	30.5	31.0	(36)
(37)			MCWBR	11.8	11.5	10.2	8.9	6.7	4.7	4.7	4.5	5.3	6.8	9.6	11.0	(37)
(38)		5% WB	MCDBR	31.3	29.9	27.8	19.9	19.5	18.0	16.4	15.5	17.0	19.7	28.6	29.7	(38)
(39)			MCWBR	12.5	11.9	11.0	7.2	6.4	5.2	5.5	5.6	6.0	6.1	9.9	11.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.560	0.602	0.705	0.724	0.730	0.709	0.640	0.593	0.579	0.613	0.542	0.522	(40)	
(41)		taud	1.754	1.640	1.462	1.519	1.510	1.572	1.743	1.838	1.851	1.737	1.776	1.825	(41)	
(42)		Ebn at Noon	234	231	212	208	203	205	221	234	238	226	237	240	(42)	
(43)		Edh at Noon	70	82	100	94	93	87	73	67	67	73	68	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1761	1925	2037	2085	2042	1925	1878	1824	1937	1909	1807	1711	(44)	
(45)		RadStd	76	94	105	100	59	69	46	78	53	62	43	57	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (1 neighbor)	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(47)

Nomenclature: See separate page