

DORI, Burkina FasoWMO: **655010**Lat: **14.033N**Lon: **0.033W**Elev: **277**StdP: **98.04**Time Zone: **0.00 (E00)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.2	15.6	-9.4	1.8	29.7	-7.5	2.1	29.6	5.5	28.4	5.1	27.9	0.1	0	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.3	42.6	21.4	41.8	21.3	40.9	21.2	26.6	33.7	26.2	33.3	25.9	33.0	1.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	20.8	29.3	24.6	20.2	29.1	24.2	19.7	29.0	84.9	33.7	83.1	33.4	81.6	33.0	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.0	4.2	3.5	DB	11.7	45.0	0.9	0.6	11.1	45.5	10.6	45.8	10.1	46.2	9.4	46.7	
			WB	5.9	28.2	0.8	0.9	5.3	28.8	4.9	29.3	4.4	29.8	3.8	30.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.8	23.8	27.3	31.2	34.1	35.1	32.7	29.9	28.4	29.9	31.5	28.6	24.8
	DBStd	3.94	2.04	2.78	2.62	2.08	1.98	2.37	2.15	1.78	1.87	1.53	1.83	2.12
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	7222	428	484	656	724	779	681	618	572	597	667	559	458
	CDD18.3	4180	169	251	398	474	521	431	359	313	347	408	309	199
	CDH23.3	59507	1893	3209	6022	7836	8682	6642	4815	3722	4544	5815	4084	2243
	CDH26.7	36394	869	1846	3944	5516	6216	4306	2574	1656	2382	3506	2476	1104
Wind	WSAvg	1.1	1.0	1.2	1.2	1.2	1.6	1.7	1.3	1.0	0.8	0.7	0.6	0.8
Precipitation	PrecAvg	468	0	0	2	5	25	62	116	166	73	17	0	0
	PrecMax	725	9	2	26	88	95	198	205	262	161	61	2	1
	PrecMin	288	0	0	0	0	0	26	46	70	15	1	0	0
	PrecStd	103	2	0	6	17	25	39	36	47	34	17	0	0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.9	40.7	42.4	43.7	44.0	41.9	39.0	36.1	38.7	40.0	39.2	37.2
		MCWB	16.8	18.1	19.3	21.1	21.7	24.1	24.5	25.8	24.7	22.2	19.7	17.8
	2%	DB	34.5	38.8	41.4	42.6	42.8	40.5	37.6	34.8	37.2	39.0	38.4	35.2
		MCWB	15.7	17.9	19.0	20.7	22.4	24.4	24.7	25.5	25.1	22.1	19.2	16.7
	5%	DB	32.9	37.2	40.5	41.7	41.9	39.2	36.2	33.7	35.9	38.2	37.6	33.9
		MCWB	15.2	17.6	18.7	20.5	22.6	24.5	24.6	25.4	25.3	22.4	18.8	15.9
	10%	DB	31.3	35.4	39.3	40.7	40.8	37.9	34.9	32.7	34.7	37.2	36.5	32.4
		MCWB	14.6	16.8	18.3	20.4	22.8	24.5	24.6	25.2	25.2	22.7	18.3	15.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.2	21.4	23.8	25.2	26.6	26.6	26.6	26.9	27.2	26.7	23.0	19.7
		MCDB	31.8	31.0	34.6	36.2	37.0	35.9	33.1	33.1	33.7	34.7	33.3	32.7
	2%	WB	17.1	19.8	21.8	24.3	25.8	25.9	26.0	26.3	26.6	25.7	21.5	18.1
		MCDB	31.3	34.9	36.2	36.7	36.7	35.5	32.7	32.3	33.1	33.7	33.6	32.4
	5%	WB	16.1	18.5	20.2	23.7	25.2	25.5	25.6	26.0	26.2	25.2	20.6	17.1
		MCDB	31.0	34.9	37.4	36.4	36.2	35.1	32.3	31.7	32.7	33.2	33.4	31.3
	10%	WB	15.2	17.5	19.2	23.1	24.7	25.2	25.2	25.6	25.8	24.7	19.7	16.2
		MCDB	30.1	34.3	37.3	35.8	35.8	34.7	31.8	31.0	32.3	32.7	33.0	30.5
Mean Daily Temperature Range	5% DB	MDBR	15.5	15.5	15.4	13.4	11.3	10.0	8.9	7.9	9.3	12.2	16.6	15.8
		MCDBR	18.0	17.9	16.8	14.6	12.6	11.1	10.5	9.2	11.0	13.4	16.9	17.2
		MCWBR	6.5	6.4	5.6	4.9	3.7	2.6	2.6	2.5	2.9	3.8	5.4	6.1
	5% WB	MCDBR	17.4	16.6	15.4	11.1	10.8	10.0	9.1	8.6	9.5	11.0	15.9	16.5
		MCWBR	7.0	6.6	6.1	4.0	3.5	2.9	3.1	3.1	3.4	3.4	5.5	6.4
Clear-Sky Solar Irradiance	taub	0.560	0.602	0.705	0.724	0.730	0.709	0.640	0.593	0.579	0.613	0.542	0.522	
	taud	1.754	1.640	1.462	1.519	1.510	1.572	1.743	1.838	1.851	1.737	1.776	1.825	
	Ebn at Noon	737	728	668	656	641	647	696	738	751	711	746	756	
	Edh at Noon	221	257	314	296	294	273	231	212	210	230	214	201	
All-Sky Solar Radiation	RadAvg	5.55	6.07	6.42	6.57	6.44	6.07	5.92	5.75	6.11	6.02	5.70	5.39	
	RadStd	0.24	0.30	0.33	0.32	0.19	0.22	0.14	0.24	0.17	0.20	0.14	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page