

OUAGADOUGOU, Burkina Faso

WMO: 655030

Lat: 12.353N

Lon: 1.512W

Elev: 316

StdP: 97.58

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.2	17.2	-10.0	1.7	31.6	-8.0	2.0	30.7	8.4	26.6	7.6	27.1	1.6	40	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.6	41.0	20.5	40.1	20.5	39.1	20.6	26.6	33.3	26.2	32.8	25.8	32.3	3.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	21.0	28.4	24.7	20.5	28.3	24.2	19.8	28.1	85.3	33.7	83.3	33.0	81.7	32.8	35.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.6	6.7	6.0	DB	14.0	42.5	0.9	0.5	13.3	42.8	12.8	43.1	12.3	43.3	11.6	43.6	(4)
			WB	6.8	28.9	0.8	1.6	6.2	30.1	5.8	31.0	5.3	31.9	4.8	33.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	29.0	25.2	28.3	31.8	33.5	32.6	30.1	27.7	26.8	27.7	29.8	28.6	25.8	(6)
(7)		DBStd	3.12	1.95	2.41	2.05	1.80	2.20	2.03	1.71	1.38	1.56	1.34	1.51	1.77	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6934	471	512	677	704	702	602	550	522	531	613	559	491	(10)
(11)		CDD18.3	3892	212	279	418	454	443	352	292	264	281	355	309	233	(11)
(12)		CDH23.3	50980	2382	3670	6388	7194	6713	4767	3184	2466	2978	4512	4030	2697	(12)
(13)		CDH26.7	28987	1199	2148	4147	4840	4320	2609	1341	867	1277	2422	2379	1438	(13)
(14)	Wind	WSAvg	2.8	3.0	2.9	2.7	3.0	3.5	3.4	2.9	2.5	2.3	2.3	2.1	2.8	(14)
(15)	Precipitation	PrecAvg	768	0	0	5	24	66	97	189	221	136	31	2	1	(15)
(16)		PrecMax	1185	3	13	39	96	255	262	368	453	330	124	26	14	(16)
(17)		PrecMin	540	0	0	0	0	8	26	91	92	24	0	0	0	(17)
(18)		PrecStd	151	1	2	9	25	39	44	54	68	56	24	5	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.0	40.2	41.5	42.0	41.2	38.9	35.8	33.9	35.2	38.0	38.1	37.0	(19)
(20)		MCWB	16.3	17.8	19.0	20.4	22.5	24.5	24.9	25.7	25.4	21.4	19.4	17.4	(20)	
(21)		2%	DB	35.1	38.9	40.4	41.1	40.1	37.2	34.2	32.4	34.2	37.0	37.2	35.9	(21)
(22)		MCWB	15.9	17.7	18.8	20.7	23.5	24.7	24.8	25.2	25.5	22.0	19.0	17.2	(22)	
(23)		5%	DB	34.0	37.7	39.8	40.2	39.1	36.1	33.1	31.8	33.2	36.1	36.8	34.9	(23)
(24)		MCWB	15.4	17.4	18.6	20.8	23.9	24.6	24.8	25.0	25.4	22.7	18.9	16.3	(24)	
(25)		10%	DB	32.8	36.1	38.9	39.2	38.0	35.0	32.1	30.8	32.2	35.1	35.9	33.5	(25)
(26)		MCWB	15.0	16.7	18.5	21.1	24.1	24.5	24.6	24.7	25.1	23.3	18.7	15.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	23.5	25.0	26.1	27.0	26.7	26.7	27.1	26.7	24.6	20.2	(27)	
(28)		MCDWB	28.1	34.2	35.6	36.3	35.6	34.6	32.0	31.5	32.8	33.3	32.7	31.4	(28)	
(29)		2%	WB	17.2	21.3	23.8	25.3	26.3	26.1	25.9	26.0	26.2	26.0	23.4	18.3	(29)
(30)		MCDWB	32.7	30.8	34.3	35.3	35.0	33.9	31.5	30.4	31.6	32.8	31.6	33.1	(30)	
(31)		5%	WB	16.3	19.3	22.8	24.8	25.9	25.7	25.5	25.6	25.9	25.5	22.4	17.3	(31)
(32)		MCDWB	32.2	33.7	33.2	34.6	34.6	33.1	30.9	29.7	31.1	32.1	30.6	32.3	(32)	
(33)		10%	WB	15.4	17.5	21.6	24.2	25.5	25.3	25.1	25.2	25.6	25.0	21.4	16.5	(33)
(34)		MCDWB	31.2	34.8	33.3	34.1	34.1	32.4	30.3	29.1	30.5	31.4	30.7	31.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	14.9	14.8	13.7	11.6	10.4	9.4	8.4	7.8	8.9	11.2	15.2	15.5	(35)	
(36)		5% DB	MCDBR	16.5	16.5	14.6	12.7	11.3	10.6	9.6	9.1	10.1	12.5	15.7	16.9	(36)
(37)		MCWBR	6.0	6.0	6.0	5.5	4.1	3.5	3.3	3.5	3.8	4.1	4.9	5.7	(37)	
(38)		5% WB	MCDBR	15.4	13.7	11.6	10.9	10.4	9.7	8.9	8.4	9.5	10.8	12.7	15.7	(38)
(39)		MCWBR	6.1	6.3	6.6	4.6	4.0	3.7	3.8	3.7	4.0	4.0	5.1	5.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.596	0.661	0.767	0.747	0.711	0.670	0.600	0.565	0.562	0.625	0.563	0.541	(40)	
(41)		taud	1.715	1.584	1.425	1.546	1.584	1.676	1.866	1.944	1.937	1.773	1.794	1.831	(41)	
(42)		Ebn at Noon	715	688	630	642	652	670	723	759	766	707	736	748	(42)	
(43)		Edh at Noon	232	274	327	289	273	245	204	191	193	224	213	202	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.55	5.85	6.08	6.23	6.09	5.79	5.50	5.32	5.65	5.93	5.64	5.45	(44)	
(45)		RadStd	0.31	0.30	0.33	0.29	0.21	0.21	0.23	0.20	0.17	0.17	0.14	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page