

BOROMO, Burkina Faso

WMO: 655160

Lat: 11.750N

Lon: 2.933W

Elev: 271

StdP: 98.11

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.4	17.4	-8.6	1.9	30.0	-6.2	2.3	29.9	5.5	30.4	5.2	30.1	0.1	40	0.333

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.1	40.4	21.1	39.6	21.2	38.8	21.3	26.7	33.0	26.4	32.7	26.1	32.4	1.9	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	21.1	29.2	24.9	20.6	29.0	24.6	20.2	28.8	85.5	33.2	84.0	32.6	82.7	32.6	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.2	4.4	3.6	13.7	42.5	1.0	0.6	13.0	43.0	12.4	43.4	11.8	43.7	11.0	44.2
			6.9	27.5	0.8	0.6	6.4	27.9	5.9	28.2	5.5	28.6	4.9	29.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.8	25.5	28.6	31.9	32.9	31.9	29.7	27.6	26.7	27.4	28.9	28.4	26.0
	DBStd	2.93	1.94	2.45	1.94	1.97	2.09	2.04	1.70	1.27	1.39	1.31	1.42	1.71
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6859	481	522	680	688	678	591	545	517	522	587	553	497
	CDD18.3	3817	222	288	422	438	419	341	287	259	272	328	303	239
	CDH23.3	48906	2599	3824	6484	6849	6211	4428	3020	2356	2680	3908	3747	2799
	CDH26.7	27273	1367	2264	4205	4507	3844	2319	1234	773	1071	1983	2191	1515
Wind	WSAvg	1.1	1.2	1.3	1.4	1.5	1.6	1.3	1.0	0.8	0.6	0.8	0.7	1.0
Precipitation	PrecAvg	888	1	1	7	38	80	120	186	252	161	43	4	1
	PrecMax	1136	28	12	58	171	194	260	319	443	279	142	46	30
	PrecMin	543	0	0	0	0	0	49	64	94	73	0	0	0
	PrecStd	144	5	2	11	33	43	41	60	77	53	35	8	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.4	40.4	41.2	41.6	40.5	38.3	35.7	33.2	34.5	37.2	37.9	37.1
		MCWB	17.7	19.2	19.7	22.0	23.4	25.2	25.3	26.1	26.1	22.8	19.9	18.2
	2%	DB	35.6	38.8	40.2	40.5	39.2	37.0	34.0	32.2	33.5	36.1	37.1	35.7
		MCWB	16.4	18.7	19.7	21.9	24.3	25.4	25.5	25.8	26.1	23.7	19.8	17.5
	5%	DB	34.3	37.7	39.5	39.6	38.2	35.8	32.9	31.3	32.7	35.1	36.4	34.6
		MCWB	15.9	18.2	19.7	22.1	24.6	25.3	25.3	25.5	25.9	24.1	19.8	17.1
	10%	DB	33.1	36.3	38.7	38.6	37.1	34.6	31.9	30.5	31.7	34.2	35.7	33.5
		MCWB	15.5	17.6	19.7	22.4	24.7	25.2	25.1	25.3	25.7	24.5	19.8	16.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.9	23.5	25.2	26.2	27.1	26.7	26.6	26.7	27.2	27.0	25.1	22.9
		MCDB	26.7	34.0	36.0	35.7	35.2	34.2	32.1	31.3	32.3	32.6	32.7	31.8
	2%	WB	17.8	22.1	24.2	25.7	26.5	26.3	26.2	26.2	26.6	26.4	24.1	19.7
		MCDB	33.6	32.9	35.0	35.2	34.6	33.7	31.7	30.7	31.8	32.2	31.7	32.5
	5%	WB	16.8	20.6	23.6	25.2	26.1	26.0	25.8	25.9	26.2	25.9	23.5	18.2
		MCDB	32.6	33.0	34.1	34.7	34.2	33.4	31.2	30.2	31.4	32.0	31.2	32.6
	10%	WB	15.9	18.6	22.9	24.8	25.7	25.6	25.4	25.5	25.9	25.5	22.7	17.3
		MCDB	31.7	35.0	33.3	34.2	33.7	32.6	30.6	29.6	30.8	31.5	30.6	31.9
Mean Daily Temperature Range	5% DB	MDBR	15.2	14.7	13.2	11.1	10.2	9.2	8.1	7.1	8.4	10.9	15.9	15.8
		MCDBR	17.1	16.4	14.3	12.5	11.4	10.7	9.4	8.4	9.8	12.5	16.5	16.9
		MCWBR	5.9	6.0	5.4	4.2	2.9	2.8	2.9	3.3	3.8	3.4	4.7	5.6
	5% WB	MCDBR	16.4	13.8	11.3	10.6	10.5	9.7	8.7	7.9	9.3	10.5	12.8	15.9
		MCWBR	6.1	6.4	5.0	3.7	3.2	3.1	3.3	3.5	4.0	3.7	4.0	6.0
Clear-Sky Solar Irradiance	taub	0.569	0.637	0.752	0.714	0.664	0.618	0.553	0.525	0.527	0.589	0.552	0.525	
	taud	1.802	1.664	1.491	1.637	1.704	1.814	2.012	2.089	2.061	1.884	1.871	1.908	
	Ebn at Noon	741	709	641	663	684	706	758	790	795	737	750	766	
	Edh at Noon	214	254	307	263	242	213	176	165	171	201	198	188	
All-Sky Solar Radiation	RadAvg	5.65	5.91	6.11	6.14	6.05	5.73	5.41	5.18	5.51	5.88	5.67	5.54	
	RadStd	0.29	0.30	0.28	0.24	0.23	0.22	0.21	0.20	0.18	0.16	0.16	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page