

PO, Burkina Faso

WMO: 655180

Lat: 11.150N

Lon: 1.150W

Elev: 1056

StdP: 14.14

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	64.1	66.0	13.4	11.3	86.1	18.1	14.2	85.4	11.6	75.6	9.8	77.8	3.1	0	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	19.1	103.4	70.6	102.0	70.5	100.5	70.3	81.0	91.5	80.3	90.7	79.6	90.0	5.1	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.6	154.2	86.7	77.7	149.6	85.6	77.0	146.2	84.8	45.7	91.2	44.8	90.8	44.1	90.5	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	11.0	9.5	DB	58.9	106.8	2.6	0.9	57.0	107.5	55.5	108.0	54.0	108.5	52.2	109.2	(4)
(5)			WB	45.2	83.2	2.3	1.5	43.6	84.3	42.3	85.1	41.0	86.0	39.3	87.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	83.4	79.6	85.4	90.0	90.4	87.3	83.1	80.1	78.9	80.0	83.0	83.7	79.8	(6)
(7)		DBStd	5.02	3.52	3.98	3.23	3.57	3.93	3.46	2.68	2.32	2.46	2.41	2.28	3.11	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12194	916	990	1240	1213	1158	992	934	896	900	1022	1011	922	(10)
(11)		CDD65	6719	451	570	775	763	693	542	469	431	450	557	561	457	(11)
(12)		CDH74	81301	5015	7533	11772	11556	9689	6434	4358	3380	3975	6053	6609	4927	(12)
(13)		CDH80	42952	2585	4359	7504	7372	5553	2927	1472	924	1384	2785	3594	2493	(13)
(14)	Wind	WSAvg	3.8	4.7	4.6	4.4	4.9	4.8	4.1	3.3	2.9	2.5	2.6	4.1	(14)	
(15)	Precipitation	PrecAvg	38.4	0.0	0.2	0.4	2.2	3.6	5.1	7.2	11.0	6.7	1.9	0.1	0.1	(15)
(16)		PrecMax	47.3	0.4	1.7	1.5	6.1	7.5	9.6	11.7	17.3	10.2	4.3	0.4	0.9	(16)
(17)		PrecMin	30.1	0.0	0.0	0.0	0.6	0.9	1.7	4.1	7.0	3.4	0.4	0.0	0.0	(17)
(18)		PrecStd	4.6	0.1	0.4	0.5	1.3	1.5	1.9	2.0	2.9	2.0	1.1	0.1	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.1	104.2	105.1	105.3	103.2	97.9	92.6	90.0	92.1	97.0	99.0	98.0	(19)
(20)			MCWB	62.4	65.8	69.4	72.6	76.8	78.0	77.4	79.3	79.3	74.0	68.4	64.8	(20)
(21)		2%	DB	96.6	101.6	103.3	103.4	100.6	95.4	90.4	88.1	90.4	95.1	97.8	95.8	(21)
(22)			MCWB	62.2	66.8	68.9	72.7	77.3	78.0	77.7	78.4	79.3	75.8	68.7	63.9	(22)
(23)		5%	DB	94.4	99.7	102.0	101.8	98.4	93.3	88.6	86.6	88.9	93.4	96.4	94.0	(23)
(24)			MCWB	61.5	66.3	68.3	73.1	77.8	77.9	77.4	77.8	78.9	76.9	68.8	63.0	(24)
(25)		10%	DB	92.1	97.5	100.5	100.0	96.3	91.2	87.0	85.0	87.1	91.5	94.9	91.6	(25)
(26)			MCWB	60.6	65.1	68.0	73.5	77.6	77.4	77.0	77.3	78.4	77.6	69.0	62.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.5	76.2	79.6	81.5	81.8	80.9	80.2	80.9	81.9	81.8	78.6	73.2	(27)
(28)			MCD B	84.5	93.8	94.8	99.8	96.2	92.2	88.6	88.0	88.9	90.4	91.8	87.4	(28)
(29)		2%	WB	66.0	73.9	77.3	79.2	80.5	80.0	79.1	79.2	80.7	80.7	76.7	68.3	(29)
(30)			MCD B	91.4	91.4	94.2	96.0	94.1	90.8	87.0	86.0	88.1	89.6	89.9	88.9	(30)
(31)		5%	WB	63.6	71.7	75.7	78.2	79.7	79.2	78.3	78.3	79.7	79.7	75.5	65.7	(31)
(32)			MCD B	90.9	90.2	92.3	94.1	93.0	89.7	85.9	84.7	87.0	88.9	88.8	89.0	(32)
(33)		10%	WB	61.8	69.1	74.5	77.3	79.0	78.4	77.6	77.6	78.7	78.8	74.1	64.0	(33)
(34)			MCD B	89.5	90.7	91.4	92.8	92.0	88.4	84.9	83.6	85.8	88.2	87.0	88.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	25.7	24.1	21.5	19.1	17.2	14.9	13.1	12.0	14.0	18.4	25.2	26.1	(35)
(36)			MCDBR	28.3	25.7	23.2	21.1	19.4	17.7	15.5	14.2	16.3	20.9	26.0	27.7	(36)
(37)			MCWBR	11.3	11.1	9.6	6.8	5.6	5.3	5.6	6.0	7.6	7.7	9.9	10.7	(37)
(38)		5% WB	MCDBR	26.8	21.0	19.4	19.0	17.5	15.8	14.2	13.3	15.5	18.1	21.5	26.4	(38)
(39)			MCWBR	12.3	11.5	8.1	6.1	6.0	6.0	6.1	6.2	8.0	8.0	9.2	11.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.620	0.692	0.784	0.734	0.665	0.614	0.553	0.530	0.535	0.608	0.582	0.569	(40)	
(41)		taud	1.707	1.581	1.459	1.616	1.701	1.821	2.010	2.073	2.035	1.835	1.809	1.817	(41)	
(42)		Ebn at Noon	222	213	197	206	216	225	240	250	250	229	230	232	(42)	
(43)		Edh at Noon	75	88	101	85	77	67	56	53	56	67	67	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1773	1845	1892	1925	1885	1758	1630	1569	1671	1844	1791	1740	(44)	
(45)		RadStd	87	83	85	69	73	61	70	59	56	60	44	58	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page