

BONDOUKOU, Côte d'Ivoire

WMO: 655450

Lat: 8.050N

Lon: 2.783W

Elev: 1214

StdP: 14.06

Time Zone: 0.00 (E00)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	66.4	68.0	28.7	23.7	80.8	33.0	28.8	82.4	10.3	78.4	9.2	76.8	0.2	320	0.236

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	19.7	97.8	70.3	96.3	70.5	94.7	71.1	79.2	89.1	78.6	88.8	78.1	88.1	0.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	145.3	84.7	75.6	140.4	83.7	75.3	138.7	83.3	43.9	89.6	43.1	89.1	42.5	88.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.8	7.0	5.7	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.4	81.7	84.2	84.4	82.7	81.5	79.1	77.3	76.4	77.6	79.5	81.1	80.2
	DBStd	3.35	2.54	2.51	2.62	2.57	2.42	2.22	1.93	1.95	1.90	2.02	1.66	2.29
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11113	983	957	1066	982	976	872	847	817	829	913	933	938
	CDD65	5638	518	537	601	532	511	422	382	352	379	448	483	473
	CDH74	51414	5393	6294	7105	5905	5170	3326	2251	1745	2257	3471	4175	4322
CDH80	21511	2817	3354	3603	2646	2065	979	438	274	515	1171	1686	1963	
Wind	WSAvg	1.5	0.9	1.2	1.6	1.7	1.6	1.9	2.2	2.2	1.5	1.1	1.2	0.9
Precipitation	PrecAvg	44.1	0.4	1.0	3.4	5.4	6.2	6.2	3.7	3.3	6.7	5.1	1.3	0.4
	PrecMax	63.1	3.1	6.7	9.1	9.8	11.9	13.9	11.0	8.4	13.8	13.8	5.5	2.1
	PrecMin	32.1	0.0	0.0	0.0	1.3	1.6	1.8	0.2	0.0	1.6	0.1	0.0	0.0
	PrecStd	8.5	0.7	1.3	2.1	2.2	2.8	2.8	2.7	2.2	2.7	2.6	1.3	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.3	100.2	99.8	96.8	94.2	90.7	88.0	86.4	89.3	91.7	93.9	95.4
		MCWB	66.7	70.0	71.6	77.0	77.6	77.4	75.9	75.2	76.9	76.6	74.0	67.6
	2%	DB	96.4	98.0	97.7	94.3	91.8	88.2	85.8	84.5	86.3	89.6	91.7	93.4
		MCWB	66.6	69.1	72.4	77.2	77.6	76.8	75.5	74.9	76.1	77.0	75.5	68.1
	5%	DB	94.6	96.2	95.9	92.5	90.2	86.8	84.1	82.8	84.6	87.8	90.2	91.5
		MCWB	66.8	69.6	72.9	77.3	77.4	76.5	74.9	74.5	75.6	76.7	75.9	68.5
	10%	DB	92.5	94.2	93.8	90.8	88.7	85.3	82.4	81.3	83.0	86.0	88.5	89.6
		MCWB	66.3	69.6	73.8	77.2	77.2	76.1	74.4	74.0	75.1	76.5	76.0	69.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.0	78.3	79.9	80.0	79.7	78.6	77.3	77.1	78.2	79.3	80.3	78.3
		MCDB	90.1	91.3	92.1	90.2	88.8	87.7	84.6	83.5	85.9	86.9	88.0	88.2
	2%	WB	75.6	77.0	78.3	79.1	78.7	77.6	76.2	75.6	77.0	78.1	78.6	77.0
		MCDB	87.1	90.6	90.6	89.9	88.8	86.1	83.4	82.1	84.9	86.3	87.9	86.9
	5%	WB	74.5	76.0	77.5	78.4	78.1	77.0	75.4	74.9	76.1	77.3	77.7	76.1
		MCDB	84.9	88.5	89.7	89.2	87.8	85.3	82.2	81.3	83.2	85.6	86.9	85.2
	10%	WB	73.2	75.0	76.7	77.7	77.5	76.3	74.7	74.3	75.4	76.7	76.9	75.2
		MCDB	82.7	86.5	88.6	88.2	86.8	83.9	80.9	80.1	81.8	84.6	85.9	83.4
Mean Daily Temperature Range	5% DB	MDBR	24.2	22.2	19.7	17.0	15.3	13.1	11.1	10.6	12.5	15.2	17.4	21.3
		MCDBR	26.4	24.6	22.5	19.2	17.3	15.2	13.4	13.0	14.6	17.3	19.3	23.8
		MCWBR	10.9	10.9	8.2	6.1	6.0	5.7	4.8	5.0	6.2	6.7	6.8	9.2
	5% WB	MCDBR	21.5	21.1	19.1	17.3	16.1	14.5	12.7	11.9	13.9	16.2	17.4	18.7
MCWBR		9.6	8.8	7.1	6.7	6.2	5.8	5.1	5.0	6.3	7.0	7.1	7.8	
Clear-Sky Solar Irradiance	taub		0.682	0.715	0.780	0.630	0.535	0.498	0.470	0.457	0.465	0.518	0.571	0.625
	taud		1.653	1.629	1.538	1.844	2.050	2.173	2.288	2.327	2.296	2.098	1.905	1.770
	Ebn at Noon		211	210	199	229	246	252	260	268	270	255	237	221
	Edh at Noon		80	84	94	68	54	47	42	41	43	52	62	70
All-Sky Solar Radiation	RadAvg		1642	1662	1716	1746	1677	1436	1253	1168	1294	1526	1556	1527
	RadStd		68	63	69	66	58	66	68	63	57	73	47	53

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page