

BONDOUKOU, Côte d'Ivoire

WMO: 655450

Lat: 8.050N

Lon: 2.783W

Elev: 370

StdP: 96.96

Time Zone: 0.00 (E00)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.1	20.0	-1.8	3.4	27.1	0.6	4.1	28.0	4.6	25.8	4.1	24.9	0.1	320	0.236

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	10.9	36.5	21.3	35.7	21.4	34.8	21.7	26.2	31.7	25.9	31.6	25.6	31.1	0.4	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.8	29.3	24.2	20.1	28.7	24.0	19.8	28.5	84.2	32.0	82.4	31.7	81.0	31.5	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 3.5	3.1	2.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.9	27.6	29.0	29.1	28.2	27.5	26.2	25.2	24.6	25.4	26.4	27.3	26.8		
	DBStd	1.86	1.41	1.39	1.46	1.43	1.34	1.23	1.07	1.08	1.05	1.12	0.92	1.27		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6174	546	532	592	546	542	484	471	454	461	507	518	521		
	CDD18.3	3132	288	298	334	296	284	234	212	196	211	249	268	263		
	CDH23.3	28563	2996	3497	3947	3281	2872	1848	1251	969	1254	1928	2319	2401		
(13)	CDH26.7	11951	1565	1863	2002	1470	1147	544	243	152	286	651	937	1091		
(14)	Wind	WSAvg	0.7	0.4	0.5	0.7	0.7	0.9	1.0	1.0	0.7	0.5	0.5	0.4		
(15) Precipitation	PrecAvg	1121	9	25	87	137	157	157	93	84	170	129	33	11		
	PrecMax	1602	80	170	232	249	302	352	280	213	351	350	140	54		
	PrecMin	815	0	0	0	34	41	45	6	0	40	3	0	0		
	PrecStd	215	19	33	54	57	70	70	69	56	69	65	34	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.8	37.9	37.7	36.0	34.5	32.6	31.1	30.2	31.8	33.1	34.4	35.2		
		MCWB	19.3	21.1	22.0	25.0	25.4	25.2	24.4	24.0	24.9	24.8	23.4	19.8		
	2%	DB	35.8	36.7	36.5	34.6	33.2	31.2	29.9	29.2	30.2	32.0	33.2	34.1		
		MCWB	19.2	20.6	22.4	25.1	25.3	24.9	24.2	23.8	24.5	25.0	24.2	20.0		
	5%	DB	34.8	35.7	35.5	33.6	32.3	30.4	29.0	28.2	29.2	31.0	32.3	33.1		
		MCWB	19.3	20.9	22.7	25.2	25.2	24.7	23.9	23.6	24.2	24.8	24.4	20.3		
	10%	DB	33.6	34.5	34.4	32.7	31.5	29.6	28.0	27.4	28.3	30.0	31.4	32.0		
		MCWB	19.0	20.9	23.2	25.1	25.1	24.5	23.5	23.4	23.9	24.7	24.4	20.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	25.7	26.6	26.7	26.5	25.9	25.2	25.1	25.7	26.3	26.8	25.7		
		MCDB	32.3	32.9	33.4	32.3	31.6	30.9	29.2	28.6	30.0	30.5	31.1	31.2		
	2%	WB	24.2	25.0	25.7	26.1	25.9	25.3	24.6	24.2	25.0	25.6	25.9	25.0		
		MCDB	30.6	32.5	32.5	32.1	31.6	30.1	28.5	27.9	29.4	30.2	31.1	30.5		
	5%	WB	23.6	24.4	25.3	25.8	25.6	25.0	24.1	23.9	24.5	25.2	25.4	24.5		
		MCDB	29.4	31.4	32.0	31.8	31.0	29.6	27.9	27.4	28.5	29.8	30.5	29.6		
	10%	WB	22.9	23.9	24.8	25.4	25.3	24.6	23.7	23.5	24.1	24.8	25.0	24.0		
		MCDB	28.2	30.3	31.4	31.2	30.4	28.8	27.2	26.7	27.7	29.2	29.9	28.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	12.3	10.9	9.4	8.5	7.3	6.1	5.9	6.9	8.5	9.7	11.8		
		MCDBR	14.7	13.7	12.5	10.7	9.6	8.4	7.5	7.2	8.1	9.6	10.7	13.2		
		MCWBR	6.1	6.1	4.6	3.4	3.3	3.1	2.7	2.8	3.5	3.7	3.8	5.1		
	5% WB	MCDBR	11.9	11.7	10.6	9.6	9.0	8.1	7.0	6.6	7.7	9.0	9.7	10.4		
		MCWBR	5.4	4.9	3.9	3.7	3.5	3.2	2.8	2.8	3.5	3.9	4.0	4.3		
(40) Clear-Sky Solar Irradiance	taub		0.682	0.715	0.780	0.630	0.535	0.498	0.470	0.457	0.465	0.518	0.571	0.625		
	taud		1.653	1.629	1.538	1.844	2.050	2.173	2.288	2.327	2.296	2.098	1.905	1.770		
	Ebn at Noon		666	662	628	721	775	794	821	846	850	804	747	698		
	Edh at Noon		253	266	295	214	170	148	133	130	136	164	195	222		
(44) All-Sky Solar Radiation	RadAvg		5.17	5.24	5.41	5.50	5.29	4.53	3.95	3.68	4.08	4.81	4.91	4.81		
	RadStd		0.21	0.20	0.22	0.21	0.18	0.21	0.21	0.20	0.18	0.23	0.15	0.17		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page