

DIMBOKRO CITY, Côte d'Ivoire

WMO: 655620

Lat: 6.650N

Lon: 4.700W

Elev: 302

StdP: 14.54

Time Zone: 0.00 (E00)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	64.6	68.2	50.4	54.9	85.6	55.7	66.9	80.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	20.3	99.1	80.2	98.0	80.1	96.6	80.0	84.2	95.3	83.4	94.3	82.6	93.3	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	163.0	92.3	80.4	159.8	91.4	79.6	155.4	89.6	48.6	95.6	47.5	94.7	46.7	93.6	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	58.1	86.4	3.8	1.7	55.4	87.6	53.1	88.6	51.0	89.5	48.2	90.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.2	83.6	86.1	86.0	85.5	84.6	82.4	80.8	80.0	81.7	82.7	83.3	82.2	(6)
	DBStd	2.92	3.10	3.02	2.38	2.28	2.23	1.97	1.75	1.73	1.76	1.73	1.50	2.38	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	12125	1041	1011	1115	1066	1073	973	953	929	952	1013	1000	999	(10)
	CDD65	6650	576	591	650	616	608	523	488	464	502	548	550	534	(11)
	CDH74	71195	6747	7486	8056	7519	6942	5087	4213	3741	4520	5405	5807	5672	(12)
(13)	CDH80	33538	3662	4172	4317	3897	3338	2064	1463	1181	1712	2299	2687	2746	(13)
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15) Precipitation	PrecAvg	44.8	0.5	1.9	4.5	5.3	5.7	7.2	3.9	2.9	4.7	4.8	2.2	0.8	(15)
	PrecMax	76.9	3.0	5.8	10.7	12.2	12.2	13.9	11.3	7.7	12.2	12.0	7.5	4.1	(16)
	PrecMin	32.1	0.0	0.0	0.0	0.5	1.9	2.4	0.2	0.0	0.3	0.3	0.0	0.0	(17)
	PrecStd	8.6	0.7	1.4	2.1	2.4	2.3	3.0	2.6	2.1	2.8	2.3	1.7	1.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.7	102.3	100.6	99.2	98.3	94.8	91.8	91.6	93.5	94.9	95.2	96.4	(19)
		MCWB	78.1	78.4	81.2	83.3	83.6	81.8	80.0	78.6	79.8	80.4	80.6	76.5	(20)
	2%	DB	97.9	100.0	98.6	97.5	95.6	92.8	89.9	89.5	91.4	93.1	93.6	94.7	(21)
		MCWB	77.6	79.1	81.7	82.7	82.5	81.2	79.3	78.9	79.6	80.4	80.6	77.9	(22)
	5%	DB	96.1	98.2	97.0	96.2	94.4	91.2	88.5	87.7	89.7	91.5	92.6	93.2	(23)
		MCWB	77.1	78.5	81.2	82.3	82.0	80.6	78.9	78.4	79.1	80.1	80.4	78.1	(24)
	10%	DB	94.5	96.4	95.3	94.5	92.9	89.5	87.0	86.0	88.0	89.9	91.2	91.6	(25)
		MCWB	76.5	78.2	80.9	81.8	81.6	79.9	78.4	77.9	78.9	79.7	80.0	78.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.8	83.7	85.0	85.2	85.2	83.5	81.7	81.0	81.8	82.4	82.8	82.6	(27)
		MCDB	95.1	96.7	96.8	96.3	95.0	92.4	89.2	88.2	90.4	91.9	92.2	92.6	(28)
	2%	WB	81.2	82.3	83.8	84.1	83.7	81.9	80.4	79.8	80.7	81.5	81.8	81.3	(29)
		MCDB	93.4	95.8	95.4	95.5	94.0	90.4	88.1	87.0	88.8	90.6	91.4	91.3	(30)
	5%	WB	80.1	81.4	82.8	83.1	82.7	81.0	79.5	78.9	79.8	80.8	81.0	80.6	(31)
		MCDB	91.7	93.8	94.3	94.2	92.9	89.4	86.9	86.1	87.8	89.6	90.5	90.3	(32)
	10%	WB	79.1	80.4	81.8	82.2	81.7	80.1	78.7	78.1	79.0	80.0	80.3	79.8	(33)
		MCDB	89.3	91.9	92.9	92.7	91.4	88.2	85.8	84.9	86.8	88.5	89.5	88.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	24.5	22.8	20.3	19.4	17.9	15.5	14.1	13.4	15.1	16.5	18.3	21.3	(35)
		MCDBR	25.4	24.1	22.1	21.1	19.6	17.7	16.4	15.8	16.9	18.0	19.4	22.8	(36)
	5% WB	MCWBR	8.3	7.1	7.6	7.7	7.7	7.2	6.6	6.8	6.8	7.1	7.3	8.4	(37)
		MCWBR	22.2	21.6	20.8	20.5	19.2	16.6	15.1	14.7	15.9	17.3	18.8	19.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.746	0.742	0.777	0.610	0.522	0.497	0.489	0.472	0.468	0.500	0.563	0.670	(40)
		taud	1.583	1.624	1.570	1.900	2.110	2.193	2.223	2.274	2.297	2.183	1.963	1.731	(41)
	Ebn at Noon		199	205	200	233	249	252	255	264	269	261	241	212	(42)
		Edh at Noon	87	85	91	64	51	46	45	43	43	48	59	74	(43)
(44) All-Sky Solar Radiation	RadAvg		1542	1536	1626	1680	1583	1336	1225	1161	1249	1434	1481	1431	(44)
	RadStd		72	61	69	62	55	70	62	76	59	62	47	52	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page