

YAMO USSOUKRO, Côte d'Ivoire

WMO: 655630

Lat: 6.903N

Lon: 5.366W

Elev: 213

StdP: 98.79

Time Zone: 0.00 (E00)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.4	17.4	5.3	5.7	30.6	9.0	7.3	28.2	6.2	25.7	5.5	26.0	0.6	0	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	11.0	36.1	23.7	35.2	24.0	34.5	24.3	27.1	32.4	26.7	32.0	26.5	31.7	2.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.8	21.7	29.9	25.3	20.9	29.5	25.1	20.7	29.3	87.1	32.9	85.4	32.4	84.3	32.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.0	5.3	4.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			11.9	28.2	2.2	0.5	10.4	28.6	9.1	28.9	7.9	29.1	6.3	29.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	26.7	28.7	28.7	28.5	27.9	26.8	25.8	25.6	26.4	26.9	27.0	26.0	(6)	(7)
	DBStd	1.62	1.98	1.59	1.30	1.21	1.13	1.04	0.92	0.88	0.92	0.90	0.75	1.50	(7)	(8)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	(9)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	(10)
	CDD10.0	6236	519	524	580	555	505	491	483	493	523	511	497		(10)	(11)
	CDD18.3	3194	261	291	322	305	297	255	233	224	243	265	261	239	(11)	(12)
	CDH23.3	28798	2771	3268	3549	3266	2907	2053	1542	1389	1705	2029	2157	2162	(12)	(13)
	CDH26.7	12386	1458	1741	1764	1532	1249	708	402	324	535	758	915	999	(13)	(14)
(14) Wind	WSAvg	2.3	1.9	2.5	2.7	2.5	2.4	2.4	2.7	2.7	2.3	2.0	1.8	1.6	(14)	(15)
(15) Precipitation	PrecAvg	1142	10	51	102	142	145	161	91	86	125	125	56	19	(15)	(16)
	PrecMax	1514	71	173	211	201	287	330	182	154	232	225	116	79	(16)	(17)
	PrecMin	907	0	4	8	87	55	72	9	9	46	44	8	0	(17)	(18)
	PrecStd	176	18	40	49	36	56	65	47	41	57	50	27	21	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.1	37.8	37.1	36.0	34.9	33.1	31.5	31.6	32.2	33.0	33.9	34.7	(19)	(20)
		MCWB	22.7	23.6	23.9	26.3	26.7	25.9	25.1	24.5	25.6	26.0	25.4	21.9	(20)	(21)
	2%	DB	35.1	36.2	35.8	34.8	33.8	32.1	30.7	30.2	31.4	32.1	32.9	33.4	(21)	(22)
		MCWB	22.3	23.2	24.7	26.4	26.5	25.8	24.9	24.5	25.3	25.6	25.7	22.6	(22)	(23)
	5%	DB	34.2	35.3	34.8	34.0	32.9	31.2	29.9	29.5	30.8	31.6	32.1	32.7	(23)	(24)
		MCWB	22.3	23.3	25.0	26.5	26.3	25.7	24.8	24.4	25.1	25.5	25.5	22.8	(24)	(25)
	10%	DB	33.3	34.6	33.8	33.1	32.0	30.3	29.0	28.6	29.8	30.8	31.3	31.8	(25)	(26)
		MCWB	22.3	23.6	25.5	26.3	26.1	25.5	24.6	24.2	25.0	25.4	25.5	23.0	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	26.7	27.2	27.7	27.5	26.7	26.1	25.7	26.4	27.0	26.9	26.2	(27)	(28)
		MCDB	32.6	33.6	32.9	33.2	32.2	30.9	30.0	29.3	30.7	31.5	31.6	31.2	(28)	(29)
	2%	WB	25.4	26.1	26.7	27.1	27.0	26.3	25.5	25.2	25.9	26.3	26.4	25.7	(29)	(30)
		MCDB	31.7	32.8	32.7	32.7	32.2	30.6	29.3	28.8	30.1	30.7	31.2	30.6	(30)	(31)
	5%	WB	25.0	25.7	26.3	26.7	26.7	26.0	25.1	24.8	25.5	25.9	26.1	25.4	(31)	(32)
		MCDB	31.0	32.1	32.3	32.2	31.6	30.3	28.8	28.2	29.6	30.2	30.8	30.2	(32)	(33)
	10%	WB	24.5	25.2	26.0	26.4	26.3	25.6	24.7	24.4	25.1	25.5	25.7	25.0	(33)	(34)
		MCDB	30.2	31.4	32.0	31.7	31.1	29.6	28.1	27.7	29.0	29.7	30.3	29.6	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.9	12.9	11.0	10.2	9.4	8.1	7.1	7.0	7.9	8.8	10.2	13.0	(35)	(36)
		MCDBR	15.1	14.0	12.1	11.1	10.2	9.1	8.2	8.0	8.9	9.6	10.8	14.0	(36)	(37)
	5% WB	MCWBR	5.5	4.3	3.8	3.9	3.9	3.5	3.3	3.1	3.5	3.8	4.4	5.4	(37)	(38)
		MCWBR	13.1	12.0	10.9	10.5	9.7	8.6	7.5	7.3	8.3	9.1	10.3	11.4	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.713	0.716	0.761	0.604	0.517	0.488	0.472	0.454	0.456	0.493	0.556	0.651	(39)	(40)
		taud	1.622	1.656	1.588	1.908	2.117	2.218	2.275	2.328	2.327	2.196	1.973	1.755	(40)	(41)
	Ebn at Noon		648	664	641	739	788	801	818	847	858	827	764	683	(41)	(42)
		Edh at Noon	263	260	280	201	158	141	134	130	132	149	183	226	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		4.89	4.92	5.20	5.33	5.04	4.26	3.85	3.71	4.06	4.55	4.59	4.51	(43)	(44)
	RadStd		0.23	0.20	0.20	0.20	0.19	0.23	0.18	0.25	0.18	0.18	0.15	0.19	(44)	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page