

ABIDJAN, Côte d'Ivoire

WMO: 655780

Lat: 5.261N

Lon: 3.926W

Elev: 21

StdP: 14.68

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.1	71.9	57.5	70.5	82.4	65.8	95.1	77.2	16.4	80.6	15.4	80.5	3.7	20	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	11.2	91.2	81.2	90.0	80.6	89.4	80.4	83.9	88.0	83.2	87.1	82.5	86.4	8.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.8	171.2	85.5	82.4	169.1	85.3	81.3	163.0	84.6	48.1	89.7	47.2	87.5	46.5	85.7	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.9	14.3	13.3	DB	66.4	94.5	4.6	3.2	63.1	96.8	60.4	98.6	57.8	100.4	54.5	102.8
			WB	60.2	84.5	4.9	1.8	56.6	85.8	53.7	86.8	51.0	87.8	47.4	89.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.2	81.9	83.3	83.6	83.5	82.4	80.2	78.5	77.3	78.5	80.6	82.4	82.4
	DBStd	2.81	2.28	2.22	2.12	2.16	2.13	1.94	1.58	1.36	1.48	1.75	1.59	1.81
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11387	988	934	1042	1004	1005	906	884	845	854	950	971	1004
	CDD65	5912	523	514	577	554	540	456	419	380	404	485	521	539
	CDH74	58305	5405	5780	6812	6614	6054	4196	2933	2016	2627	4427	5608	5833
	CDH80	17827	1830	2168	2695	2668	2096	836	331	153	302	948	1801	1999
(14) Wind	WSAvg	6.5	5.4	6.4	6.8	6.7	6.4	6.9	7.0	6.7	7.1	7.3	6.4	5.3
(15) Precipitation	PrecAvg	73.7	0.9	1.8	3.9	5.9	11.3	21.1	8.3	1.5	3.0	6.1	6.2	3.1
	PrecMax	144.5	6.1	6.3	10.3	12.5	26.4	45.3	66.9	9.4	15.7	19.3	11.6	10.3
	PrecMin	41.7	0.0	0.0	0.3	0.7	4.8	6.3	0.4	0.1	0.1	0.3	1.9	0.1
	PrecStd	20.3	1.3	1.5	2.4	2.8	5.5	9.3	11.3	1.7	3.1	4.4	2.5	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.3	92.6	92.6	91.8	90.9	88.1	85.3	84.2	85.6	88.4	90.6	91.2
		MCWB	77.7	81.6	82.8	82.4	81.8	80.5	78.4	77.1	78.5	80.1	81.4	80.6
	2%	DB	89.6	90.9	90.1	90.2	89.6	86.4	84.1	82.6	84.0	86.4	88.8	89.4
		MCWB	77.4	81.2	81.2	81.6	81.1	79.6	77.8	76.2	77.5	79.3	80.6	79.2
	5%	DB	88.1	89.5	89.5	89.5	88.1	85.6	82.7	81.8	82.7	85.7	87.8	88.1
		MCWB	78.3	80.5	81.0	81.3	80.8	79.1	76.9	75.9	76.9	79.0	80.3	79.4
	10%	DB	87.4	88.0	88.1	88.1	87.5	84.2	82.1	80.6	82.1	84.3	86.3	87.2
		MCWB	78.5	80.4	80.8	81.0	80.5	78.4	76.6	75.5	76.8	78.4	79.6	79.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.9	84.9	85.2	84.8	83.8	82.6	80.0	78.8	79.8	81.6	83.3	83.8
		MCDB	86.8	88.1	88.6	89.0	87.8	85.6	83.0	81.8	83.0	85.3	87.2	86.8
	2%	WB	82.6	83.5	83.6	83.5	82.6	80.9	78.9	77.6	78.7	80.5	81.9	82.4
		MCDB	86.2	87.6	87.9	87.7	86.6	84.3	82.1	80.6	82.0	84.4	85.9	86.0
	5%	WB	81.4	82.5	82.7	82.6	81.7	80.0	78.0	77.0	78.0	79.7	81.0	81.4
		MCDB	85.2	86.7	86.5	86.7	85.8	83.3	81.2	80.0	81.1	83.4	85.5	85.3
	10%	WB	80.6	81.7	81.9	81.8	80.9	79.1	77.3	76.3	77.3	79.1	80.4	80.7
		MCDB	84.5	85.7	85.8	86.1	85.3	82.5	80.4	79.2	80.4	82.7	84.9	84.9
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	11.7	11.2	11.1	10.5	8.5	7.8	8.1	8.2	9.2	11.1	11.8
		MCDBR	13.6	12.3	11.8	11.8	11.6	10.1	8.7	9.2	9.0	10.3	12.0	12.6
		MCWBR	6.2	5.5	5.5	5.7	5.5	5.0	4.2	4.3	4.2	5.4	5.6	5.7
	5% WB	MCDBR	11.4	11.4	11.3	11.6	11.3	9.8	8.3	8.6	8.8	9.9	11.7	11.5
		MCWBR	5.7	5.9	6.0	6.2	6.0	5.4	4.6	4.9	4.6	5.8	5.8	5.8
(40) Clear-Sky Solar Irradiance	taub		0.792	0.764	0.761	0.587	0.513	0.513	0.521	0.510	0.479	0.480	0.546	0.677
	taud		1.546	1.613	1.614	1.978	2.172	2.171	2.134	2.167	2.284	2.293	2.062	1.752
	Ebn at Noon		190	201	204	238	250	247	246	254	266	267	247	213
	Edh at Noon		91	87	87	59	48	47	49	49	44	43	54	73
(44) All-Sky Solar Radiation	RadAvg		1617	1569	1654	1669	1498	1246	1318	1300	1367	1540	1612	1529
	RadStd		78	68	75	70	60	91	81	89	60	57	46	40

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page