

ABIDJAN, Côte d'Ivoire

WMO: 655780

Lat: 5.261N

Lon: 3.926W

Elev: 6

StdP: 101.25

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.7	22.2	14.1	10.1	28.0	18.8	13.6	25.1	7.3	27.0	6.9	26.9	1.6	20	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.2	32.9	27.3	32.2	27.0	31.9	26.9	28.9	31.1	28.4	30.6	28.1	30.2	3.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.2	24.5	29.7	28.0	24.2	29.6	27.4	23.3	29.2	94.0	32.1	91.9	30.8	90.3	29.8	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.1	6.4	5.9	19.1	34.7	2.5	1.8	17.3	36.0	15.8	37.0	14.3	38.0	12.5	39.3
			15.6	29.2	2.7	1.0	13.7	29.9	12.1	30.5	10.5	31.0	8.6	31.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	27.7	28.5	28.7	28.6	28.0	26.8	25.9	25.1	25.8	27.0	28.0	28.0
	DBStd	1.56	1.27	1.23	1.18	1.20	1.18	1.08	0.88	0.75	0.82	0.97	0.88	1.00
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6326	549	519	579	558	558	503	491	469	474	528	539	558
	CDD18.3	3284	291	286	321	308	300	253	233	211	224	269	289	299
	CDH23.3	32392	3003	3211	3784	3674	3363	2331	1629	1120	1459	2459	3116	3241
	CDH26.7	9904	1017	1204	1497	1482	1164	464	184	85	168	527	1001	1111
Wind	WSAvg	2.9	2.4	2.9	3.1	3.0	2.8	3.1	3.1	3.0	3.2	3.3	2.9	2.4
Precipitation	PrecAvg	1873	22	45	100	149	288	536	211	39	75	154	158	78
	PrecMax	3670	155	160	261	318	670	1150	1700	238	398	489	294	261
	PrecMin	1060	0	0	7	17	123	159	10	3	2	8	47	2
	PrecStd	515	33	39	62	70	140	236	286	43	78	111	64	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	33.7	33.7	33.2	32.7	31.2	29.6	29.0	29.8	31.4	32.6	32.9
		MCWB	25.4	27.6	28.2	28.0	27.6	26.9	25.8	25.1	25.8	26.7	27.4	27.0
	2%	DB	32.0	32.7	32.3	32.3	32.0	30.2	28.9	28.1	28.9	30.2	31.6	31.9
		MCWB	25.2	27.3	27.3	27.6	27.3	26.4	25.4	24.6	25.3	26.3	27.0	26.2
	5%	DB	31.2	31.9	31.9	32.0	31.2	29.8	28.2	27.7	28.1	29.8	31.0	31.2
		MCWB	25.7	26.9	27.2	27.4	27.1	26.2	24.9	24.4	25.0	26.1	26.9	26.3
	10%	DB	30.8	31.1	31.2	31.2	30.8	29.0	27.9	27.0	27.8	29.1	30.2	30.7
		MCWB	25.9	26.9	27.1	27.2	27.0	25.8	24.8	24.2	24.9	25.8	26.5	26.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.9	29.4	29.6	29.3	28.8	28.1	26.6	26.0	26.5	27.6	28.5	28.8
		MCDB	30.4	31.2	31.5	31.7	31.0	29.8	28.3	27.7	28.3	29.6	30.7	30.4
	2%	WB	28.1	28.6	28.7	28.6	28.1	27.2	26.0	25.3	26.0	26.9	27.7	28.0
		MCDB	30.1	30.9	31.0	31.0	30.3	29.0	27.8	27.0	27.8	29.1	30.0	30.0
	5%	WB	27.5	28.1	28.1	28.1	27.6	26.7	25.6	25.0	25.5	26.5	27.2	27.4
		MCDB	29.6	30.4	30.3	30.4	29.9	28.5	27.3	26.7	27.3	28.6	29.7	29.6
	10%	WB	27.0	27.6	27.7	27.7	27.2	26.2	25.2	24.6	25.2	26.1	26.9	27.0
		MCDB	29.2	29.8	29.9	30.0	29.6	28.0	26.9	26.2	26.9	28.2	29.4	29.4
Mean Daily Temperature Range	5% DB	MDBR	7.1	6.5	6.2	6.2	5.8	4.7	4.3	4.5	4.6	5.1	6.2	6.6
		MCDBR	7.6	6.8	6.6	6.5	6.4	5.6	4.8	5.1	5.0	5.7	6.7	7.0
		MCWBR	3.4	3.0	3.0	3.2	3.0	2.8	2.3	2.4	2.3	3.0	3.1	3.2
	5% WB	MCDBR	6.3	6.3	6.3	6.5	6.3	5.4	4.6	4.8	4.9	5.5	6.5	6.4
		MCWBR	3.1	3.3	3.3	3.5	3.3	3.0	2.5	2.7	2.6	3.2	3.2	3.2
Clear-Sky Solar Irradiance	taub	0.792	0.764	0.761	0.587	0.513	0.513	0.521	0.510	0.479	0.480	0.546	0.677	
	taud	1.546	1.613	1.614	1.978	2.172	2.171	2.134	2.167	2.284	2.293	2.062	1.752	
	Ebn at Noon	600	635	642	751	789	778	776	801	839	842	778	670	
	Edh at Noon	286	273	274	187	150	147	154	153	138	136	169	229	
All-Sky Solar Radiation	RadAvg	5.10	4.95	5.21	5.26	4.72	3.93	4.16	4.10	4.31	4.86	5.08	4.82	
	RadStd	0.25	0.21	0.24	0.22	0.19	0.29	0.26	0.28	0.19	0.18	0.15	0.13	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page