

ADIAKE, Côte d'Ivoire

WMO: 655850

Lat: 5.300N

Lon: 3.300W

Elev: 39

StdP: 100.86

Time Zone: 0.00 (E00)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.9	21.8	16.1	11.5	25.4	18.4	13.3	24.7	5.5	26.3	5.1	26.4	0.7	320	0.268

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	7.5	33.1	26.8	32.6	26.7	32.1	26.6	28.0	31.7	27.7	31.3	27.3	30.9	2.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	22.9	30.2	26.7	22.4	29.8	26.3	21.9	29.4	90.0	31.5	88.1	31.6	86.8	31.2	32.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.2	4.3	3.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.0	27.5	28.1	28.4	28.2	27.6	26.3	25.5	25.0	25.8	26.6	27.4	27.4
	DBStd	1.42	1.04	1.05	1.03	1.02	1.02	0.91	0.84	0.75	0.73	0.86	0.73	0.97
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6196	542	508	569	546	544	488	481	465	473	515	523	540
	CDD18.3	3154	283	275	311	296	286	238	223	207	223	257	273	282
	CDH23.3	28637	2806	2894	3426	3263	2891	1908	1431	1089	1411	2099	2652	2769
CDH26.7	8691	1015	1058	1335	1231	927	375	161	91	187	482	876	952	
Wind	WSAvg	1.2	1.0	1.4	1.4	1.3	1.3	1.2	1.5	1.4	1.1	1.0	0.9	0.7
Precipitation	PrecAvg	1873	28	66	100	143	282	497	182	64	109	176	148	54
	PrecMax	2575	145	184	203	267	678	900	600	311	451	385	380	188
	PrecMin	1194	0	3	6	31	124	132	13	4	4	30	34	1
	PrecStd	387	31	44	52	58	118	206	133	64	83	89	81	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	33.7	33.8	33.8	32.9	31.2	29.9	29.2	30.0	31.4	32.6	33.0
		MCWB	25.1	25.9	27.2	27.6	27.3	26.8	25.3	24.3	25.4	26.5	27.2	26.3
	2%	DB	32.2	32.7	33.0	32.9	32.1	30.2	28.9	28.2	29.1	30.7	31.9	32.1
		MCWB	25.7	26.5	27.0	27.3	27.1	26.2	25.0	24.0	25.0	26.3	26.9	26.4
	5%	DB	31.8	32.0	32.3	32.2	31.5	29.5	28.2	27.7	28.4	30.0	31.2	31.6
		MCWB	25.7	26.4	26.8	26.9	26.9	25.8	24.7	23.9	24.7	26.0	26.7	26.4
	10%	DB	31.1	31.3	31.8	31.6	30.7	28.8	27.7	27.0	27.8	29.2	30.8	30.9
		MCWB	25.7	26.3	26.6	26.8	26.7	25.5	24.5	23.7	24.5	25.6	26.6	26.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.1	28.4	28.5	28.4	27.2	26.2	25.1	26.0	27.2	27.9	28.0
		MCDB	31.3	31.9	32.2	32.2	31.7	30.3	28.6	27.5	28.7	30.4	31.6	31.5
	2%	WB	27.2	27.5	27.7	27.8	27.7	26.7	25.6	24.7	25.4	26.6	27.4	27.4
		MCDB	30.9	31.1	31.4	31.6	31.1	29.5	27.9	26.9	28.0	29.8	31.1	31.0
	5%	WB	26.8	27.1	27.3	27.4	27.2	26.2	25.2	24.3	25.1	26.1	27.0	27.0
		MCDB	30.4	30.6	30.9	31.1	30.6	28.8	27.3	26.5	27.5	29.2	30.8	30.7
	10%	WB	26.5	26.7	27.0	27.1	26.9	25.8	24.8	24.1	24.8	25.8	26.7	26.6
		MCDB	29.7	30.0	30.5	30.6	30.1	28.1	26.8	26.2	27.0	28.5	30.1	30.0
Mean Daily Temperature Range	5% DB	MDBR	8.4	7.6	7.5	7.2	6.6	5.2	4.5	4.6	4.8	5.8	7.3	7.9
		MCDBR	9.1	8.2	8.0	7.8	7.7	6.4	5.4	5.5	5.6	6.8	7.9	8.6
		MCWBR	4.0	3.2	3.1	3.3	3.6	3.1	2.3	2.2	2.3	3.1	3.9	4.1
	5% WB	MCDBR	8.1	7.6	7.7	7.6	7.3	6.0	4.9	4.7	5.1	6.4	7.7	7.9
		MCWBR	4.0	3.4	3.4	3.6	3.7	3.2	2.4	2.2	2.3	3.1	3.9	4.1
Clear-Sky Solar Irradiance	taub	0.794	0.767	0.761	0.587	0.512	0.510	0.517	0.507	0.475	0.479	0.547	0.678	
	taud	1.538	1.603	1.609	1.974	2.170	2.175	2.141	2.172	2.293	2.292	2.050	1.745	
	Ebn at Noon	599	633	642	751	790	780	780	803	843	843	777	669	
	Edh at Noon	288	275	275	188	150	147	153	152	137	136	171	231	
All-Sky Solar Radiation	RadAvg	5.05	4.89	5.17	5.21	4.73	3.91	4.06	4.00	4.17	4.77	5.04	4.80	
	RadStd	0.23	0.20	0.22	0.22	0.19	0.28	0.24	0.26	0.20	0.18	0.14	0.12	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page