

SAN PEDRO, Côte d'Ivoire

WMO: 655940

Lat: 4.747N

Lon: 6.661W

Elev: 8

StdP: 101.23

Time Zone: 0.00 (E00)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.5	22.2	17.6	12.6	24.6	20.0	14.7	24.5	9.5	26.3	8.4	26.0	1.3	0	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.4	32.2	26.8	31.8	26.8	31.3	26.7	28.1	30.6	27.7	30.3	27.5	30.1	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	29.6	27.0	22.8	29.5	26.7	22.4	29.3	90.0	31.0	88.4	30.6	87.1	30.3	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.6	6.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	27.3	27.7	28.0	28.0	27.2	26.2	25.5	25.0	25.7	26.5	26.9	27.1
	DBStd	1.28	0.95	0.98	0.93	0.95	1.01	0.91	0.73	0.78	0.73	0.80	0.70	0.69
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6115	536	496	559	541	532	487	480	465	471	512	507	530
	CDD18.3	3073	277	262	301	291	274	237	222	207	221	254	257	272
	CDH23.3	28636	2814	2757	3312	3327	2837	2008	1482	1099	1439	2226	2564	2771
	CDH26.7	7772	922	948	1204	1224	841	318	126	66	154	406	701	862
(14) Wind	WSAvg	2.7	2.3	2.5	2.8	3.0	2.6	2.9	3.1	3.2	2.9	2.9	2.2	1.9
(15) Precipitation	PrecAvg	1318	21	34	57	107	265	331	103	66	66	126	133	56
	PrecMax	2070	58	127	199	326	708	545	442	194	221	382	275	172
	PrecMin	810	0	0	0	7	94	96	4	4	0	8	16	0
	PrecStd	313	17	37	49	74	171	125	115	45	60	92	71	42
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.4	32.8	32.7	31.7	30.2	29.0	28.6	29.2	30.2	31.2	32.0
		MCWB	25.3	26.6	27.0	27.4	26.7	26.4	24.8	24.5	25.3	25.9	26.6	26.0
	2%	DB	31.4	31.8	32.1	32.1	31.1	29.7	28.3	28.0	28.7	29.7	30.6	31.1
		MCWB	25.9	26.7	27.0	27.3	26.8	26.1	24.5	24.2	25.1	25.8	26.5	26.2
	5%	DB	31.0	31.3	31.7	31.6	30.6	29.0	28.0	27.4	28.1	29.2	30.1	30.6
		MCWB	26.0	26.7	27.0	27.2	26.7	25.7	24.4	24.0	25.0	25.6	26.3	26.2
	10%	DB	30.4	30.8	31.1	31.0	30.0	28.3	27.4	26.9	27.8	28.9	29.7	30.1
		MCWB	25.9	26.6	26.9	27.1	26.5	25.4	24.2	23.9	24.9	25.5	26.1	26.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.2	28.3	28.6	28.2	27.4	25.8	25.9	26.2	26.7	27.5	27.7
		MCDB	30.3	30.8	31.7	31.0	30.1	29.0	27.3	26.9	27.7	28.8	30.1	30.1
	2%	WB	27.2	27.7	27.9	28.1	27.6	26.6	25.3	25.2	25.7	26.2	27.0	27.1
		MCDB	30.0	30.3	30.9	30.6	29.7	28.5	27.0	26.5	27.5	28.5	29.7	30.0
	5%	WB	26.8	27.2	27.6	27.7	27.2	26.2	25.0	24.7	25.3	26.0	26.6	26.7
		MCDB	29.7	30.0	30.5	30.3	29.5	28.1	26.9	26.2	27.2	28.4	29.3	29.6
	10%	WB	26.5	27.0	27.2	27.4	26.8	25.8	24.7	24.3	25.0	25.7	26.2	26.5
		MCDB	29.3	29.8	30.0	30.1	29.2	27.8	26.6	26.0	27.0	28.0	29.0	29.3
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	7.0	6.9	6.4	5.6	4.4	4.1	4.1	4.3	5.0	6.0	6.7
		MCDBR	7.6	7.3	7.3	7.0	6.4	5.2	4.7	4.8	4.8	5.4	6.5	7.3
		MCWBR	3.4	3.1	3.2	3.1	2.9	2.4	2.0	2.2	2.1	2.4	3.1	3.3
	5% WB	MCDBR	6.9	6.7	6.8	6.7	5.9	4.9	4.2	4.3	4.5	5.1	6.4	6.8
		MCWBR	3.3	3.1	3.3	3.3	3.1	2.7	2.0	2.4	2.3	2.5	3.3	3.3
(40) Clear-Sky Solar Irradiance	taub		0.755	0.716	0.717	0.557	0.496	0.506	0.510	0.498	0.470	0.464	0.516	0.644
	taud		1.604	1.694	1.693	2.059	2.234	2.190	2.159	2.201	2.313	2.348	2.157	1.814
	Ebn at Noon		626	669	671	774	803	783	784	810	847	857	806	696
	Edh at Noon		270	252	253	172	140	144	150	147	134	129	154	216
(44) All-Sky Solar Radiation	RadAvg		4.95	4.86	5.22	5.18	4.51	3.92	4.26	4.30	4.58	4.97	4.93	4.74
	RadStd		0.26	0.23	0.27	0.26	0.25	0.30	0.33	0.30	0.20	0.20	0.18	0.16

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page