

SASSANDRA, Côte d'Ivoire

WMO: 655990

Lat: 4.950N

Lon: 6.083W

Elev: 66

StdP: 100.53

Time Zone: 0.00 (E00)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.6	22.0	16.0	11.5	25.3	19.8	14.6	24.8	6.0	26.9	5.3	25.8	0.8	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.6	32.2	27.0	31.8	27.0	31.2	26.8	27.8	31.2	27.5	30.8	27.2	30.4	0.5	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.7	30.0	26.6	22.3	29.7	26.2	21.9	29.3	89.4	31.4	87.8	31.2	86.7	30.8	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 4.5	3.8	3.1	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	16.9	28.9	2.5	0.5	15.0	29.2	13.5	29.5	12.1	29.7	10.3	30.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.7	27.3	27.6	27.8	27.9	27.1	26.1	25.4	24.9	25.4	26.4	26.9	27.1
	DBStd	1.32	1.04	1.10	1.00	1.02	1.00	0.97	0.73	0.72	0.80	0.82	0.76	0.80
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6078	537	492	551	536	531	483	478	461	462	509	508	530
	CDD18.3	3037	278	258	293	286	273	233	219	203	212	251	258	272
	CDH23.3	26666	2738	2563	3044	3116	2702	1836	1307	946	1173	2048	2538	2654
(14) Wind	WSAvg	0.8	0.8	0.2	0.3	0.4	0.9	0.9	1.2	1.5	1.0	1.1	0.7	0.8
	PrecAvg	1482	24	32	51	104	235	482	164	38	43	111	126	69
	PrecMax	2236	114	138	121	282	606	1234	750	169	186	290	306	209
	PrecMin	782	0	0	0	3	28	90	4	4	0	2	12	0
	PrecStd	348	27	32	29	63	125	266	172	34	39	83	68	51
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.2	32.7	32.9	31.9	30.6	29.1	28.7	29.2	30.2	31.5	31.9
		MCWB	25.9	27.0	27.2	27.7	27.1	26.5	25.2	24.8	25.3	26.3	26.9	26.7
	2%	DB	31.5	31.8	32.0	32.2	31.2	29.6	28.4	28.0	28.6	29.8	31.0	31.1
		MCWB	26.4	27.0	27.0	27.4	27.0	26.0	24.9	24.4	25.0	26.0	26.8	26.6
	5%	DB	31.0	31.2	31.4	31.7	30.8	29.0	28.0	27.4	28.0	29.2	30.2	30.7
		MCWB	26.3	26.7	26.9	27.2	26.9	25.6	24.7	24.2	24.8	25.7	26.3	26.5
	10%	DB	30.5	30.7	30.8	31.0	30.1	28.3	27.3	26.9	27.4	28.8	29.8	30.1
		MCWB	26.1	26.5	26.7	26.9	26.6	25.4	24.4	24.0	24.6	25.5	26.2	26.3
	0.4%	WB	27.7	28.1	28.2	28.2	28.0	27.1	26.1	25.4	26.0	26.8	27.4	27.7
		MCDB	31.0	31.7	31.4	31.8	31.0	29.8	28.4	27.6	28.4	29.6	30.4	30.9
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	27.2	27.6	27.6	27.8	27.3	26.4	25.5	24.9	25.4	26.2	27.0	27.2
		MCDB	30.5	30.9	30.8	31.4	30.3	29.0	27.7	27.1	27.8	29.0	30.4	30.5
	5%	WB	26.9	27.2	27.2	27.5	27.0	26.0	25.1	24.6	25.1	26.0	26.6	26.8
		MCDB	30.1	30.3	30.3	30.9	30.1	28.4	27.4	26.7	27.5	28.8	29.8	30.0
	10%	WB	26.6	26.8	26.9	27.2	26.7	25.6	24.7	24.2	24.8	25.7	26.2	26.5
		MCDB	29.5	29.7	29.9	30.3	29.5	27.8	26.8	26.3	27.0	28.2	29.2	29.4
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	6.7	6.7	6.6	5.9	4.6	4.4	4.5	4.6	5.2	6.1	6.6
		MCDBR	7.5	7.2	7.2	7.2	6.8	5.5	5.0	5.1	5.1	5.7	6.7	7.1
		MCWBR	3.5	3.1	3.1	3.2	3.2	2.8	2.4	2.5	2.3	2.7	3.4	3.5
	5% WB	MCDBR	6.9	6.9	6.8	6.9	6.4	5.3	4.6	4.8	4.9	5.4	6.6	6.6
		MCWBR	3.3	3.2	3.1	3.2	3.3	2.8	2.4	2.6	2.4	2.7	3.4	3.4
(40) Clear-Sky Solar Irradiance	taub		0.754	0.718	0.722	0.561	0.497	0.503	0.507	0.493	0.467	0.465	0.520	0.647
	taud		1.599	1.684	1.680	2.042	2.224	2.195	2.169	2.217	2.318	2.339	2.137	1.804
	Ebn at Noon		626	667	668	771	802	785	787	814	850	855	802	693
	Edh at Noon		271	254	256	175	142	143	149	145	133	130	157	218
(44) All-Sky Solar Radiation	RadAvg		4.95	4.85	5.21	5.20	4.57	3.94	4.26	4.26	4.54	4.91	4.94	4.72
	RadStd		0.24	0.22	0.24	0.25	0.23	0.29	0.30	0.29	0.18	0.19	0.18	0.15

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page