

PAMANDZI, Mayotte

WMO: 670050

Lat: 12.805S

Lon: 45.281E

Elev: 7

StdP: 101.24

Time Zone: 3.00 (E03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.7	21.3	17.1	12.2	24.9	17.8	12.8	25.0	10.5	25.6	9.7	25.9	1.2	240	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	5.4	32.1	26.3	31.7	26.3	31.2	26.1	27.2	30.6	27.0	30.4	26.7	30.1	4.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	29.3	26.1	21.5	29.2	25.8	21.1	29.1	86.4	31.1	85.1	30.3	83.8	30.4	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.7	8.7	7.9	19.2	33.0	0.7	0.7	18.7	33.5	18.3	33.9	17.9	34.2	17.3	34.7
			17.2	28.0	1.5	0.6	16.1	28.5	15.2	28.8	14.4	29.1	13.3	29.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	28.2	28.2	28.4	28.3	27.5	26.2	25.2	24.9	25.5	26.8	27.7	28.2
	DBStd	1.55	0.97	0.90	0.88	0.81	0.93	0.94	0.87	0.85	0.86	0.92	0.90	0.82
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6234	563	509	569	549	543	487	472	461	466	520	531	565
	CDD18.3	3193	305	276	311	299	285	237	213	202	216	262	281	307
	CDH23.3	32534	3487	3184	3641	3498	3058	2116	1538	1414	1671	2450	2973	3506
	CDH26.7	9428	1189	1099	1326	1263	864	367	152	168	304	621	879	1197
Wind	WSAvg	3.8	4.0	3.5	3.1	3.4	4.4	5.0	5.2	4.1	3.3	3.2	3.4	3.1
Precipitation	PrecAvg	1256	292	232	226	98	36	21	12	15	22	42	84	176
	PrecMax	1766	484	439	372	250	105	76	33	56	54	111	187	435
	PrecMin	866	113	84	104	22	1	1	2	2	4	7	17	59
	PrecStd	218	101	84	72	53	28	18	8	13	14	29	50	91
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.2	32.4	32.2	31.2	30.2	29.1	29.2	30.1	31.2	32.0	32.2
		MCWB	26.1	26.3	26.6	26.8	25.8	24.5	23.3	23.6	24.1	25.1	26.1	25.9
	2%	DB	31.4	31.7	32.0	31.7	30.8	29.5	28.3	28.5	29.2	30.3	31.1	31.8
		MCWB	26.2	26.4	26.6	26.5	25.5	24.0	22.8	23.1	23.7	24.7	25.6	25.8
	5%	DB	31.1	31.1	31.2	31.1	30.2	29.0	28.0	28.1	28.9	30.0	30.8	31.1
		MCWB	26.2	26.3	26.5	26.2	25.1	23.8	22.7	22.7	23.6	24.5	25.4	25.8
	10%	DB	30.7	30.8	31.0	30.9	29.9	28.5	27.5	27.7	28.2	29.2	30.1	30.8
		MCWB	26.1	26.3	26.4	26.1	25.0	23.4	22.5	22.6	23.1	24.1	25.1	25.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.4	27.7	27.8	26.7	25.5	24.5	24.5	25.2	26.3	27.2	27.1
		MCDB	30.5	30.6	30.9	31.0	30.3	29.1	27.9	28.1	28.9	29.7	30.8	30.8
	2%	WB	26.9	27.0	27.2	27.1	26.2	24.7	23.7	23.8	24.5	25.6	26.5	26.6
		MCDB	30.4	30.4	30.6	30.4	29.7	28.3	27.2	27.4	28.2	29.1	30.0	30.3
	5%	WB	26.6	26.7	26.9	26.7	25.8	24.3	23.3	23.4	24.0	25.1	26.0	26.3
		MCDB	30.0	30.0	30.3	30.0	29.2	27.9	26.8	27.0	27.6	28.7	29.4	29.9
	10%	WB	26.2	26.4	26.6	26.4	25.4	23.9	22.9	22.9	23.6	24.6	25.5	26.0
		MCDB	29.5	29.6	29.9	29.7	28.8	27.6	26.4	26.5	27.2	28.2	28.9	29.6
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.2	5.4	5.2	4.8	4.9	5.1	6.0	6.2	5.9	5.3	5.3
		MCDBR	5.4	5.6	5.7	5.6	5.1	5.3	5.5	6.4	6.4	6.1	5.6	5.7
		MCWBR	2.3	2.4	2.4	2.4	2.4	2.5	2.6	3.0	2.7	2.5	2.3	2.3
	5% WB	MCDBR	5.1	5.3	5.4	5.3	5.0	5.2	5.3	6.1	6.0	5.7	5.3	5.4
MCWBR		2.4	2.5	2.5	2.5	2.5	2.6	2.7	3.0	2.8	2.6	2.4	2.4	
Clear-Sky Solar Irradiance	taub	0.427	0.421	0.393	0.375	0.365	0.351	0.348	0.356	0.385	0.414	0.436	0.409	0.409
	taud	2.493	2.513	2.610	2.653	2.648	2.661	2.654	2.618	2.512	2.451	2.413	2.532	2.532
	Ebn at Noon	918	917	925	911	889	887	897	916	918	913	903	933	933
	Edh at Noon	116	113	100	91	87	83	85	93	109	119	125	111	111
All-Sky Solar Radiation	RadAvg	5.50	5.66	5.70	5.64	5.28	4.99	5.17	5.78	6.29	6.64	6.56	6.16	6.16
	RadStd	0.45	0.43	0.34	0.27	0.19	0.14	0.10	0.09	0.16	0.19	0.26	0.31	0.31

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page