

NAMPULA, Mozambique

WMO: 672370

Lat: 15.106S

Lon: 39.282E

Elev: 440

StdP: 96.15

Time Zone: 2.00 (E02)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	16.1	9.4	7.7	28.8	10.8	8.5	27.3	7.9	21.4	7.3	21.9	3.1	240	0.312

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	11.9	35.2	22.2	34.4	22.2	33.6	22.2	25.2	30.4	25.0	30.2	24.7	29.6	3.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	20.1	26.6	23.8	19.7	26.3	23.3	19.0	25.9	80.0	30.3	78.7	30.2	77.3	30.1	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.9	6.2	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	26.9	26.5	26.2	24.7	23.6	21.8	21.5	22.6	24.4	26.3	27.6	27.8
	DBStd	2.52	1.08	1.11	1.14	1.35	1.22	1.44	1.43	1.41	1.49	1.52	1.47	1.41
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	0	0	0	0	0	1	1	0	0	0	0	0
	CDD10.0	5466	523	461	502	441	422	353	356	392	433	504	528	551
	CDD18.3	2426	265	228	243	191	164	103	98	134	183	246	278	293
	CDH23.3	19109	2136	1737	1747	1138	932	411	442	859	1607	2421	2881	2798
	CDH26.7	7406	812	631	568	283	179	41	61	211	664	1191	1466	1299
Wind	WSAvg	3.1	2.4	2.6	2.6	2.9	2.8	3.2	3.2	3.2	3.6	3.8	3.7	3.2
Precipitation	PrecAvg	1047	258	213	184	83	22	14	20	8	7	25	71	174
	PrecMax	1594	546	407	422	242	121	73	65	54	77	100	307	421
	PrecMin	738	21	66	25	8	0	0	4	0	0	0	4	14
	PrecStd	272	141	89	97	57	24	16	15	12	13	30	65	105
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	33.2	32.5	32.0	31.1	29.4	29.9	31.6	34.0	36.0	36.9	36.2
		MCWB	24.3	24.5	24.2	22.6	21.0	19.5	19.0	19.3	20.2	21.8	21.6	23.5
	2%	DB	32.9	32.2	31.4	30.3	29.7	28.0	28.3	30.1	32.8	34.5	35.5	35.2
		MCWB	24.1	24.3	24.1	22.9	21.2	19.5	18.8	18.9	19.7	21.2	21.6	23.1
	5%	DB	31.9	31.2	30.8	29.4	28.6	26.9	27.1	29.0	31.7	33.5	34.7	34.1
		MCWB	24.1	23.9	24.0	22.8	21.0	19.3	18.8	18.7	19.7	21.0	21.8	23.3
	10%	DB	30.9	30.2	29.9	28.3	27.8	25.9	26.0	27.9	30.5	32.4	33.6	33.0
		MCWB	24.0	23.6	23.9	22.5	20.8	18.9	18.4	18.6	19.6	20.9	21.8	23.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.9	25.7	25.4	24.8	23.2	21.8	22.0	21.7	22.2	24.0	24.6	26.1
		MCDB	30.4	31.0	29.9	28.8	27.5	25.5	25.9	27.1	29.1	32.1	32.3	32.0
	2%	WB	25.2	25.1	25.1	24.1	22.6	21.0	20.2	20.7	21.4	22.9	23.7	25.1
		MCDB	30.2	30.2	29.6	28.0	26.6	24.9	24.7	26.0	28.7	30.8	30.3	31.5
	5%	WB	24.9	24.8	24.7	23.8	22.1	20.2	19.8	20.1	21.0	22.2	23.2	24.6
		MCDB	30.0	29.5	29.0	27.4	26.0	24.0	24.2	25.3	28.2	29.6	29.5	30.7
	10%	WB	24.3	24.2	24.2	23.2	21.7	19.9	19.2	19.6	20.3	21.8	22.9	24.1
		MCDB	29.1	28.5	28.2	26.4	25.5	23.6	23.5	24.7	27.0	29.0	29.1	29.7
Mean Daily Temperature Range	5% DB	MDBR	8.7	8.6	8.0	8.1	8.9	8.9	9.2	10.6	12.2	12.5	11.9	10.2
		MCDBR	10.0	9.7	8.9	9.0	9.8	9.8	10.7	12.4	14.0	14.0	13.6	12.0
		MCWBR	3.2	3.1	2.8	3.0	3.1	3.1	3.5	3.4	3.5	3.3	3.0	2.9
	5% WB	MCDBR	8.9	9.2	8.0	7.7	8.7	8.6	9.5	10.8	12.6	12.8	11.5	10.3
		MCWBR	3.6	3.3	3.1	3.0	3.3	3.4	4.0	3.6	3.8	3.7	3.2	3.4
Clear-Sky Solar Irradiance	taub	0.403	0.393	0.377	0.354	0.336	0.324	0.329	0.355	0.408	0.441	0.426	0.410	
	taud	2.456	2.489	2.538	2.583	2.590	2.607	2.572	2.453	2.296	2.235	2.310	2.419	
	Ebn at Noon	941	942	937	926	910	905	909	911	894	888	913	934	
	Edh at Noon	121	116	107	97	90	85	90	108	134	148	139	125	
All-Sky Solar Radiation	RadAvg	5.83	5.88	5.70	5.30	4.85	4.37	4.41	5.14	6.00	6.43	6.50	6.35	
	RadStd	0.43	0.42	0.29	0.22	0.12	0.14	0.18	0.23	0.18	0.26	0.32	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page