

MAPUTO, Mozambique

WMO: 673410

Lat: 25.921S

Lon: 32.573E

Elev: 44

StdP: 100.80

Time Zone: 2.00 (E02)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	13.0	3.1	4.8	21.8	5.9	5.8	21.4	14.4	20.5	12.6	20.8	1.9	210	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.1	36.0	24.0	34.1	23.8	32.8	23.7	26.6	31.7	26.1	30.9	25.6	30.1	5.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	28.6	24.9	20.0	28.4	24.2	19.2	27.9	83.4	32.1	81.0	30.9	78.8	30.1	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.7	10.1	8.5	DB	8.8	41.0	1.0	1.8	8.1	42.2	7.6	43.3	7.0	44.3	6.3	45.5
			WB	7.9	28.0	1.4	0.6	6.8	28.4	6.0	28.8	5.2	29.1	4.2	29.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.9	27.1	27.2	26.6	24.4	22.5	20.6	19.7	21.4	22.5	23.7	24.8	26.4
	DBStd	3.32	1.90	1.65	1.88	2.05	1.92	1.71	1.89	2.36	2.73	2.70	2.64	2.46
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	13	0	0	0	0	0	2	8	2	2	0	0	0
	CDD10.0	5077	531	482	515	433	388	318	302	352	376	426	446	509
	CDD18.3	2049	273	249	257	183	129	69	51	97	127	168	196	251
	CDH23.3	16224	2661	2449	2326	1260	769	424	346	605	757	1040	1397	2191
(13)	CDH26.7	5398	951	869	812	365	202	97	84	204	270	343	439	762
(14)	Wind	WSAvg	4.3	4.6	4.5	4.2	3.9	3.4	3.5	3.9	4.5	4.8	4.7	4.9
(15) Precipitation	PrecAvg	791	170	137	93	53	29	14	18	13	36	59	77	83
	PrecMax	1254	800	500	277	198	153	60	160	40	320	223	191	210
	PrecMin	365	5	5	4	4	0	0	0	0	0	3	16	8
	PrecStd	245	144	112	66	42	33	16	32	13	57	47	45	56
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.0	35.8	36.1	34.8	33.3	32.0	31.9	34.1	36.7	38.0	36.8	38.4
		MCWB	26.0	25.6	25.4	23.5	20.7	17.4	17.6	18.6	19.8	22.7	22.9	25.7
	2%	DB	33.9	33.2	33.2	32.0	30.8	29.2	29.1	31.1	32.7	33.2	33.2	34.4
		MCWB	25.6	25.3	24.8	23.1	20.6	18.0	17.4	19.2	20.3	22.4	23.8	25.4
	5%	DB	32.2	32.0	31.9	30.1	28.9	27.2	27.0	28.8	29.7	29.9	30.9	32.1
		MCWB	24.7	24.6	24.5	22.6	20.6	18.3	17.6	19.2	20.4	22.3	23.5	24.9
	10%	DB	31.0	31.0	30.6	28.8	27.1	25.8	25.1	26.4	27.1	27.9	29.0	30.4
		MCWB	24.3	24.3	23.9	22.4	20.4	18.3	17.8	18.9	20.4	21.4	22.8	24.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.2	26.7	25.5	24.1	21.6	20.9	22.4	23.2	25.1	25.9	27.1
		MCDB	33.0	31.4	31.4	30.3	28.1	25.5	24.4	27.8	29.0	30.5	32.0	33.7
	2%	WB	26.4	26.4	26.0	24.5	22.9	20.6	19.8	21.3	22.3	23.8	25.0	26.2
		MCDB	31.4	30.6	30.5	29.1	27.0	24.8	23.9	25.8	27.4	28.5	29.5	32.1
	5%	WB	25.8	25.9	25.4	23.8	22.1	19.9	19.2	20.6	21.7	23.1	24.3	25.5
		MCDB	30.3	30.0	29.6	28.1	26.2	24.2	23.6	25.0	26.3	27.7	28.3	30.6
	10%	WB	25.3	25.2	24.8	23.2	21.4	19.3	18.6	19.9	21.0	22.4	23.7	24.9
		MCDB	29.3	29.3	28.8	27.2	25.4	23.7	23.1	24.2	25.3	26.6	27.5	29.2
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	8.1	8.4	9.1	10.7	11.6	11.7	11.2	10.1	8.9	8.2	8.2
		MCDBR	10.0	9.4	10.4	11.2	13.0	14.4	15.2	15.2	15.1	13.2	11.7	11.2
		MCWBR	3.9	3.6	3.9	4.6	5.6	6.7	6.7	6.0	5.7	4.9	4.7	4.5
	5% WB	MCDBR	8.9	8.5	9.0	9.7	10.8	11.8	11.9	11.7	11.4	11.0	9.7	9.9
		MCWBR	4.0	3.8	3.7	4.5	5.2	6.5	6.5	5.8	5.3	4.8	4.1	4.3
(40) Clear-Sky Solar Irradiance	taub		0.440	0.424	0.425	0.413	0.383	0.372	0.372	0.437	0.493	0.504	0.473	0.459
	taud		2.348	2.399	2.388	2.374	2.425	2.432	2.428	2.228	2.098	2.108	2.228	2.275
	Ebn at Noon		907	906	875	836	819	806	822	799	799	824	872	891
	Edh at Noon		134	125	120	112	97	92	95	127	158	165	151	145
(44) All-Sky Solar Radiation	RadAvg		6.14	6.10	5.32	4.45	3.97	3.53	3.70	4.32	4.88	5.13	5.65	6.12
	RadStd		0.44	0.45	0.32	0.26	0.16	0.20	0.15	0.29	0.28	0.33	0.40	0.50

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page