

WALVIS BAY PELICAN POINT, Namibia

WMO: 681040

Lat: 22.892S

Lon: 14.435E

Elev: 0

StdP: 14.70

Time Zone: 2.00 (E02)

Period: 90-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	42.8	44.9	15.4	12.0	71.5	21.4	16.1	71.5	40.5	68.0	32.7	68.0	5.2	90	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.4	92.8	63.1	88.0	62.3	84.0	62.8	70.5	81.7	68.6	78.6	67.3	76.0	13.9	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	99.6	74.7	65.4	93.9	72.4	64.1	89.7	70.7	34.4	81.5	32.8	79.0	31.7	76.0	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.4	24.6	21.0	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.9	67.9	68.2	67.7	67.6	63.4	63.1	61.9	58.7	59.3	61.0	63.2	64.8
	DBStd	6.46	3.12	3.36	4.50	6.89	7.49	8.63	8.28	6.45	3.66	2.86	3.20	3.68
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1171	8	8	18	39	123	146	174	228	178	129	71	49
	CDD50	5059	555	508	549	529	417	393	368	269	278	341	395	457
	CDD65	756	98	96	102	117	75	90	77	32	7	5	16	41
	CDH74	5039	188	247	503	1065	750	814	767	371	88	35	113	98
	CDH80	1921	19	31	144	474	330	345	326	173	31	6	32	10
Wind	WSAvg	8.3	8.6	8.5	7.9	7.4	7.6	8.7	8.8	8.1	8.2	8.0	8.8	9.3
Precipitation	PrecAvg	2.4	0.4	0.4	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2
	PrecMax	6.7	3.0	2.9	2.4	1.3	0.2	0.1	0.3	0.1	0.4	0.5	1.1	1.6
	PrecMin	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.9	0.7	0.6	0.6	0.3	0.0	0.0	0.1	0.0	0.1	0.1	0.3	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.5	85.1	89.2	97.0	96.5	93.6	93.0	93.0	84.1	77.3	82.7	82.3
		MCWB	67.3	68.2	68.9	67.8	63.6	60.9	60.3	59.8	58.7	62.0	65.6	66.8
	2%	DB	78.1	80.3	82.6	91.3	89.2	89.2	88.2	83.6	73.4	73.3	76.2	76.9
		MCWB	66.7	67.2	67.9	67.7	62.8	59.2	59.4	59.2	59.2	59.4	61.3	64.9
	5%	DB	75.4	77.0	78.5	85.0	82.1	83.8	82.7	74.3	69.6	70.1	73.3	74.1
		MCWB	65.5	66.3	66.7	66.3	61.7	57.7	57.6	55.6	58.8	59.3	60.5	63.8
	10%	DB	73.4	74.7	74.9	79.7	75.6	77.8	76.8	68.0	66.4	67.8	70.3	71.7
		MCWB	64.9	65.2	65.5	64.3	59.5	57.9	56.7	56.1	57.8	58.8	60.1	62.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.2	71.0	73.5	72.7	69.4	68.5	66.0	65.7	63.8	64.9	65.6	68.2
		MCDB	77.9	79.9	84.8	85.8	83.6	80.4	78.3	81.3	70.2	70.6	74.9	76.9
	2%	WB	68.4	68.6	69.9	69.7	65.2	63.3	62.5	61.1	61.2	62.3	63.0	66.2
		MCDB	74.3	76.5	79.4	86.5	79.5	77.3	79.1	72.3	69.3	68.5	71.7	74.6
	5%	WB	67.2	67.3	67.5	67.4	63.1	61.1	60.1	58.9	59.6	60.5	61.7	64.8
		MCDB	73.1	74.4	76.0	81.9	76.8	75.8	76.7	69.0	66.8	67.3	70.2	72.2
	10%	WB	65.8	66.2	65.7	65.1	61.2	59.4	58.2	57.3	58.5	59.3	60.6	63.4
		MCDB	71.9	72.7	73.4	77.3	72.8	72.5	71.8	65.3	64.9	66.2	69.0	70.0
Mean Daily Temperature Range	5% DB	MDBR	12.5	13.4	15.7	20.1	20.0	21.9	21.1	19.4	16.8	16.5	16.1	12.3
		MCDBR	15.2	17.3	21.1	29.0	30.3	29.3	29.0	31.5	24.0	20.4	21.6	17.5
		MCWBR	6.7	7.3	9.0	10.8	12.2	13.3	13.2	14.7	12.0	9.7	9.5	7.7
	5% WB	MCDBR	13.0	14.2	19.1	24.1	24.1	24.5	24.0	23.7	18.6	17.0	18.7	15.9
		MCWBR	6.9	7.1	9.2	10.4	11.2	13.5	12.9	13.3	10.1	9.3	9.0	7.7
Clear-Sky Solar Irradiance	taub	0.439	0.447	0.422	0.379	0.350	0.340	0.362	0.405	0.467	0.461	0.405	0.410	
	taud	2.288	2.284	2.338	2.423	2.442	2.427	2.368	2.242	2.035	2.105	2.315	2.316	
	Ebn at Noon	288	282	280	279	275	271	267	266	262	274	296	297	
	Edh at Noon	45	45	41	34	31	30	33	41	54	53	44	44	
All-Sky Solar Radiation	RadAvg	2331	2195	1969	1676	1398	1280	1334	1503	1752	2067	2371	2425	
	RadStd	100	93	77	80	60	48	49	75	83	68	119	89	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page