

HOSEA KUTAKO INTL, Namibia

WMO: 681120

Lat: 22.480S

Lon: 17.471E

Elev: 5640

StdP: 11.94

Time Zone: 2.00 (E02)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.8	32.6	-2.5	5.9	56.1	1.6	7.4	57.8	21.3	67.9	19.0	67.8	5.1	250	0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	25.9	92.9	57.9	91.2	57.6	89.6	57.3	66.2	76.5	65.3	75.9	64.4	75.4	8.0	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.4	108.2	69.5	62.4	104.4	68.9	61.2	99.8	68.1	34.4	76.6	33.6	76.3	32.8	75.4	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	16.7	14.5		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	74.7	73.1	70.0	66.4	59.5	54.4	53.2	58.7	65.5	71.1	72.7	74.6	(6)	
	DBStd	8.83	4.06	4.38	4.11	3.72	4.76	4.21	5.00	4.93	5.65	5.16	4.83	3.97	(7)	
	HDD50	52	0	0	0	0	3	14	28	6	1	0	0	0	(8)	
	HDD65	1177	2	2	6	27	177	318	366	198	60	13	7	1	(9)	
	CDD50	5933	764	648	621	491	298	146	127	277	465	653	680	763	(10)	
	CDD65	1584	301	230	163	67	8	0	0	4	74	201	237	299	(11)	
	CDH74	18831	2874	2138	1568	844	335	62	67	446	1575	2702	2910	3310	(12)	
	CDH80	7075	1187	838	448	150	30	1	0	61	527	1139	1240	1454	(13)	
(14) Wind	WSAvg	6.2	6.4	6.0	5.1	4.9	5.5	5.6	6.0	6.4	6.7	7.3	7.2	6.8	(14)	
(15) Precipitation	PrecAvg	15.3	3.2	4.0	3.7	1.3	0.3	0.1	0.0	0.0	0.1	0.5	0.9	1.1	(15)	
	PrecMax	24.7	8.3	11.4	12.4	4.0	1.5	0.5	0.1	0.1	0.7	2.9	2.8	4.2	(16)	
	PrecMin	8.1	0.3	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	4.4	2.4	3.1	3.2	1.1	0.4	0.2	0.0	0.0	0.2	0.8	0.9	1.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.5	93.6	90.0	86.1	84.0	79.0	78.1	84.3	89.8	94.0	93.6	95.0	(19)	
		MCWB	59.5	59.8	59.0	58.0	54.3	49.0	49.1	52.6	54.2	56.7	56.6	57.9	(20)	
	2%	DB	91.5	90.4	87.3	83.9	80.3	75.4	75.9	82.0	87.7	91.5	91.3	92.3	(21)	
		MCWB	58.8	59.3	58.4	57.4	53.5	49.2	48.5	51.2	54.0	55.4	56.7	57.9	(22)	
	5%	DB	89.5	87.9	85.2	81.3	77.9	73.5	73.6	79.1	85.9	89.3	89.4	90.0	(23)	
		MCWB	59.1	59.1	58.5	56.7	52.5	49.1	48.0	49.9	53.2	54.9	56.6	57.8	(24)	
	10%	DB	87.2	85.7	82.7	78.9	75.6	71.4	71.2	76.3	83.8	86.4	87.4	87.9	(25)	
		MCWB	59.2	59.6	59.2	56.8	52.3	48.6	47.4	49.0	52.6	54.5	56.2	57.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.4	67.4	66.3	64.2	58.4	54.0	52.8	54.9	58.3	61.7	64.4	65.2	(27)	
		MCDB	77.7	77.9	77.5	73.5	72.1	70.3	72.6	78.7	81.9	79.3	76.7	77.1	(28)	
	2%	WB	66.3	66.2	64.7	62.7	56.2	52.0	50.7	53.0	56.5	60.0	62.9	63.8	(29)	
		MCDB	76.5	76.6	75.7	72.3	72.4	69.2	71.7	77.2	79.5	77.5	75.5	77.0	(30)	
	5%	WB	65.3	65.3	63.6	61.5	54.8	50.7	49.2	51.3	55.1	58.5	61.7	62.9	(31)	
		MCDB	75.9	75.8	74.5	71.7	73.0	69.1	70.5	75.5	79.4	77.8	75.0	76.6	(32)	
	10%	WB	64.4	64.4	62.5	60.1	53.4	49.3	47.8	50.0	53.7	57.3	60.5	61.9	(33)	
		MCDB	75.3	75.0	73.4	71.0	72.4	68.8	69.1	74.0	79.4	77.8	74.9	76.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.0	23.8	24.5	25.3	31.2	33.8	33.9	34.2	34.0	30.5	28.7	25.9	(35)	
		MCDBR	28.0	28.5	27.9	29.5	33.4	37.0	36.7	37.9	36.2	34.0	31.9	30.0	(36)	
	5% WB	MCWBR	9.7	10.1	10.5	11.9	14.2	17.6	17.8	18.1	16.1	13.9	12.6	10.5	(37)	
		MCWBR	19.9	20.1	20.8	20.5	28.4	31.9	32.9	32.4	30.2	26.4	22.9	22.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.334	0.334	0.327	0.299	0.266	0.246	0.254	0.299	0.367	0.375	0.322	0.321	(40)	
		taud	2.509	2.530	2.526	2.569	2.604	2.601	2.547	2.387	2.201	2.235	2.468	2.514	(41)	
	Ebn at Noon	Ebn at Noon	320	316	310	306	305	307	307	301	292	299	322	325	(42)	
		Edh at Noon	36	35	34	30	26	25	27	35	46	46	38	36	(43)	
(44) All-Sky Solar Radiation	RadAvg	2311	2152	1948	1756	1613	1490	1560	1806	2097	2272	2427	2468		(44)	
	RadStd	155	175	118	120	36	35	24	52	65	99	131	137		(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page