

POLOKWANE, South Africa

WMO: 681740

Lat: 23.8575S

Lon: 29.4517E

Elev: 1226

StdP: 87.44

Time Zone: 2.00 (E02)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.9	4.0	-11.2	1.7	19.2	-8.1	2.2	16.3	9.2	15.1	8.1	15.6	1.8	190	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.4	32.8	16.7	31.4	16.7	30.2	16.8	20.7	26.2	20.2	25.5	19.7	24.9	3.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	16.3	22.2	18.9	15.9	22.0	18.2	15.2	21.8	66.2	26.3	64.2	25.3	62.3	25.1	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.3	6.4	DB	0.9	35.3	1.3	1.2	0.0	36.1	-0.8	36.9	-1.5	37.5	-2.4	38.4	(4)
(5)			WB	-1.4	21.6	1.1	0.7	-2.2	22.1	-2.8	22.5	-3.4	22.8	-4.2	23.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	22.2	22.2	21.1	18.6	15.6	13.1	12.6	15.0	18.3	20.0	20.9	21.8	(6)
(7)		DBStd	4.21	2.01	1.84	2.11	2.37	2.26	2.07	2.13	2.75	3.08	3.24	3.05	2.47	(7)
(8)		HDD10.0	7	0	0	0	0	1	2	3	1	0	0	0	0	(8)
(9)		HDD18.3	634	2	1	4	26	88	157	178	107	38	19	12	3	(9)
(10)		CDD10.0	3086	378	342	343	257	174	95	84	157	250	311	327	367	(10)
(11)		CDD18.3	671	122	109	88	32	3	0	0	5	38	72	88	112	(11)
(12)		CDH23.3	5918	797	727	598	310	127	31	29	202	641	833	799	824	(12)
(13)		CDH26.7	1792	219	213	159	63	12	1	2	33	224	322	284	260	(13)
(14)	Wind	WSAvg	2.8	2.8	2.8	2.6	2.3	2.2	2.4	2.5	2.7	3.1	3.5	3.4	3.0	(14)
(15)	Precipitation	PrecAvg	482	81	63	54	32	11	4	2	11	41	86	91		(15)
(16)		PrecMax	949	267	331	174	144	65	70	44	75	87	127	215	199	(16)
(17)		PrecMin	254	12	2	1	0	0	0	0	0	0	0	0	6	(17)
(18)		PrecStd	123	52	54	40	31	15	11	7	11	18	29	40	44	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	33.2	32.1	30.2	28.2	26.0	25.9	29.2	33.1	34.2	33.8	33.1	(19)
(20)			MCWB	18.1	17.8	17.5	15.9	13.7	12.0	10.7	13.1	14.7	15.5	16.8	18.4	(20)
(21)		2%	DB	30.8	31.0	30.0	28.5	26.1	24.0	23.9	27.5	31.0	32.1	31.9	31.1	(21)
(22)			MCWB	18.5	18.1	17.7	15.7	13.0	11.3	10.6	12.3	13.9	15.5	16.6	18.0	(22)
(23)		5%	DB	29.1	29.1	28.3	26.9	24.8	22.6	22.2	25.8	29.2	30.2	30.1	29.7	(23)
(24)			MCWB	18.4	18.2	17.7	15.8	13.0	10.8	10.3	12.0	13.8	15.5	16.8	18.3	(24)
(25)		10%	DB	27.6	27.7	26.8	25.1	23.1	20.9	20.7	23.9	27.3	28.1	28.1	27.9	(25)
(26)			MCWB	18.6	18.4	17.6	15.8	12.7	10.7	10.1	11.7	13.5	15.7	17.0	18.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	21.2	21.0	19.0	16.4	14.2	13.9	15.6	17.3	19.1	20.3	21.2	(27)
(28)			MCDWB	27.3	26.4	25.7	24.5	23.1	21.0	20.6	24.3	26.7	27.5	26.6	27.7	(28)
(29)		2%	WB	20.7	20.5	19.9	18.0	15.4	13.0	12.6	14.5	16.2	18.2	19.5	20.5	(29)
(30)			MCDWB	26.0	25.6	24.5	23.6	21.8	19.5	19.6	22.8	25.6	26.2	25.9	26.5	(30)
(31)		5%	WB	20.1	19.9	19.2	17.4	14.6	12.2	11.6	13.5	15.5	17.4	18.9	19.8	(31)
(32)			MCDWB	25.1	24.8	24.4	23.0	20.9	18.9	18.7	21.7	24.7	25.4	25.3	25.5	(32)
(33)		10%	WB	19.6	19.4	18.7	16.7	13.8	11.5	10.8	12.6	14.7	16.7	18.2	19.3	(33)
(34)			MCDWB	24.5	24.3	24.0	22.3	20.2	18.4	18.1	20.6	23.7	24.7	24.3	25.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.4	10.7	10.9	12.0	14.4	15.0	15.2	15.6	15.0	13.1	11.4	10.5	(35)
(36)			MCDBR	13.2	14.0	14.0	15.4	16.8	18.0	18.2	18.8	18.6	17.0	15.3	13.7	(36)
(37)			MCWBR	4.0	4.3	4.5	5.4	6.6	7.7	7.9	7.3	6.6	5.3	4.7	4.2	(37)
(38)		5% WB	MCDWB	9.9	10.1	10.4	11.8	13.4	14.5	14.9	15.2	15.2	13.3	11.6	11.0	(38)
(39)			MCWBR	3.5	3.7	3.8	4.6	6.1	7.2	7.5	6.6	6.1	4.9	4.4	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.376	0.374	0.365	0.341	0.306	0.291	0.288	0.341	0.397	0.416	0.385	0.383	(40)	
(41)		taud	2.394	2.401	2.414	2.440	2.492	2.515	2.509	2.344	2.217	2.208	2.340	2.372	(41)	
(42)		Ebn at Noon	967	955	936	915	910	907	922	900	889	904	953	962	(42)	
(43)		Edh at Noon	129	125	118	105	91	85	88	114	141	150	135	132	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.54	6.23	5.58	4.81	4.51	4.00	4.29	5.05	5.82	6.24	6.40	6.42	(44)	
(45)		RadStd	0.51	0.57	0.49	0.40	0.18	0.26	0.13	0.24	0.32	0.43	0.55	0.47	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page