

JOHANNESBURG BOTANICAL, South Africa

WMO: 683610

Lat: 26.1565S

Lon: 27.9988E

Elev: 1624

StdP: 83.28

Time Zone: 2.00 (E02)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 1.0	(c) 2.1	(d) -13.2	(e) 1.5	(f) 15.7	(g) -11.1	(h) 1.8	(i) 14.5	(j) 4.2	(k) 11.4	(l) 3.5	(m) 12.4	(n) 0.7	(o) 220	(p) 0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 10.9	(c) 31.9	(d) 15.4	(e) 30.6	(f) 15.2	(g) 29.2	(h) 15.3	(i) 19.7	(j) 25.0	(k) 19.0	(l) 24.4	(m) 18.4	(n) 24.1	(o) 1.7	(p) 310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	16.0	21.3	17.2	15.0	20.4	16.9	14.7	20.1	64.4	25.4	61.6	24.7	59.4	23.9	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
3.6	3.2	2.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-3.1	20.2	1.1	0.5	-3.9	20.6	-4.6	20.9	-5.2	21.1	-6.0	21.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	21.5	21.0	20.0	16.9	14.1	11.5	11.2	13.7	17.5	19.4	19.7	21.2	(6)
(7)		DBStd	4.40	1.99	1.69	2.07	2.40	2.60	2.15	2.10	3.08	3.19	2.95	2.80	2.33	(7)
(8)		HDD10.0	33	0	0	0	0	4	10	12	6	1	0	0	0	(8)
(9)		HDD18.3	860	2	2	8	55	131	204	220	144	51	23	17	4	(9)
(10)		CDD10.0	2698	356	309	309	207	133	56	50	122	226	291	292	347	(10)
(11)		CDD18.3	484	99	77	60	12	1	0	0	2	26	55	59	93	(11)
(12)		CDH23.3	4591	686	525	476	147	44	2	2	96	509	740	612	753	(12)
(13)		CDH26.7	1233	198	111	93	19	2	0	0	6	132	252	187	233	(13)
(14)	Wind	WSAvg	0.9	0.9	0.9	0.8	0.7	0.7	0.8	0.8	1.0	1.0	1.1	1.1	1.0	(14)
(15)	Precipitation	PrecAvg	713	125	114	99	38	17	5	1	5	14	66	93	119	(15)
(16)		PrecMax	1097	227	327	330	124	102	18	9	32	59	147	208	209	(16)
(17)		PrecMin	510	39	17	19	0	0	0	0	0	0	20	10	37	(17)
(18)		PrecStd	155	47	79	70	32	25	6	2	8	16	36	45	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	31.0	30.2	28.9	26.6	23.2	23.2	27.2	31.1	33.1	33.0	33.2	(19)
(20)			MCWB	16.4	16.4	15.8	15.4	12.4	10.0	9.1	11.7	13.4	14.5	14.2	16.4	(20)
(21)		2%	DB	30.8	29.3	29.0	26.9	24.3	21.9	21.9	25.9	29.8	31.1	30.8	31.0	(21)
(22)			MCWB	16.7	17.8	15.7	14.8	11.3	9.6	8.9	11.5	12.6	13.8	14.7	16.5	(22)
(23)		5%	DB	29.0	28.0	27.8	25.0	23.0	20.2	20.2	24.1	28.1	29.5	28.9	29.1	(23)
(24)			MCWB	16.9	17.3	15.6	13.5	11.2	8.9	8.6	10.4	12.1	13.8	14.9	16.5	(24)
(25)		10%	DB	27.1	26.8	26.1	23.5	21.5	19.0	18.9	22.2	26.8	27.8	27.0	27.8	(25)
(26)			MCWB	17.2	17.2	15.8	13.4	11.2	8.6	8.6	9.9	11.7	13.7	15.5	16.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	25.9	19.3	17.2	15.0	12.2	15.8	14.2	15.1	17.1	22.9	19.7	(27)
(28)			MCDWB	24.8	26.5	25.6	23.1	20.5	18.7	16.5	22.2	25.7	26.0	23.6	26.2	(28)
(29)		2%	WB	19.5	19.8	18.2	16.6	13.6	11.0	10.4	12.7	14.2	16.3	18.0	18.7	(29)
(30)			MCDWB	24.8	24.8	23.9	22.5	20.6	18.6	17.9	22.4	24.9	25.2	25.3	25.3	(30)
(31)		5%	WB	18.8	19.0	17.6	16.0	12.8	10.2	9.5	11.7	13.6	15.6	17.1	18.2	(31)
(32)			MCDWB	24.1	24.1	23.2	21.8	19.7	17.6	17.5	21.5	24.4	24.3	24.7	24.9	(32)
(33)		10%	WB	18.3	18.3	16.9	15.1	12.0	9.5	8.8	10.8	12.9	15.0	16.5	17.6	(33)
(34)			MCDWB	23.6	23.7	22.6	20.7	19.0	16.8	17.3	20.3	23.7	23.6	23.7	24.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.9	11.2	11.7	12.7	14.0	14.8	15.2	15.7	16.1	14.9	13.1	11.8	(35)
(36)			MCDBR	14.2	13.6	14.4	15.0	16.0	16.7	17.1	17.6	18.1	17.4	16.0	14.5	(36)
(37)			MCWBR	4.8	5.8	5.1	5.8	6.6	7.5	7.8	7.5	7.0	6.0	5.5	5.0	(37)
(38)		5% WB	MCDBR	10.3	10.8	11.1	11.3	13.4	14.2	15.0	15.4	15.8	14.1	13.0	12.0	(38)
(39)			MCWBR	4.4	5.5	4.7	5.1	6.4	7.2	7.9	7.0	6.4	5.8	5.7	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.386	0.389	0.376	0.328	0.292	0.274	0.276	0.329	0.370	0.403	0.363	0.371	(40)	
(41)		taud	2.324	2.316	2.331	2.438	2.518	2.540	2.522	2.365	2.265	2.206	2.358	2.355	(41)	
(42)		Ebn at Noon	957	938	920	921	918	916	927	906	911	914	972	973	(42)	
(43)		Edh at Noon	138	135	127	104	86	80	85	110	133	150	132	134	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.63	6.25	5.55	4.75	4.34	3.94	4.28	5.05	6.03	6.45	6.75	6.81	(44)	
(45)		RadStd	0.71	0.56	0.51	0.42	0.22	0.19	0.11	0.24	0.27	0.45	0.60	0.41	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	+0.66	+0.75	N/A	N/A	N/A	N/A	N/A	-181	+234	+87

Nomenclature: See separate page