

CAPE TOWN PORTNET, South Africa

WMO: 688170

Lat: 33.9206S

Lon: 18.4431E

Elev: 2

StdP: 101.30

Time Zone: 2.00 (E02)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	10.2	0.3	3.9	18.7	1.7	4.3	16.9	14.1	14.5	12.6	14.0	1.6	240	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.2	32.1	19.4	29.9	18.8	28.1	18.4	21.2	29.2	20.5	28.2	19.8	27.1	4.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.3	24.9	17.6	12.6	23.7	17.0	12.1	23.1	61.4	29.4	58.7	28.0	56.5	27.2	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	13.6	12.1	DB	7.6	36.1	0.9	2.5	6.9	37.9	6.3	39.3	5.8	40.7	5.1	42.5	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	22.1	22.2	20.8	19.0	16.7	15.0	14.9	14.9	16.1	18.2	19.2	21.1	(6)
(7)		DBStd	3.70	2.73	2.75	2.92	3.00	2.23	1.87	2.14	2.03	2.51	2.80	2.71	2.63	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	556	2	2	7	25	61	102	111	108	78	37	19	4	(9)
(10)		CDD10.0	3041	376	343	334	271	209	151	151	153	182	253	276	343	(10)
(11)		CDD18.3	554	119	111	83	46	12	2	3	3	10	32	45	89	(11)
(12)		CDH23.3	2698	628	576	392	222	44	11	13	13	47	154	186	411	(12)
(13)	CDH26.7	757	187	168	116	70	6	1	1	1	11	41	46	109	(13)	
(14)	Wind	WSAvg	4.4	5.9	5.3	4.7	3.9	2.9	3.1	3.3	3.4	4.3	4.9	5.6	5.5	(14)
(15)	Precipitation	PrecAvg	574	19	16	22	44	77	109	82	87	46	33	22	19	(15)
(16)		PrecMax	829	75	67	86	172	198	248	158	230	112	135	80	54	(16)
(17)		PrecMin	349	0	0	0	6	14	23	0	21	4	0	0	0	(17)
(18)		PrecStd	119	19	18	24	31	48	57	41	50	29	29	21	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	34.2	33.7	32.5	27.4	25.0	25.1	24.9	27.8	31.4	30.9	32.9	(19)
MCWB			20.8	20.1	19.7	18.4	15.6	14.3	14.2	15.0	15.5	18.0	17.1	21.0	(20)	
2%		DB	30.9	30.7	29.6	28.3	24.3	21.9	22.0	21.9	24.0	27.2	27.5	29.4	(21)	
		MCWB	20.0	19.6	19.0	17.4	15.2	12.8	13.7	14.0	14.4	16.6	16.9	19.1	(22)	
5%		DB	28.5	28.5	27.2	25.5	22.1	19.8	19.9	19.7	21.4	24.7	25.2	27.3	(23)	
		MCWB	19.3	18.9	18.5	16.6	15.0	12.9	13.4	13.4	13.8	16.1	16.3	18.5	(24)	
10%		DB	26.6	26.5	25.2	23.3	20.4	17.9	18.1	18.0	19.5	22.5	23.4	25.4	(25)	
		MCWB	19.1	18.7	18.1	16.1	14.5	12.9	12.9	12.8	13.4	15.5	15.8	18.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.8	22.4	21.2	19.9	17.5	15.9	15.8	16.2	16.3	19.6	19.2	21.8	(27)
MCDWB			31.0	29.8	29.2	29.2	23.5	20.6	22.7	22.0	26.3	30.6	28.7	32.2	(28)	
2%		WB	21.3	20.8	20.2	18.7	16.5	14.8	14.9	15.2	15.3	18.2	18.0	20.4	(29)	
		MCDWB	29.1	28.0	27.3	27.7	21.6	18.2	19.6	21.0	22.1	26.5	25.3	28.9	(30)	
5%		WB	20.5	20.0	19.3	17.8	15.8	14.2	14.3	14.4	14.7	17.1	17.3	19.6	(31)	
		MCDWB	28.0	27.2	26.0	25.2	20.4	17.1	18.4	19.1	19.9	24.1	23.8	27.1	(32)	
10%		WB	19.7	19.3	18.5	17.1	15.2	13.7	13.7	13.6	14.1	16.3	16.7	18.9	(33)	
		MCDWB	26.7	26.1	24.5	23.1	19.1	16.5	17.3	17.3	18.3	22.3	22.9	25.5	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.1	7.2	7.0	6.6	5.9	5.5	5.8	5.6	5.4	6.2	6.1	6.6	(35)
MCDBR			10.9	10.9	10.8	11.2	9.9	9.8	9.8	9.4	10.0	10.8	9.9	10.5	(36)	
MCWBR			4.4	4.3	4.2	4.1	4.5	5.0	5.0	4.7	4.3	4.4	4.3	4.7	(37)	
5% WB		MCDWB	10.7	9.7	10.0	11.0	8.2	6.8	7.8	8.8	9.0	10.5	9.5	10.7	(38)	
		MCWBR	4.6	4.2	4.1	4.4	4.2	4.0	4.3	4.6	4.1	4.3	4.3	4.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.345	0.336	0.323	0.322	0.317	0.319	0.334	0.344	0.353	0.340	0.344	(40)	
taud		2.540	2.543	2.565	2.593	2.589	2.576	2.566	2.521	2.456	2.446	2.526	2.528	(41)		
Ebn at Noon		994	972	945	902	847	824	842	875	920	951	991	996	(42)		
Edh at Noon		109	105	96	83	74	70	75	88	105	115	110	112	(43)		
(44)	All-Sky Solar Radiation	RadAvg	8.21	7.33	5.88	4.30	2.97	2.50	2.79	3.53	4.88	6.45	7.66	8.30	(44)	
(45)		RadStd	0.18	0.21	0.22	0.21	0.19	0.14	0.17	0.17	0.20	0.30	0.22	0.19	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	+0.36	+0.49	N/A	N/A	+0.53	+0.47	-2	-74	+111	+61	

Nomenclature: See separate page