

TANANA, AK, USA

WMO: 701780

Lat: 65.175N

Lon: 152.107W

Elev: 68

StdP: 100.51

Time Zone: -9.00 (NAK)

Period: 99-19

WBAN: 26529

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-44.1	-40.7	-36.8	0.1	-33.5	-35.8	0.1	-32.8	8.5	-17.0	7.8	-16.4	0.4	280	0.691

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	26.4	16.2	24.5	15.4	22.8	14.7	17.6	24.0	16.7	22.5	15.7	21.0	2.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.1	10.8	18.9	14.1	10.1	18.5	13.2	9.5	17.8	49.5	24.0	46.8	22.4	44.1	21.0	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.4	5.5	DB	-45.3	29.2	3.1	1.3	-47.6	30.1	-49.4	30.9	-51.2	31.6	-53.4	32.6	(4)
(5)			WB	-37.2	19.3	1.7	1.5	-38.4	20.3	-39.4	21.2	-40.4	22.1	-41.6	23.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.0	-22.2	-17.1	-13.8	-2.3	8.3	14.7	15.7	12.2	6.3	-3.2	-15.6	-20.0	(6)	
	DBStd	15.13	10.81	8.32	7.00	6.45	4.79	3.02	2.90	3.10	3.98	5.36	7.57	8.88	(7)	
	HDD10.0	5196	999	759	738	369	88	2	2	13	120	409	767	928	(8)	
	HDD18.3	7807	1257	992	997	619	311	116	91	192	361	667	1017	1187	(9)	
	CDD10.0	444	0	0	0	0	36	142	177	81	9	0	0	0	(10)	
	CDD18.3	14	0	0	0	0	0	5	8	1	0	0	0	0	(11)	
	CDH23.3	278	0	0	0	0	21	101	136	20	0	0	0	0	(12)	
	CDH26.7	37	0	0	0	0	2	14	19	1	0	0	0	0	(13)	
(14) Wind	WSAvg	2.2	2.1	2.4	2.5	2.5	2.4	2.2	2.0	1.9	2.1	2.3	2.0	2.1	(14)	
(15) Precipitation	PrecAvg	329	14	13	14	11	14	36	55	65	41	23	18	20	(15)	
	PrecMax	532	60	49	57	33	28	67	128	129	126	55	57	55	(16)	
	PrecMin	150	1	0	0	0	0	5	9	23	1	2	1	2	(17)	
	PrecStd	98	12	11	16	10	7	18	28	28	32	13	13	15	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.7	0.9	3.8	15.2	26.0	28.6	28.9	25.9	18.8	10.1	0.9	-2.0	(19)	
		MCWB	-1.6	0.1	1.4	7.4	13.3	16.5	17.7	17.0	11.7	6.1	0.0	-3.2	(20)	
	2%	DB	-3.5	-1.6	1.0	11.9	22.5	26.3	26.6	23.0	16.9	7.0	-1.1	-4.0	(21)	
		MCWB	-4.4	-3.1	-1.7	5.4	12.4	15.6	17.0	15.6	11.1	4.7	-2.0	-4.9	(22)	
	5%	DB	-5.8	-3.6	-1.2	9.4	19.9	24.2	24.7	20.5	14.8	5.1	-2.9	-6.2	(23)	
		MCWB	-6.5	-4.7	-3.2	4.2	11.0	14.7	16.3	14.3	10.2	3.3	-3.8	-6.9	(24)	
	10%	DB	-8.1	-6.0	-3.4	7.1	17.7	22.6	22.9	18.5	13.0	3.6	-5.3	-8.2	(25)	
		MCWB	-8.9	-6.9	-5.1	2.9	10.1	13.9	15.7	13.6	9.6	2.0	-6.0	-8.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.3	0.1	1.8	7.8	14.2	18.1	19.1	17.8	12.9	7.5	0.2	-2.7	(27)	
		MCDB	-0.4	0.8	3.5	13.7	23.7	26.1	26.1	24.0	16.6	9.4	0.7	-2.1	(28)	
	2%	WB	-3.9	-2.8	-1.4	5.8	12.9	16.8	17.9	16.5	11.7	4.9	-2.0	-4.8	(29)	
		MCDB	-3.1	-1.8	0.3	11.2	20.9	23.8	24.4	21.3	15.3	6.6	-1.2	-4.0	(30)	
	5%	WB	-6.0	-4.6	-3.2	4.5	11.8	15.7	17.2	15.3	10.8	3.4	-3.7	-6.7	(31)	
		MCDB	-5.3	-3.5	-1.2	9.1	18.6	22.3	23.1	19.0	13.9	4.8	-2.9	-6.1	(32)	
	10%	WB	-8.2	-6.8	-5.1	3.0	10.6	14.8	16.4	14.3	10.0	2.2	-5.9	-8.5	(33)	
		MCDB	-7.4	-5.8	-3.3	6.6	16.6	20.8	21.8	17.7	12.9	3.5	-5.2	-7.8	(34)	
(35) Mean Daily Temperature Range	MDBR		7.8	9.2	12.7	12.2	12.9	12.5	11.0	10.3	9.3	6.6	7.3	7.4	(35)	
	5% DB	MCDBR	6.7	7.5	12.5	13.3	17.0	16.3	15.6	14.4	13.1	7.5	5.8	6.7	(36)	
		MCWBR	6.3	6.8	10.3	8.1	8.4	7.8	7.8	8.1	8.2	5.5	5.3	6.1	(37)	
	5% WB	MCDBR	6.5	7.5	12.0	12.6	15.3	13.9	13.6	11.2	10.9	6.9	5.6	6.6	(38)	
		MCWBR	6.2	6.9	9.9	7.8	7.7	7.0	7.4	6.7	7.1	5.3	5.1	6.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.175	0.243	0.253	0.326	0.350	0.379	0.382	0.389	0.310	0.270	N/A	0.177	(40)	
	taud		1.925	2.205	2.293	2.178	2.385	2.328	2.363	2.332	2.542	2.402	N/A	1.935	(41)	
	Ebn at Noon		346	668	846	836	856	832	817	767	781	639	N/A	90	(42)	
	Edh at Noon		22	52	76	111	101	110	103	97	63	44	N/A	7	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.14	0.81	2.62	4.62	5.28	5.58	4.73	3.52	2.22	0.88	0.22	0.04	(44)	
	RadStd		0.01	0.07	0.18	0.29	0.46	0.39	0.33	0.36	0.29	0.11	0.03	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.26	N/A	N/A	N/A	N/A	N/A	N/A	-491	+111	+13
(47) Regional (5 neighbors)		+1.04	N/A	N/A	N/A	N/A	N/A	-320	-389	N/A	N/A

Nomenclature: See separate page