

GOLOVIN, AK, USA

WMO: 701995

Lat: 64.550N

Lon: 163.007W

Elev: 25

StdP: 14.68

Time Zone: -9.00 (NAK)

Period: 99-19

WBAN: 26628

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -25.7	(c) -20.3	(d) -28.8	(e) 1.1	(f) -16.7	(g) -27.1	(h) 1.2	(i) -15.6	(j) 42.7	(k) 23.1	(l) 39.3	(m) 22.1	(n) 7.5	(o) 320	(p) 0.844

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	71.6	59.5	66.3	57.2	63.6	55.7	60.4	67.6	58.6	65.2	56.9	63.1	8.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.0	69.4	63.5	54.9	64.2	61.6	53.8	61.7	60.5	26.6	67.6	25.4	65.0	24.2	63.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 34.6	(b) 29.7	(c) 25.7	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 34.6	(b) 29.7	(c) 25.7	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.1	7.6	10.5	10.0	24.5	37.1	50.8	54.7	53.3	44.1	31.5	15.7	8.1		
	DBStd	20.94	17.07	14.44	12.61	10.45	9.15	6.85	5.37	6.20	6.34	8.59	11.73	14.93		
	HDD50	8038	1315	1107	1240	764	410	68	14	30	192	572	1028	1298		
	HDD65	13119	1780	1527	1705	1214	865	430	323	370	627	1037	1478	1763		
	CDD50	406	0	0	0	0	10	91	159	131	15	0	0	0		
	CDD65	12	0	0	0	0	0	3	3	6	0	0	0	0		
	CDH74	58	0	0	0	0	1	30	18	9	0	0	0	0		
	CDH80	9	0	0	0	0	0	7	2	0	0	0	0	0		
	WSAvg	10.3	12.6	12.7	10.8	10.4	8.0	7.8	8.8	9.2	10.8	10.2	11.0	11.6		
	PrecAvg	24.4	1.7	1.7	1.3	1.1	1.1	1.5	2.7	3.7	3.1	2.6	2.2	1.8		
	PrecMax	33.3	3.4	5.3	3.5	2.6	2.7	2.5	5.6	7.4	6.4	5.5	4.6	3.4		
(15) Precipitation	PrecMin	17.6	0.5	0.4	0.3	0.3	0.4	0.7	0.7	1.1	0.8	1.2	0.4	0.7		
	PrecStd	3.7	0.8	1.1	0.8	0.6	0.6	0.5	1.1	1.3	1.3	1.2	1.1	0.7		
	DB	36.9	37.2	37.0	49.7	69.7	78.9	75.5	74.7	62.6	51.7	41.7	39.2			
	MCWB	32.7	33.6	32.5	41.0	53.9	59.1	59.8	61.4	51.9	46.9	37.4	33.4			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	35.6	35.8	34.2	45.2	58.8	69.7	70.1	70.3	56.9	46.1	37.3	36.3			
	2% MCWB	32.6	32.2	31.4	37.7	48.0	57.2	59.0	60.0	50.5	42.7	35.4	33.2			
	5% DB	33.6	33.5	31.9	41.5	54.2	64.2	65.8	65.9	54.5	45.0	35.7	33.8			
	5% MCWB	31.0	30.7	30.4	35.4	45.7	54.8	58.2	57.1	50.1	41.6	33.8	31.0			
	10% DB	29.9	29.9	29.6	38.5	48.5	61.4	63.2	63.0	52.8	43.0	32.4	28.3			
	10% MCWB	27.9	28.3	27.8	33.7	42.8	53.4	56.3	55.9	49.4	39.8	30.9	26.1			
	0.4% WB	34.1	35.4	34.2	40.6	54.1	61.2	63.5	63.6	54.2	46.4	38.3	35.2			
	0.4% MCDB	35.7	37.1	36.2	48.6	66.3	69.4	72.2	71.0	58.0	49.2	40.2	37.0			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	32.4	32.2	31.9	38.1	49.8	58.7	60.3	60.7	52.1	44.0	36.0	33.2			
	2% MCDB	34.6	34.6	33.5	44.3	58.2	67.6	66.8	68.1	55.4	46.0	38.0	36.5			
	5% WB	30.6	30.2	30.2	36.2	46.4	56.3	58.5	58.6	50.8	42.0	33.2	30.6			
	5% MCDB	32.8	32.2	31.5	41.4	51.9	63.9	64.8	64.3	54.0	44.7	35.1	33.1			
	10% WB	27.9	28.0	27.0	34.2	43.7	54.0	56.9	56.6	49.6	40.1	31.0	26.7			
	10% MCDB	29.5	29.5	28.7	38.0	49.2	60.8	62.9	62.1	52.7	43.0	32.4	28.4			
	MDBR	11.8	11.5	14.0	14.2	12.8	12.3	9.6	10.3	9.6	8.3	9.3	11.4			
	5% DB	11.7	10.6	10.7	15.2	20.0	18.1	16.5	12.9	11.1	8.2	7.4	10.7			
(36) Mean Daily Temperature Range	MCDBR	10.2	9.3	8.8	10.7	11.8	10.6	9.6	7.9	7.5	6.5	6.9	8.9			
	5% WB	11.8	10.4	8.9	14.7	18.0	16.5	14.6	11.2	9.0	7.7	7.1	10.1			
	MCWBR	10.8	9.5	7.8	10.6	11.1	10.3	9.2	7.7	6.4	6.6	6.8	8.6			
	MCWBR	10.8	9.5	7.8	10.6	11.1	10.3	9.2	7.7	6.4	6.6	6.8	8.6			
(40) Clear-Sky Solar Irradiance	taub	0.180	0.256	0.265	0.335	0.356	0.352	0.359	0.389	0.316	0.279	0.366	0.180			
	taud	1.917	2.135	2.242	2.091	2.260	2.431	2.448	2.341	2.540	2.386	2.788	1.899			
	Ebn at Noon	119	206	263	262	269	274	268	245	247	202	108	39			
	Edh at Noon	8	19	26	39	36	31	30	31	20	15	7	3			
(44) All-Sky Solar Radiation	RadAvg	48	251	811	1415	1661	1826	1448	1118	699	287	70	15			
	RadStd	7	36	83	91	152	164	96	142	68	36	11	1			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+1.49	N/A	N/A	N/A	N/A	+0.86	+0.99	N/A	N/A	+63	N/A

Nomenclature: See separate page