

NOME AP, AK, USA

WMO: 702000

Lat: 64.511N

Lon: 165.440W

Elev: 13

StdP: 14.69

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26617

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -27.0	(c) -22.5	(d) -31.0	(e) 1.0	(f) -25.2	(g) -27.5	(h) 1.2	(i) -21.5	(j) 33.8	(k) 16.7	(l) 30.4	(m) 18.6	(n) 1.4	(o) 10	(p) 0.872

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	68.2	56.0	64.2	55.2	61.1	54.2	58.5	64.4	56.9	62.1	55.0	59.8	10.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.1	66.9	60.1	54.1	62.3	58.6	52.3	58.2	56.7	25.4	64.3	24.3	62.0	23.2	60.1	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 28.3	(b) 25.1	(c) 22.0	(e) -29.4	(f) 76.5	(g) 5.5	(h) 4.4	(i) -33.4	(j) 79.7	(k) -36.6	(l) 82.3	(m) -39.7	(n) 84.7	(o) -43.6	(p) 88.0		
(4) 28.3	(5) 25.1	(6) 22.0	(7) -28.9	(8) 61.2	(9) 4.8	(10) 2.8	(11) -32.4	(12) 63.2	(13) -35.3	(14) 64.9	(15) -38.0	(16) 66.5	(17) -41.5	(18) 68.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.2	6.2	9.8	9.8	22.5	37.2	47.9	51.8	50.3	43.6	30.6	18.3	9.3
	DBStd	20.04	16.68	15.27	12.68	11.13	8.43	6.95	5.46	5.14	6.28	8.27	11.19	14.33
	HDD50	8197	1358	1124	1247	826	406	119	40	57	203	603	952	1262
	HDD65	13436	1823	1544	1712	1276	863	514	411	455	641	1068	1402	1727
	CDD50	238	0	0	0	0	8	56	95	67	12	0	0	0
	CDD65	3	0	0	0	0	0	1	1	1	0	0	0	0
	CDH74	23	0	0	0	0	0	7	12	4	0	0	0	0
	CDH80	2	0	0	0	0	0	1	1	0	0	0	0	0
	WSAvg	9.3	9.0	10.4	8.4	8.7	8.6	8.9	9.0	9.3	9.7	9.3	10.1	9.9
	PrecAvg	15.7	0.9	0.7	0.6	0.7	0.7	1.0	2.2	2.9	2.3	1.5	1.1	0.9
(15) Precipitation	PrecMax	24.3	2.4	2.1	3.1	2.2	3.0	4.1	6.3	6.6	7.5	3.9	4.4	2.2
	PrecMin	7.4	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.4	0.1	0.0	0.0	0.0
	PrecStd	3.7	0.6	0.6	0.6	0.6	0.7	0.9	1.3	1.4	1.5	0.9	0.9	0.5
	PrecStd	3.7	0.6	0.6	0.6	0.6	0.7	0.9	1.3	1.4	1.5	0.9	0.9	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.2	35.8	35.0	46.4	65.6	73.8	74.8	69.6	61.5	50.3	40.5	36.0
		MCWB	34.4	33.3	32.0	39.5	52.1	56.7	58.9	58.1	51.4	45.8	37.7	32.4
	2%	DB	33.5	33.1	32.6	42.2	58.2	67.7	68.2	65.2	57.3	46.2	37.4	33.5
		MCWB	31.7	31.8	30.8	37.0	48.0	54.2	56.8	56.9	49.7	43.0	35.8	31.8
	5%	DB	31.5	31.3	30.5	38.9	53.3	62.3	64.3	61.6	54.4	43.9	35.3	31.6
		MCWB	30.0	30.0	29.1	34.8	45.2	52.4	56.2	55.9	49.2	41.6	33.7	30.0
	10%	DB	28.9	29.5	28.2	36.1	49.3	58.4	61.1	58.5	52.3	41.6	33.1	28.8
		MCWB	27.6	28.2	26.9	33.2	42.7	51.0	55.2	54.3	48.4	39.7	31.9	27.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.9	34.0	33.2	40.0	52.7	58.4	60.8	61.6	53.4	46.5	38.5	33.9
		MCDB	36.9	35.0	33.9	45.4	64.2	69.5	69.7	66.6	57.0	48.9	39.5	34.8
	2%	WB	32.4	32.2	31.5	37.4	48.5	55.6	58.7	58.5	51.7	44.1	36.2	32.2
		MCDB	33.6	33.0	32.3	41.6	57.0	64.1	65.2	62.9	54.6	45.7	37.3	33.2
	5%	WB	30.2	30.4	29.4	35.2	45.8	53.5	57.3	56.7	50.6	42.1	33.9	30.1
		MCDB	31.3	31.1	30.3	38.2	52.8	60.6	62.8	60.4	53.4	43.7	34.9	31.2
	10%	WB	27.7	28.3	27.0	33.4	43.3	51.5	55.5	54.6	49.1	39.9	32.1	27.6
		MCDB	28.9	29.3	28.3	35.4	48.5	57.5	60.5	57.9	52.1	41.5	33.1	28.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.2	13.4	14.1	12.2	11.4	11.9	10.1	10.3	10.5	10.1	10.5	12.2
		MCDBR	11.0	10.1	10.4	11.7	19.3	20.0	17.9	15.7	12.5	8.7	6.6	9.7
		MCWBR	9.8	9.5	9.3	8.4	11.4	10.5	10.0	9.7	8.0	7.3	5.9	8.6
	5% WB	MCDBR	10.7	10.1	9.2	10.3	18.5	16.8	15.0	12.9	9.4	7.7	6.6	8.9
		MCWBR	9.9	9.9	8.6	7.6	11.2	9.4	9.1	8.9	6.8	7.1	6.4	8.4
(40) Clear-Sky Solar Irradiance	taub		0.179	0.255	0.273	0.328	0.366	0.355	0.374	0.400	0.322	0.283	0.374	0.185
	taud		1.911	2.117	2.188	2.072	2.203	2.430	2.416	2.279	2.510	2.361	2.729	1.892
	Ebn at Noon		120	206	258	264	265	273	263	240	244	199	101	37
	Edh at Noon		8	19	28	40	38	32	31	33	21	15	8	3
(44) All-Sky Solar Radiation	RadAvg		48	259	817	1457	1641	1807	1419	1107	701	283	68	16
	RadStd		7	35	102	95	204	178	95	143	65	33	11	1

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.49	N/A	N/A	N/A	+0.86	+0.99	N/A	N/A	+63	N/A
(47) Regional (6 neighbors)		+1.49	N/A	N/A	N/A	+0.86	+0.99	N/A	N/A	+63	N/A

Nomenclature: See separate page