

NOME AP, AK, USA

WMO: 702000

Lat: 64.511N

Lon: 165.440W

Elev: 4

StdP: 101.28

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26617

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.8	-30.3	-35.0	0.1	-31.8	-33.1	0.2	-29.7	15.1	-8.5	13.6	-7.4	0.6	10	0.872

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.6	20.1	13.3	17.9	12.9	16.1	12.3	14.7	18.0	13.8	16.7	12.8	15.5	4.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.4	9.6	15.6	12.3	8.9	14.8	11.3	8.3	13.7	41.2	17.9	38.7	16.6	36.1	15.6	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	11.2	9.8	-34.1	24.7	3.0	2.5	-36.3	26.5	-38.1	27.9	-39.8	29.3	-42.0	31.1		
(5)			-33.9	16.2	2.7	1.6	-35.8	17.3	-37.4	18.3	-38.9	19.2	-40.8	20.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.1	-14.3	-12.3	-12.4	-5.3	2.9	8.8	11.0	10.2	6.5	-0.8	-7.6	-12.6		
	DBStd	11.13	9.27	8.49	7.05	6.19	4.68	3.86	3.03	2.86	3.49	4.60	6.21	7.96		
	HDD10.0	4554	754	624	693	459	226	66	22	32	113	335	529	701		
	HDD18.3	7464	1013	858	951	709	479	286	228	253	356	593	779	959		
	CDD10.0	132	0	0	0	0	4	31	53	37	7	0	0	0		
	CDD18.3	2	0	0	0	0	0	1	1	1	0	0	0	0		
	CDH23.3	13	0	0	0	0	0	4	7	2	0	0	0	0		
	CDH26.7	1	0	0	0	0	0	1	1	0	0	0	0	0		
(14) Wind	WSAvg	4.2	4.0	4.7	3.8	3.9	3.9	4.0	4.0	4.2	4.3	4.2	4.5	4.4		
(15) Precipitation	PrecAvg	399	22	19	15	17	19	26	57	73	59	39	29	24		
	PrecMax	618	62	54	78	55	75	105	159	167	190	98	112	55		
	PrecMin	189	0	0	0	0	1	1	6	10	2	0	1	1		
	PrecStd	95	14	15	14	14	17	22	32	35	38	23	22	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	2.1	1.7	8.0	18.7	23.2	23.8	20.9	16.4	10.1	4.7	2.2		
		MCWB	1.4	0.7	0.0	4.1	11.2	13.7	14.9	14.5	10.8	7.7	3.2	0.2		
	2%	DB	0.8	0.6	0.3	5.7	14.6	19.8	20.1	18.5	14.0	7.9	3.0	0.9		
		MCWB	-0.2	-0.1	-0.7	2.8	8.9	12.4	13.8	13.8	9.8	6.1	2.1	-0.1		
	5%	DB	-0.3	-0.4	-0.8	3.8	11.8	16.8	17.9	16.5	12.4	6.6	1.8	-0.2		
		MCWB	-1.1	-1.1	-1.6	1.6	7.3	11.3	13.4	13.3	9.6	5.4	0.9	-1.1		
	10%	DB	-1.7	-1.4	-2.1	2.3	9.6	14.7	16.1	14.7	11.3	5.3	0.6	-1.8		
		MCWB	-2.4	-2.1	-2.9	0.6	5.9	10.5	12.9	12.4	9.1	4.3	-0.1	-2.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.6	1.1	0.6	4.4	11.5	14.7	16.0	16.4	11.9	8.0	3.6	1.1		
		MCDB	2.7	1.6	1.1	7.4	17.9	20.8	20.9	19.2	13.9	9.4	4.2	1.5		
	2%	WB	0.2	0.1	-0.3	3.0	9.2	13.1	14.9	14.7	11.0	6.7	2.3	0.1		
		MCDB	0.9	0.5	0.2	5.3	13.9	17.8	18.4	17.1	12.5	7.6	2.9	0.7		
	5%	WB	-1.0	-0.9	-1.5	1.8	7.7	12.0	14.0	13.7	10.3	5.6	1.0	-1.0		
		MCDB	-0.4	-0.5	-0.9	3.5	11.5	15.9	17.1	15.8	11.9	6.5	1.6	-0.4		
	10%	WB	-2.4	-2.1	-2.8	0.8	6.3	10.8	13.0	12.6	9.5	4.4	0.1	-2.5		
		MCDB	-1.7	-1.5	-2.1	1.9	9.2	14.2	15.8	14.4	11.1	5.3	0.6	-1.7		
(35) Mean Daily Temperature Range	MDBR		7.3	7.4	7.8	6.8	6.3	6.6	5.6	5.7	5.9	5.6	5.8	6.8		
	5% DB	MCDBR	6.1	5.6	5.8	6.5	10.7	11.1	9.9	8.7	6.9	4.9	3.7	5.4		
		MCWBR	5.5	5.3	5.2	4.7	6.3	5.8	5.6	5.4	4.4	4.1	3.3	4.8		
	5% WB	MCDBR	5.9	5.6	5.1	5.7	10.3	9.4	8.3	7.1	5.2	4.3	3.7	5.0		
		MCWBR	5.5	5.5	4.8	4.2	6.2	5.2	5.1	4.9	3.8	3.9	3.5	4.7		
(40) Clear-Sky Solar Irradiance	taub		0.179	0.255	0.273	0.328	0.366	0.355	0.374	0.400	0.322	0.283	0.374	0.185		
	taud		1.911	2.117	2.188	2.072	2.203	2.430	2.416	2.279	2.510	2.361	2.729	1.892		
	Ebn at Noon		378	648	814	833	836	861	830	757	770	627	318	117		
	Edh at Noon		26	60	87	125	121	100	99	103	66	48	24	10		
(44) All-Sky Solar Radiation	RadAvg		0.15	0.82	2.58	4.59	5.17	5.70	4.47	3.49	2.21	0.89	0.21	0.05		
	RadStd		0.02	0.11	0.32	0.30	0.64	0.56	0.30	0.45	0.20	0.10	0.04	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		+0.83	N/A	N/A	N/A	+0.48	+0.55	N/A	N/A	+35	N/A		
(47) Regional (6 neighbors)		+0.83	N/A	N/A	N/A	+0.48	+0.55	N/A	N/A	+35	N/A		

Nomenclature: See separate page