

ANVIK, AK, USA

WMO: 702075

Lat: 62.650N

Lon: 160.183W

Elev: 88

StdP: 14.65

Time Zone: -9.00 (NAK)

Period: 95-19

WBAN: 26644

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-25.8	-19.9	-29.0	1.1	-18.3	-27.1	1.2	-15.2	22.4	5.1	20.6	5.1	4.2	30	0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	73.2	57.2	70.5	56.3	66.4	54.2	59.6	70.1	57.6	67.4	55.9	64.8	5.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.7	63.8	62.3	53.7	61.4	61.3	51.8	57.3	59.8	26.1	69.6	24.8	67.3	23.6	64.2	67.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.2	17.4	15.8	DB	-28.5	78.7	7.5	2.4	-33.9	80.4	-38.4	81.8	-42.6	83.1	-48.1	84.8	(4)
(5)			WB	-25.7	61.4	5.7	3.7	-29.8	64.0	-33.1	66.2	-36.3	68.3	-40.4	70.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	30.3	5.4	11.3	13.4	30.0	44.8	54.8	56.5	52.7	44.9	29.8	13.4	5.4
	DBStd	21.72	15.91	13.33	11.56	10.47	8.73	6.12	5.33	5.32	6.21	8.77	11.91	13.07
	HDD50	7736	1382	1084	1134	600	204	21	7	28	169	626	1098	1383
	HDD65	12679	1847	1504	1599	1050	627	312	267	384	602	1091	1548	1848
	CDD50	541	0	0	0	0	42	163	209	111	16	0	0	0
	CDD65	11	0	0	0	0	0	5	4	2	0	0	0	0
	CDH74	84	0	0	0	0	5	39	32	8	0	0	0	0
	CDH80	6	0	0	0	0	0	5	1	0	0	0	0	0
Wind	WSAvg	6.9	9.0	8.8	8.1	7.0	5.9	5.0	5.2	5.4	6.0	7.0	7.7	8.2
Precipitation	PrecAvg	20.6	1.3	1.3	1.1	0.9	1.0	1.3	2.5	3.3	2.6	2.1	1.7	1.5
	PrecMax	27.0	3.0	4.4	3.1	2.0	2.0	2.2	4.8	6.6	4.9	5.4	3.5	3.1
	PrecMin	13.1	0.3	0.3	0.2	0.3	0.3	0.6	0.4	0.9	1.1	0.6	0.4	0.6
	PrecStd	3.5	0.7	0.8	0.7	0.5	0.4	0.5	1.1	1.1	1.0	1.1	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	38.7	39.2	54.8	73.1	79.0	78.8	74.5	63.4	51.8	39.1	37.3
		MCWB	34.3	34.6	32.2	42.9	53.8	59.6	60.5	60.9	52.0	45.4	36.6	34.2
	2%	DB	35.5	35.8	36.3	51.6	67.5	73.3	73.1	68.2	59.3	46.0	36.5	34.2
		MCWB	33.0	33.1	31.2	41.5	51.6	56.4	58.1	58.1	49.3	42.1	34.6	32.8
	5%	DB	31.5	32.4	33.7	46.3	63.0	70.4	70.5	64.1	55.4	43.7	34.3	27.9
		MCWB	30.0	31.0	29.8	38.2	49.2	54.9	57.2	55.0	48.4	39.9	32.5	26.5
	10%	DB	27.3	29.6	29.7	43.6	57.8	66.1	66.4	62.6	54.0	40.9	30.5	21.4
		MCWB	25.3	28.0	26.4	35.9	46.0	53.2	55.1	53.9	47.8	37.6	29.4	20.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.6	35.4	34.4	44.1	55.9	61.9	62.0	62.9	53.7	46.1	37.9	35.3
		MCDB	37.5	37.4	36.7	54.0	71.3	75.0	74.4	68.3	59.6	50.0	39.2	36.3
	2%	WB	32.6	33.3	31.9	41.2	52.3	58.4	59.7	59.0	51.5	43.2	34.8	32.3
		MCDB	34.6	35.2	35.8	49.9	65.1	70.9	70.5	66.8	56.4	45.7	36.0	34.2
	5%	WB	29.6	30.9	29.2	39.0	49.9	55.9	57.9	56.5	50.1	40.8	32.2	27.0
		MCDB	31.4	32.2	33.0	45.9	61.2	67.1	67.9	63.6	54.8	44.0	33.9	27.9
	10%	WB	25.6	27.3	26.2	36.9	47.5	54.1	56.4	54.4	48.4	38.3	29.5	21.1
		MCDB	27.7	28.7	29.5	43.1	57.7	64.3	65.6	60.4	52.7	40.6	30.9	22.1
Mean Daily Temperature Range	5% DB	MDBR	8.0	9.9	13.3	13.8	15.8	15.7	13.8	11.9	11.0	7.7	7.7	8.2
		MCDBR	9.4	11.1	12.6	14.8	20.8	21.4	20.4	15.7	14.5	9.7	8.6	11.8
		MCWBR	8.5	10.1	9.9	9.4	11.1	10.8	10.6	9.1	9.1	7.2	8.0	11.1
	5% WB	MCDBR	9.6	11.1	12.0	14.3	19.7	18.3	18.7	13.9	12.5	9.1	8.8	12.1
		MCWBR	9.1	10.4	9.8	9.3	10.6	9.6	9.9	8.3	8.2	7.2	8.4	11.5
Clear-Sky Solar Irradiance	taub		0.208	0.258	0.269	0.351	0.368	0.360	0.355	0.373	0.320	0.288	0.214	0.188
	taud		2.014	2.226	2.261	2.083	2.300	2.392	2.452	2.402	2.533	2.410	2.029	1.904
	Ebn at Noon		144	224	269	260	268	273	272	255	252	213	136	80
	Edh at Noon		10	19	27	40	36	33	31	30	22	16	10	6
All-Sky Solar Radiation	RadAvg		85	298	881	1439	1647	1685	1413	1089	718	324	107	37
	RadStd		11	39	94	109	175	171	115	123	77	37	17	3

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page