

ANVIK, AK, USA

WMO: 702075

Lat: 62.650N

Lon: 160.183W

Elev: 27

StdP: 101.00

Time Zone: -9.00 (NAK)

Period: 95-19

WBAN: 26644

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-32.1	-28.8	-33.9	0.2	-27.9	-32.9	0.2	-26.2	10.0	-15.0	9.2	-14.9	1.9	30	0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	22.9	14.0	21.4	13.5	19.1	12.4	15.4	21.2	14.2	19.7	13.3	18.2	2.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.6	9.1	16.8	12.0	8.8	16.3	11.0	8.2	15.4	42.8	20.9	39.8	19.6	37.1	17.9	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.8	7.1	-33.6	25.9	4.2	1.3	-36.6	26.9	-39.1	27.6	-41.4	28.4	-44.5	29.3		
(5)			-32.0	16.3	3.2	2.1	-34.3	17.8	-36.2	19.0	-37.9	20.1	-40.2	21.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.9	-14.8	-11.5	-10.3	-1.1	7.1	12.6	13.6	11.5	7.2	-1.2	-10.3	-14.8	(6)
(7)		DBStd	12.07	8.84	7.41	6.42	5.81	4.85	3.40	2.96	2.96	3.45	4.87	6.61	7.26	(7)
(8)		HDD10.0	4298	768	602	630	333	113	12	4	16	94	348	610	768	(8)
(9)		HDD18.3	7044	1026	836	888	583	348	173	148	213	334	606	860	1027	(9)
(10)		CDD10.0	301	0	0	0	0	23	91	116	62	9	0	0	0	(10)
(11)		CDD18.3	6	0	0	0	0	0	3	2	1	0	0	0	0	(11)
(12)		CDH23.3	47	0	0	0	0	3	22	18	4	0	0	0	0	(12)
(13)		CDH26.7	3	0	0	0	0	0	3	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.1	4.0	3.9	3.6	3.1	2.6	2.3	2.3	2.4	2.7	3.1	3.4	3.7	(14)
(15)	Precipitation	PrecAvg	522	34	33	27	22	26	34	63	84	67	53	42	37	(15)
(16)		PrecMax	687	76	112	78	51	50	56	122	167	124	136	90	78	(16)
(17)		PrecMin	333	8	8	5	7	8	15	10	23	29	16	9	15	(17)
(18)		PrecStd	88	17	21	17	12	11	12	27	27	26	28	22	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.9	3.7	4.0	12.6	22.8	26.1	26.0	23.6	17.4	11.0	4.0	2.9	(19)
(20)			MCWB	1.3	1.4	0.1	6.1	12.1	15.3	15.8	16.1	11.1	7.5	2.5	1.2	(20)
(21)		2%	DB	2.0	2.1	2.4	10.9	19.7	23.0	22.8	20.1	15.2	7.8	2.5	1.2	(21)
(22)			MCWB	0.6	0.6	-0.5	5.3	10.9	13.5	14.5	14.5	9.6	5.6	1.4	0.4	(22)
(23)		5%	DB	-0.3	0.2	1.0	8.0	17.2	21.3	21.4	17.8	13.0	6.5	1.3	-2.3	(23)
(24)			MCWB	-1.1	-0.5	-1.2	3.5	9.5	12.7	14.0	12.8	9.1	4.4	0.3	-3.1	(24)
(25)		10%	DB	-2.6	-1.4	-1.3	6.5	14.3	18.9	19.1	17.0	12.2	5.0	-0.8	-5.9	(25)
(26)			MCWB	-3.7	-2.2	-3.1	2.2	7.8	11.8	12.8	12.2	8.8	3.1	-1.4	-6.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.0	1.9	1.3	6.7	13.3	16.6	16.7	17.1	12.1	7.8	3.3	1.9	(27)
(28)			MCD B	3.1	3.0	2.6	12.2	21.8	23.9	23.5	20.1	15.4	10.0	4.0	2.4	(28)
(29)		2%	WB	0.3	0.7	-0.1	5.1	11.3	14.6	15.4	15.0	10.8	6.2	1.6	0.2	(29)
(30)			MCD B	1.4	1.8	2.1	9.9	18.4	21.6	21.4	19.4	13.6	7.6	2.2	1.2	(30)
(31)		5%	WB	-1.4	-0.6	-1.5	3.9	10.0	13.3	14.4	13.6	10.1	4.9	0.1	-2.8	(31)
(32)			MCD B	-0.3	0.1	0.5	7.7	16.2	19.5	20.0	17.5	12.7	6.7	1.1	-2.3	(32)
(33)		10%	WB	-3.6	-2.6	-3.2	2.7	8.6	12.3	13.6	12.5	9.1	3.5	-1.4	-6.1	(33)
(34)			MCD B	-2.4	-1.8	-1.4	6.2	14.3	18.0	18.7	15.8	11.5	4.8	-0.6	-5.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.5	7.4	7.6	8.8	8.7	7.6	6.6	6.1	4.3	4.3	4.6	(35)
(36)			MCDBR	5.2	6.2	7.0	8.2	11.5	11.9	11.3	8.7	8.0	5.4	4.8	6.6	(36)
(37)			MCWBR	4.7	5.6	5.5	5.2	6.2	6.0	5.9	5.0	5.0	4.0	4.4	6.2	(37)
(38)		5% WB	MCDBR	5.4	6.2	6.7	7.9	10.9	10.2	10.4	7.7	6.9	5.0	4.9	6.7	(38)
(39)			MCWBR	5.1	5.8	5.4	5.2	5.9	5.4	5.5	4.6	4.5	4.0	4.7	6.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.208	0.258	0.269	0.351	0.368	0.360	0.355	0.373	0.320	0.288	0.214	0.188	(40)	
(41)		taud	2.014	2.226	2.261	2.083	2.300	2.392	2.452	2.402	2.533	2.410	2.029	1.904	(41)	
(42)		Ebn at Noon	455	707	847	821	846	862	857	803	793	670	429	253	(42)	
(43)		Edh at Noon	33	60	85	127	113	105	97	94	68	51	31	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.27	0.94	2.78	4.54	5.19	5.31	4.45	3.43	2.27	1.02	0.34	0.12	(44)	
(45)		RadStd	0.04	0.12	0.29	0.34	0.55	0.54	0.36	0.39	0.24	0.12	0.06	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page