

HOOPER BAY, AK, USA

WMO: 702186

Lat: 61.524N

Lon: 166.147W

Elev: 6

StdP: 101.26

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26651

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.9	-23.8	-32.6	0.2	-23.5	-30.9	0.2	-20.6	19.2	-5.1	17.7	-6.6	4.7	110	0.970

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	18.7	14.0	17.1	12.8	15.0	12.3	14.8	17.6	13.7	16.2	12.7	14.6	5.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.0	9.4	15.4	12.4	9.0	14.9	11.5	8.4	14.0	41.2	17.6	38.3	16.1	36.0	14.6	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.0	14.5	12.8	DB	-27.9	21.1	4.3	2.8	-30.9	23.1	-33.4	24.7	-35.8	26.2	-38.9	28.2	(4)
(5)			WB	-28.4	15.8	3.4	2.7	-30.9	17.7	-32.9	19.3	-34.8	20.8	-37.2	22.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.5	-11.2	-9.2	-10.3	-3.4	2.3	7.9	10.8	11.1	8.1	1.5	-4.3	-9.9	(6)
(7)		DBStd	9.81	8.18	6.90	6.65	5.65	4.07	3.26	2.53	2.57	3.11	4.37	5.70	6.66	(7)
(8)		HDD10.0	3966	659	538	630	403	239	78	20	16	71	264	431	616	(8)
(9)		HDD18.3	6882	917	772	888	651	496	313	235	226	307	522	681	874	(9)
(10)		CDD10.0	128	2	0	0	2	2	16	43	48	14	1	0	0	(10)
(11)		CDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0	(11)
(12)		CDH23.3	3	0	0	0	0	0	1	1	1	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.6	7.3	8.0	7.1	6.4	5.8	5.8	5.5	6.1	6.4	6.4	7.1	7.4	(14)
(15)	Precipitation	PrecAvg	714	49	48	34	30	38	54	77	98	96	71	66	53	(15)
(16)		PrecMax	974	110	117	107	60	82	82	117	147	170	142	130	111	(16)
(17)		PrecMin	573	10	14	4	7	4	24	46	34	14	20	13	12	(17)
(18)		PrecStd	94	24	26	22	13	18	15	21	26	29	25	30	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	4.1	7.0	14.1	16.3	20.9	21.0	22.1	18.7	13.8	10.0	5.9	(19)
(20)			MCWB	5.0	1.7	2.2	7.5	9.8	13.7	16.1	16.4	13.2	7.4	4.9	2.7	(20)
(21)		2%	DB	7.5	2.0	1.9	10.8	12.1	16.1	17.7	18.8	17.3	11.1	7.8	1.7	(21)
(22)			MCWB	3.1	0.8	0.2	5.4	8.3	12.0	13.9	14.6	11.9	6.3	3.5	0.7	(22)
(23)		5%	DB	2.3	0.9	0.7	3.8	9.5	13.7	16.1	16.3	13.6	8.9	4.0	0.9	(23)
(24)			MCWB	0.8	0.1	-0.3	2.1	7.2	10.8	13.5	13.9	11.3	6.6	2.5	0.0	(24)
(25)		10%	DB	-0.2	-0.2	-0.9	2.3	7.6	12.3	14.1	14.1	12.2	7.5	2.5	-0.9	(25)
(26)			MCWB	-0.8	-0.7	-1.5	1.1	5.7	10.2	12.0	12.3	10.5	5.8	1.6	-1.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	1.9	2.4	8.0	10.8	14.2	16.8	16.7	13.7	9.0	5.7	2.8	(27)
(28)			MCDWB	14.7	3.9	5.5	14.9	15.1	18.8	19.5	20.2	17.0	10.8	8.1	5.9	(28)
(29)		2%	WB	2.9	0.6	0.5	5.3	8.9	12.5	14.7	15.0	12.3	7.9	3.9	0.7	(29)
(30)			MCDWB	7.8	1.2	1.4	10.4	11.6	15.2	17.2	17.8	15.6	9.5	6.6	1.4	(30)
(31)		5%	WB	0.7	0.0	-0.2	2.4	7.4	11.2	13.6	14.1	11.4	6.8	2.8	-0.1	(31)
(32)			MCDWB	2.0	0.6	0.4	3.9	9.4	13.4	15.8	16.5	14.0	8.4	4.3	0.5	(32)
(33)		10%	WB	-0.9	-0.9	-1.4	0.9	5.8	10.2	12.5	12.9	10.4	5.7	1.6	-1.0	(33)
(34)			MCDWB	-0.3	-0.4	-0.8	1.8	7.7	12.2	14.2	14.5	11.9	7.8	2.8	-0.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	5.5	6.6	5.6	4.3	4.6	3.8	3.5	3.8	3.9	4.6	5.4	(35)
(36)			MCDBR	8.9	5.3	7.0	6.3	7.9	8.1	6.9	6.5	5.5	3.5	5.0	4.9	(36)
(37)			MCWBR	6.9	4.9	6.0	4.5	5.4	5.1	4.3	4.2	3.4	2.8	4.3	4.5	(37)
(38)		5% WB	MCDWR	8.0	5.2	6.1	6.0	7.5	7.4	6.1	5.9	4.4	3.1	4.3	4.9	(38)
(39)			MCWBR	6.6	5.0	5.4	4.3	5.3	4.9	4.1	3.9	3.1	2.9	4.0	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.222	0.285	0.290	0.355	0.373	0.374	0.381	0.395	0.345	0.309	0.264	N/A	(40)	
(41)		taud	2.037	2.110	2.185	2.045	2.212	2.395	2.416	2.336	2.453	2.335	2.036	N/A	(41)	
(42)		Ebn at Noon	489	670	824	822	843	853	835	784	768	651	399	N/A	(42)	
(43)		Edh at Noon	38	72	95	134	124	106	102	101	75	58	38	N/A	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.32	1.06	2.78	4.46	5.00	5.14	4.19	3.30	2.14	1.04	0.33	0.14	(44)	
(45)		RadStd	0.05	0.14	0.33	0.42	0.63	0.46	0.31	0.43	0.19	0.08	0.05	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page