

TATALINA, AK, USA

WMO: 702315

Lat: 62.894N

Lon: 155.976W

Elev: 294

StdP: 97.84

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26536

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.2	-30.4	-37.2	0.1	-32.9	-34.3	0.2	-30.2	8.6	-6.4	7.4	-8.8	0.7	60	0.687

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	24.6	14.8	22.7	14.0	20.8	13.0	16.1	22.2	15.1	20.5	14.2	18.8	2.5	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	10.2	17.2	12.9	9.6	16.0	12.1	9.1	15.5	46.1	22.2	43.0	20.6	40.5	19.0	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	5.9	5.3	-34.6	27.1	3.2	1.5	-36.9	28.1	-38.8	29.0	-40.6	29.8	-43.0	30.9		
(5)			-34.6	17.4	2.7	1.6	-36.5	18.5	-38.1	19.4	-39.7	20.3	-41.6	21.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.7	-17.3	-11.6	-8.9	0.7	8.9	13.7	14.9	12.4	7.3	-2.1	-11.8	-14.5	(6)
(7)		DBStd	12.88	9.50	7.56	6.54	5.80	4.39	3.46	3.15	3.30	3.88	5.63	6.91	7.66	(7)
(8)		HDD10.0	4296	847	605	587	279	72	7	1	12	96	376	654	760	(8)
(9)		HDD18.3	6947	1106	838	846	529	294	146	116	187	331	634	904	1018	(9)
(10)		CDD10.0	408	0	0	0	1	37	117	152	87	14	1	0	0	(10)
(11)		CDD18.3	17	0	0	0	0	1	6	8	3	0	0	0	0	(11)
(12)		CDH23.3	109	0	0	0	0	6	37	51	16	0	0	0	0	(12)
(13)		CDH26.7	11	0	0	0	0	0	6	4	1	0	0	0	0	(13)
(14)	Wind	WSAvg	1.9	1.7	2.0	2.2	2.3	2.2	2.1	2.0	1.8	2.0	1.8	1.7	1.6	(14)
(15)	Precipitation	PrecAvg	443	25	18	16	16	21	45	70	73	56	37	34	31	(15)
(16)		PrecMax	637	88	89	68	52	52	83	141	136	146	119	101	124	(16)
(17)		PrecMin	252	0	0	0	0	0	10	16	26	9	7	0	3	(17)
(18)		PrecStd	90	23	21	18	13	13	21	31	26	39	23	28	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.8	4.5	6.4	15.2	24.1	26.9	26.9	25.6	18.7	11.7	4.1	4.5	(19)
(20)			MCWB	2.0	1.4	1.3	6.7	11.7	15.1	16.2	16.9	11.6	8.1	2.7	-0.9	(20)
(21)		2%	DB	1.6	2.4	3.6	12.2	21.0	24.0	24.8	22.3	15.9	8.2	2.0	1.6	(21)
(22)			MCWB	0.1	0.4	0.3	5.0	10.8	13.9	15.5	15.2	10.3	5.5	0.9	0.0	(22)
(23)		5%	DB	-0.8	0.6	1.8	10.4	18.6	22.1	22.8	19.7	14.1	6.6	0.1	-1.1	(23)
(24)			MCWB	-1.7	-0.6	-0.9	4.1	9.7	12.9	14.8	13.9	9.8	4.6	-0.5	-1.8	(24)
(25)		10%	DB	-3.5	-1.5	0.0	8.4	16.3	20.3	20.8	17.7	12.5	5.1	-2.4	-3.7	(25)
(26)			MCWB	-4.2	-2.6	-1.9	3.0	8.6	12.1	14.0	12.8	9.2	3.6	-2.9	-4.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.4	2.3	2.5	7.3	12.7	17.2	17.6	17.9	12.5	8.3	2.8	1.6	(27)
(28)			MCDWB	4.2	3.4	4.8	14.0	21.2	25.7	24.7	23.9	15.9	10.9	3.6	4.5	(28)
(29)		2%	WB	0.2	0.7	0.8	5.5	11.6	15.1	16.2	16.0	11.4	6.2	0.8	0.0	(29)
(30)			MCDWB	1.3	2.0	2.9	10.9	19.3	21.6	22.9	20.8	14.1	7.5	1.6	1.0	(30)
(31)		5%	WB	-1.8	-0.8	-0.4	4.4	10.4	13.8	15.3	14.6	10.5	5.1	-0.5	-1.9	(31)
(32)			MCDWB	-0.8	0.6	1.4	9.4	17.2	20.2	21.0	18.5	13.3	6.3	0.3	-0.6	(32)
(33)		10%	WB	-4.2	-2.6	-2.0	3.4	9.3	12.8	14.6	13.5	9.7	3.6	-2.8	-4.4	(33)
(34)			MCDWB	-3.4	-1.5	0.0	7.9	15.1	18.8	19.6	16.7	12.1	4.9	-2.4	-3.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	6.1	8.1	8.6	9.0	8.7	7.7	6.8	6.1	4.7	4.8	5.2	(35)
(36)			MCDBR	6.1	6.3	7.9	10.1	11.8	10.8	10.6	10.1	8.2	5.7	5.0	6.6	(36)
(37)			MCWBR	5.1	5.4	5.5	5.2	5.3	4.5	4.6	4.5	4.4	3.9	4.6	5.5	(37)
(38)		5% WB	MCDWB	6.2	6.4	7.1	9.2	10.5	9.7	9.3	8.5	6.7	5.2	5.0	6.3	(38)
(39)			MCWBR	5.4	5.6	5.3	5.0	5.0	4.5	4.4	4.2	4.0	3.8	4.7	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.194	0.253	0.260	0.306	0.341	0.358	0.356	0.360	0.302	0.275	0.204	0.180	(40)	
(41)		taud	2.035	2.231	2.289	2.253	2.411	2.381	2.434	2.436	2.578	2.466	2.034	1.916	(41)	
(42)		Ebn at Noon	480	710	860	878	875	863	855	817	817	695	436	255	(42)	
(43)		Edh at Noon	31	59	82	107	100	106	98	90	64	47	29	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.26	0.97	2.79	4.61	5.20	5.28	4.53	3.46	2.29	0.99	0.34	0.11	(44)	
(45)		RadStd	0.03	0.10	0.27	0.36	0.54	0.39	0.39	0.35	0.31	0.12	0.05	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	+1.00	N/A	+0.85	N/A	N/A	N/A	-299	-358	N/A	N/A

Nomenclature: See separate page