

TALKEETNA, AK, USA

WMO: 702510

Lat: 62.320N

Lon: 150.095W

Elev: 107

StdP: 100.05

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26528

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.9	-26.0	-32.7	0.2	-28.6	-29.7	0.2	-23.2	8.9	-7.6	8.1	-7.7	0.8	50	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	25.7	15.6	23.5	14.8	21.6	13.9	16.8	23.5	15.8	21.3	15.0	19.8	2.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	10.3	17.9	13.5	9.7	17.2	12.7	9.2	16.5	47.3	23.1	44.5	21.4	41.9	19.7	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.3	5.9	5.2	-32.4	28.9	4.6	2.8	-35.7	30.9	-38.4	32.5	-41.0	34.1	-44.3	36.1		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-32.1	17.9	3.9	1.2	-34.9	18.7	-37.2	19.4	-39.3	20.1	-42.2	20.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-9.6	-6.9	-4.2	2.6	8.8	13.9	15.6	13.7	9.0	1.6	-6.2	-8.8
	DBStd	10.44	8.20	6.83	5.49	3.77	3.29	2.83	2.49	2.48	3.05	4.65	6.47	7.20
	HDD10.0	3193	609	474	441	224	62	2	0	2	52	261	484	582
	HDD18.3	5788	867	708	699	473	294	135	92	144	281	519	734	841
	CDD10.0	457	0	0	0	1	26	120	172	118	21	1	0	0
	CDD18.3	11	0	0	0	0	0	3	6	2	0	0	0	0
	CDH23.3	213	0	0	0	1	14	75	93	31	0	0	0	0
	CDH26.7	44	0	0	0	0	2	18	19	5	0	0	0	0
Wind	WSAvg	1.8	2.3	2.1	2.2	1.8	1.9	1.8	1.6	1.3	1.3	1.5	2.0	2.2
Precipitation	PrecAvg	727	35	36	34	36	42	60	90	116	110	77	43	49
	PrecMax	1142	107	178	184	115	98	164	228	217	260	254	184	171
	PrecMin	394	0	0	2	3	10	12	27	26	23	7	0	0
	PrecStd	170	26	34	35	30	19	38	47	53	64	41	45	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.1	5.9	9.5	17.0	25.3	29.1	29.3	26.9	20.5	13.3	7.5	5.0
		MCWB	1.7	1.9	3.6	7.9	12.5	15.8	17.2	17.5	12.1	8.0	4.3	1.9
	2%	DB	3.2	3.9	7.0	13.5	21.5	25.3	25.7	23.5	17.8	11.0	4.9	3.1
		MCWB	0.7	1.0	2.1	6.1	11.1	15.0	16.4	15.2	11.2	6.5	2.4	0.5
	5%	DB	1.9	2.8	5.2	11.3	18.8	22.8	23.6	21.2	16.0	9.3	3.4	1.8
		MCWB	-0.1	0.4	1.1	4.7	9.9	13.9	15.6	14.5	10.8	5.8	1.2	-0.3
	10%	DB	0.8	1.6	3.5	9.8	16.6	20.7	21.5	19.2	14.3	7.7	2.0	0.6
		MCWB	-1.1	-0.6	0.1	3.9	8.9	13.0	14.7	13.7	10.1	4.9	0.3	-1.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.5	3.0	4.2	8.5	13.3	17.7	18.4	18.0	13.4	9.6	4.8	2.7
		MCDB	3.8	4.7	8.1	16.5	23.5	26.8	26.8	24.9	17.6	12.0	7.0	4.3
	2%	WB	1.3	1.9	2.8	6.5	11.8	15.8	17.1	16.4	12.3	7.7	3.0	1.0
		MCDB	2.7	3.3	6.0	12.1	19.9	23.1	24.2	21.4	15.8	9.9	4.4	2.2
	5%	WB	0.2	0.7	1.7	5.3	10.6	14.7	16.1	15.4	11.6	6.4	1.6	0.2
		MCDB	1.8	2.4	4.2	10.2	16.8	21.1	22.1	19.5	14.6	8.5	2.9	1.6
	10%	WB	-1.1	-0.5	0.6	4.4	9.6	13.6	15.2	14.5	10.9	5.4	0.5	-1.1
		MCDB	0.7	1.5	2.9	9.1	15.6	19.3	20.3	18.1	13.4	7.3	1.8	0.6
Mean Daily Temperature Range	5% DB	MDBR	8.0	9.5	11.2	10.7	11.3	10.1	8.7	8.8	8.8	7.8	7.4	7.7
		MCDBR	5.7	7.3	11.7	14.0	16.6	15.3	14.1	13.5	12.4	9.5	5.6	6.2
		MCWBR	4.4	5.5	7.8	7.8	7.8	6.4	6.1	6.5	6.9	5.9	3.9	4.9
	5% WB	MCDBR	5.5	6.2	9.4	12.3	13.8	13.0	12.1	10.9	9.4	7.2	4.5	5.5
		MCWBR	4.4	4.9	6.4	7.0	6.6	5.7	5.5	5.7	5.6	4.8	3.4	4.7
Clear-Sky Solar Irradiance	taub	0.215	0.272	0.284	0.336	0.368	0.369	0.373	0.357	0.314	0.287	0.228	0.202	
	taud	2.051	2.191	2.235	2.159	2.289	2.362	2.371	2.442	2.546	2.432	2.027	1.909	
	Ebn at Noon	469	686	827	843	847	854	838	823	805	683	418	253	
	Edh at Noon	34	64	88	118	114	109	105	90	67	51	33	21	
All-Sky Solar Radiation	RadAvg	0.26	0.97	2.70	4.58	5.43	5.36	4.68	3.67	2.40	1.11	0.38	0.12	
	RadStd	0.04	0.12	0.25	0.29	0.45	0.35	0.37	0.36	0.31	0.13	0.05	0.01	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	N/A	+1.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page