

NENANA, AK, USA

WMO: 702600

Lat: 64.550N

Lon: 149.072W

Elev: 110

StdP: 100.01

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26435

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.2	-38.7	-42.0	0.1	-27.8	-37.4	0.1	-29.6	11.7	-15.7	10.3	-13.4	0.5	100	0.679

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	27.0	16.1	25.0	15.5	23.1	14.6	17.7	24.7	16.6	22.9	15.6	21.2	2.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.8	19.1	14.0	10.1	18.1	13.0	9.5	17.4	49.9	24.8	46.8	22.9	44.0	21.1	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.7	6.7	DB	-43.7	29.6	3.4	1.9	-46.2	30.9	-48.2	32.0	-50.1	33.1	-52.5	34.4	(4)
(5)			WB	-36.8	19.6	2.2	1.4	-38.4	20.6	-39.7	21.4	-40.9	22.1	-42.6	23.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.5	-19.6	-15.2	-11.8	0.3	9.5	15.1	16.3	13.6	7.7	-2.5	-14.2	-18.4	(6)	
	DBStd	14.90	10.77	9.36	8.20	5.90	4.33	2.93	2.58	3.37	4.08	6.17	8.29	9.30	(7)	
	HDD10.0	4745	918	707	677	292	61	1	1	7	89	387	727	880	(8)	
	HDD18.3	7271	1176	940	935	541	274	103	72	151	319	645	977	1138	(9)	
	CDD10.0	536	0	0	0	1	46	155	196	119	19	0	0	0	(10)	
	CDD18.3	21	0	0	0	0	1	7	9	4	0	0	0	0	(11)	
	CDH23.3	363	0	0	0	0	29	128	152	54	0	0	0	0	(12)	
	CDH26.7	55	0	0	0	0	3	20	26	6	0	0	0	0	(13)	
(14) Wind	WSAvg	2.3	2.4	2.5	2.5	2.6	2.5	2.1	2.0	1.9	2.2	2.4	2.4	2.4	(14)	
(15) Precipitation	PrecAvg	302	12	11	8	8	16	41	85	67	41	24	20	13	(15)	
	PrecMax	425	53	43	63	78	72	121	192	136	171	126	53	38	(16)	
	PrecMin	192	0	1	0	0	2	6	34	21	5	5	0	2	(17)	
	PrecStd	60	12	11	14	18	15	30	47	33	33	26	18	9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.5	6.9	8.0	18.0	26.8	29.0	29.2	27.4	20.0	13.4	3.5	3.5	(19)	
		MCWB	2.6	2.5	3.1	8.5	13.0	16.7	17.9	17.1	12.5	7.6	1.0	0.8	(20)	
	2%	DB	1.7	2.6	5.2	14.1	23.2	26.8	27.0	24.8	17.9	9.8	1.3	0.3	(21)	
		MCWB	-0.7	-0.5	1.7	6.2	12.2	15.7	16.8	16.4	11.2	5.7	-0.6	-1.7	(22)	
	5%	DB	-1.2	0.7	2.6	12.0	20.8	24.5	24.9	22.2	16.2	7.5	-0.6	-2.3	(23)	
		MCWB	-3.2	-1.6	-0.7	5.0	11.0	14.8	15.9	15.1	10.4	4.2	-2.1	-4.1	(24)	
	10%	DB	-4.1	-2.1	0.0	9.4	18.5	22.7	23.0	19.9	14.3	5.4	-2.9	-5.7	(25)	
		MCWB	-5.7	-4.0	-2.6	3.8	9.7	13.9	15.3	14.0	10.0	2.7	-4.3	-7.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.8	2.7	4.4	9.1	14.0	18.7	19.2	18.9	13.8	8.6	1.3	1.2	(27)	
		MCDB	5.8	6.4	7.3	16.7	23.7	26.4	26.6	25.1	16.8	12.2	2.8	3.3	(28)	
	2%	WB	-0.4	0.2	1.6	6.8	12.7	16.9	17.8	17.2	12.4	6.1	-0.2	-1.4	(29)	
		MCDB	1.9	2.4	5.0	13.0	21.8	24.3	24.9	23.3	15.9	9.3	1.1	0.5	(30)	
	5%	WB	-2.8	-1.7	-0.5	5.4	11.7	15.7	16.8	15.8	11.4	4.4	-2.0	-3.7	(31)	
		MCDB	-0.9	0.7	2.5	11.0	19.3	22.5	23.3	20.5	14.9	7.1	-0.6	-2.0	(32)	
	10%	WB	-5.1	-3.9	-2.5	4.1	10.5	14.7	15.9	14.8	10.4	2.9	-4.3	-6.5	(33)	
		MCDB	-3.6	-1.7	0.1	9.4	17.3	21.1	21.7	18.7	14.0	5.3	-2.9	-5.3	(34)	
(35) Mean Daily Temperature Range	MDBR		9.0	11.1	12.9	12.3	12.8	12.2	11.0	10.7	10.5	7.9	7.9	9.3	(35)	
	5% DB	MCDBR	10.5	11.2	13.1	15.4	16.7	15.5	15.0	14.1	13.0	10.5	9.0	12.4	(36)	
		MCWBR	8.9	8.9	10.4	9.1	7.6	6.7	7.1	7.6	8.1	8.0	7.7	10.9	(37)	
	5% WB	MCDBR	10.7	10.9	12.5	14.4	14.6	14.0	13.2	12.3	11.5	10.3	8.9	12.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.177	0.249	0.255	0.307	0.347	0.384	0.379	0.392	0.312	0.267	N/A	0.179	(40)	
	taud		1.950	2.205	2.303	2.297	2.421	2.331	2.368	2.330	2.538	2.463	N/A	1.939	(41)	
	Ebn at Noon		392	673	851	868	863	830	824	768	785	670	N/A	134	(42)	
	Edh at Noon		24	55	77	100	98	110	103	98	64	43	N/A	9	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.17	0.88	2.68	4.60	5.29	5.62	4.84	3.70	2.34	0.95	0.25	0.05	(44)	
	RadStd		0.01	0.07	0.16	0.31	0.39	0.35	0.34	0.34	0.30	0.10	0.04	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.31	N/A	N/A	N/A	N/A	N/A	-621	-682	N/A	N/A
(47) Regional (7 neighbors)		+0.93	N/A	N/A	N/A	N/A	N/A	-333	-379	N/A	N/A

Nomenclature: See separate page