

CORDOVA, AK, USA

WMO: 702960

Lat: 60.492N

Lon: 145.476W

Elev: 31

StdP: 14.68

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26410

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.2	(c) 4.1	(d) -10.0	(e) 3.2	(f) 7.8	(g) -5.4	(h) 4.1	(i) 10.7	(j) 24.6	(k) 40.2	(l) 20.8	(m) 39.5	(n) 0.4	(o) 100	(p) 0.660

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.5	(c) 71.1	(d) 58.5	(e) 67.2	(f) 57.3	(g) 63.9	(h) 56.1	(i) 61.0	(j) 67.9	(k) 59.0	(l) 64.8	(m) 57.2	(n) 62.1	(o) 5.9	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.7	71.1	64.0	56.0	66.8	61.0	54.6	63.6	59.2	27.0	68.0	25.6	64.9	24.5	62.2	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 19.2	(b) 16.5	(c) 13.1	(e) -5.9	(f) 78.0	(g) 5.9	(h) 4.8	(i) -10.2	(j) 81.5	(k) -13.7	(l) 84.3	(m) -17.0	(n) 87.0	(o) -21.3	(p) 90.4		
(4) 19.2	(5) 16.5	(6) 13.1	(7) -5.9	(8) 78.0	(9) 5.9	(10) 4.8	(11) -10.2	(12) 81.5	(13) -13.7	(14) 84.3	(15) -17.0	(16) 87.0	(17) -21.3	(18) 90.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.1	27.1	29.2	31.0	38.1	45.5	51.5	54.7	54.1	48.7	40.5	31.5	29.1
	DBStd	12.13	10.84	8.88	7.33	4.88	4.43	3.85	3.01	3.15	4.13	5.83	8.99	9.66
	HDD50	3987	711	581	589	357	153	23	2	3	68	296	555	649
	HDD65	9073	1176	1001	1053	806	605	405	321	338	489	760	1005	1114
	CDD50	391	0	0	0	1	12	69	146	131	30	2	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	47	0	0	0	0	1	23	9	14	0	0	0	0
	CDH80	5	0	0	0	0	0	3	1	1	0	0	0	0
Wind	WSAvg	4.2	4.0	4.5	4.9	5.0	4.6	3.5	3.0	3.2	4.2	4.3	4.1	4.7
Precipitation	PrecAvg	95.4	7.6	7.0	5.6	5.1	5.6	4.7	6.2	10.2	15.0	11.5	8.1	8.5
	PrecMax	131.8	15.9	12.7	16.2	10.0	12.0	10.1	9.4	20.5	28.7	20.5	19.3	16.2
	PrecMin	56.7	2.6	1.6	1.5	2.3	1.7	1.4	2.6	3.3	7.2	3.5	1.7	3.4
	PrecStd	16.5	3.3	2.9	3.3	2.0	2.7	1.9	1.8	4.2	5.5	4.1	4.3	3.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.5	48.8	52.1	63.5	71.4	77.0	74.1	75.6	68.1	56.4	50.4	47.7
		MCWB	41.5	39.3	42.9	49.8	53.9	61.3	62.2	60.8	56.8	48.9	44.3	42.2
	2%	DB	44.8	43.6	46.1	55.1	66.0	70.4	68.5	69.4	62.9	53.6	47.5	44.9
		MCWB	40.6	39.2	39.8	44.2	51.8	57.1	60.3	59.5	53.6	47.5	43.1	40.9
	5%	DB	42.7	41.8	43.3	50.7	61.1	64.8	65.0	65.3	59.5	51.4	45.3	42.7
		MCWB	39.1	38.3	38.1	42.2	50.1	55.9	58.5	58.1	52.3	46.3	41.5	39.6
	10%	DB	40.7	40.2	41.2	47.5	56.6	60.8	62.2	62.3	56.9	49.5	43.2	40.8
		MCWB	38.0	37.2	36.9	41.1	48.4	53.8	56.7	56.3	51.5	45.1	39.8	38.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.6	42.0	44.0	51.1	56.4	62.7	63.7	64.0	57.7	52.1	46.4	43.5
		MCDB	46.8	45.4	49.7	62.0	66.8	75.0	72.3	71.6	63.1	54.4	48.8	45.9
	2%	WB	41.2	40.2	41.2	46.1	53.3	59.0	60.9	60.9	55.4	49.7	44.1	41.7
		MCDB	44.0	42.9	44.8	53.0	63.2	67.5	67.3	67.0	60.5	52.0	46.8	44.4
	5%	WB	39.5	38.9	39.1	43.3	51.0	56.6	58.9	58.7	53.9	47.6	42.1	40.0
		MCDB	42.0	41.4	42.1	48.7	59.1	63.5	64.2	63.9	57.9	50.3	44.8	42.2
	10%	WB	38.1	37.6	37.5	41.7	49.0	54.3	57.2	56.9	52.4	45.8	40.1	38.3
		MCDB	40.4	39.9	40.5	46.4	55.3	59.9	61.4	61.2	55.9	48.7	42.8	40.4
Mean Daily Temperature Range	5% DB	MDBR	12.9	13.8	15.1	15.3	15.9	14.2	12.5	14.2	14.6	13.4	12.3	11.3
		MCDBR	11.4	11.7	16.4	23.4	29.1	26.8	21.5	23.4	21.7	16.0	11.3	9.6
		MCWBR	8.3	8.0	11.0	14.7	17.2	16.2	14.4	15.4	14.2	10.6	8.0	7.0
	5% WB	MCDBR	10.6	10.0	13.2	20.1	24.4	22.6	18.7	19.6	17.2	11.2	9.9	8.7
		MCWBR	8.1	7.3	9.4	13.2	15.3	14.4	13.1	13.9	12.2	8.4	7.7	6.7
Clear-Sky Solar Irradiance	taub	0.254	0.294	0.310	0.352	0.366	0.373	0.366	0.368	0.334	0.316	0.259	0.233	
	taud	2.132	2.251	2.270	2.206	2.267	2.330	2.417	2.410	2.486	2.339	2.128	1.988	
	Ebn at Noon	158	222	259	266	272	271	271	260	251	210	150	107	
	Edh at Noon	13	21	29	37	38	36	32	30	23	19	13	9	
All-Sky Solar Radiation	RadAvg	95	318	802	1359	1684	1728	1494	1135	761	353	132	53	
	RadStd	10	52	82	123	91	75	94	130	107	44	19	5	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page