

IGIUGIG, AK, USA

WMO: 703061

Lat: 59.324N

Lon: 155.902W

Elev: 27

StdP: 101.00

Time Zone: -9.00 (NAK)

Period: 05-19

WBAN: 25521

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.6	-28.2	-34.8	0.1	-31.2	-31.7	0.2	-28.1	17.1	2.9	15.1	0.4	2.3	210	0.775

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	22.1	15.5	19.9	14.5	18.0	13.5	16.6	20.7	15.2	18.6	14.1	17.0	3.1	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.0	10.7	17.5	13.6	9.8	16.3	12.7	9.2	15.2	46.4	20.8	42.4	18.8	39.5	17.1	21.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.7	11.5	9.7	DB	-31.6	25.8	4.2	2.8	-34.6	27.8	-37.1	29.5	-39.5	31.1	-42.6	33.1	(4)
(5)			WB	-31.1	17.3	3.4	1.7	-33.6	18.5	-35.5	19.5	-37.4	20.5	-39.9	21.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.7	-9.9	-5.9	-7.0	0.3	6.2	10.9	13.1	12.6	9.0	2.6	-5.0	-6.7	(6)	
	DBStd	10.22	11.09	8.15	7.31	4.38	3.11	2.65	2.53	2.13	3.23	4.86	7.41	8.73	(7)	
	HDD10.0	3281	618	447	528	290	123	18	2	3	53	232	449	517	(8)	
	HDD18.3	6066	876	680	787	540	376	223	163	177	279	489	699	776	(9)	
	CDD10.0	259	0	0	0	0	6	46	99	85	23	1	0	0	(10)	
	CDD18.3	2	0	0	0	0	0	1	1	0	0	0	0	0	(11)	
	CDH23.3	29	0	0	0	0	1	14	13	1	0	0	0	0	(12)	
	CDH26.7	5	0	0	0	0	0	4	1	0	0	0	0	0	(13)	
(14) Wind	WSAvg	3.8	4.0	4.0	3.5	4.0	4.1	3.7	3.2	3.5	3.7	3.6	4.0	4.3	(14)	
(15) Precipitation	PrecAvg	826	62	53	47	44	48	55	77	83	108	89	79	80	(15)	
	PrecMax	1043	152	97	89	69	100	83	122	142	180	156	184	148	(16)	
	PrecMin	625	19	12	11	6	17	18	39	27	45	13	10	36	(17)	
	PrecStd	112	28	19	25	15	20	17	21	27	33	31	41	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	6.0	6.5	11.6	20.8	26.3	25.2	22.2	18.6	12.8	8.1	5.6	(19)	
		MCWB	4.2	3.3	4.2	5.8	12.3	16.5	17.1	16.2	13.8	9.6	6.0	3.5	(20)	
	2%	DB	4.9	3.9	4.6	9.1	16.8	21.3	22.5	20.0	16.2	11.5	6.5	4.6	(21)	
		MCWB	3.1	2.0	2.7	4.9	10.1	14.0	16.2	15.1	12.3	8.8	4.9	2.9	(22)	
	5%	DB	3.8	3.0	3.3	7.3	13.8	18.4	20.3	18.3	14.5	10.4	5.5	3.8	(23)	
		MCWB	2.3	1.4	1.8	4.3	8.3	12.7	15.0	14.2	11.9	8.2	4.1	2.3	(24)	
	10%	DB	2.9	2.2	2.3	5.7	11.5	16.1	18.1	16.7	13.5	9.2	4.2	2.9	(25)	
		MCWB	1.6	1.0	1.0	3.4	7.4	11.6	14.2	13.5	11.3	7.3	2.9	1.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.4	3.5	4.6	6.4	12.9	16.8	19.1	18.4	14.5	10.2	6.5	4.0	(27)	
		MCDB	6.4	5.3	5.8	9.8	20.4	24.1	22.6	19.7	16.8	11.9	7.9	5.1	(28)	
	2%	WB	3.3	2.4	3.1	5.4	10.5	14.6	17.1	16.1	13.4	9.3	5.1	3.1	(29)	
		MCDB	4.7	3.6	4.2	8.6	15.7	20.0	21.2	18.7	15.0	11.0	6.1	4.2	(30)	
	5%	WB	2.5	1.7	1.9	4.5	8.9	13.3	15.6	14.8	12.5	8.5	4.1	2.5	(31)	
		MCDB	3.7	2.7	2.9	7.0	12.7	17.6	19.4	17.3	14.0	10.2	5.3	3.6	(32)	
	10%	WB	1.6	1.0	1.1	3.6	7.8	12.1	14.5	13.8	11.6	7.5	3.0	1.7	(33)	
		MCDB	2.8	2.0	2.1	5.5	10.9	15.4	17.5	16.0	13.2	9.2	4.1	2.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.2	8.3	7.5	8.3	8.4	7.2	6.7	7.3	6.7	6.9	6.3	(35)	
		MCDBR	4.4	5.5	6.5	9.0	13.6	13.4	12.3	10.1	8.7	6.0	5.3	4.4	(36)	
	5% WB	MCWBR	3.4	4.3	4.8	5.6	7.3	6.9	6.2	5.6	5.6	4.2	4.3	3.5	(37)	
		MCWBR	4.1	5.3	5.7	8.2	11.6	12.3	11.1	8.5	7.5	5.1	5.4	4.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.256	0.298	0.312	0.358	0.383	0.379	0.375	0.362	0.330	0.304	0.272	0.256	(40)	
		taud	2.136	2.203	2.219	2.236	2.274	2.357	2.416	2.450	2.512	2.427	2.108	1.975	(41)	
	Edn at Noon		541	708	820	840	844	854	835	809	713	495	360		(42)	
		Edh at Noon	45	73	97	115	119	112	103	93	74	59	46	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.39	0.99	2.61	3.95	4.79	5.26	4.42	3.55	2.45	1.27	0.53	0.24	(44)	
	RadStd		0.06	0.18	0.40	0.48	0.52	0.48	0.42	0.42	0.34	0.12	0.08	0.02	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (9 neighbors)		N/A	+2.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page