

EGEGIK, AK, USA

WMO: 703334

Lat: 58.185N

Lon: 157.386W

Elev: 92

StdP: 14.65

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 25519

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.8	-8.9	-23.6	1.5	-13.0	-17.0	2.2	-8.5	37.1	35.3	33.5	35.1	6.3	20	0.840

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	66.1	57.2	63.3	55.9	61.1	54.9	58.6	64.0	57.3	62.0	55.9	60.2	11.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.8	66.5	60.1	54.7	63.8	59.0	53.9	62.1	58.3	25.4	64.1	24.6	62.1	23.7	60.0	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 32.5	28.0	24.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-12.5	61.5	5.9	2.3	-16.7	63.2	-20.2	64.6	-23.5	65.9	-27.7	67.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.4	17.5	24.4	24.1	33.2	42.6	49.2	53.2	54.3	49.2	38.0	28.4	22.4		
	DBStd	15.64	15.06	12.18	11.78	7.07	5.57	4.40	3.97	3.45	4.50	7.97	11.20	13.60		
	HDD50	5293	1009	718	803	503	237	65	15	4	64	373	647	855		
	HDD65	10429	1474	1138	1267	953	696	474	367	333	474	836	1097	1320		
	CDD50	340	0	0	1	0	6	41	114	137	40	1	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	2	0	0	0	0	0	1	1	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	11.4	11.1	12.2	11.4	11.7	11.6	10.9	11.1	10.9	11.4	11.6	11.7	11.8		
	PrecAvg	32.5	2.4	2.1	1.9	1.7	1.9	2.2	3.0	3.3	4.3	3.5	3.1	3.1		
(15) Precipitation	PrecMax	41.1	6.0	3.8	3.5	2.7	3.9	3.3	4.8	5.6	7.1	6.1	7.2	5.8		
	PrecMin	24.6	0.7	0.5	0.4	0.2	0.7	0.7	1.5	1.1	1.8	0.5	0.4	1.4		
	PrecStd	4.4	1.1	0.7	1.0	0.6	0.8	0.7	0.8	1.1	1.3	1.2	1.6	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.3	43.4	54.8	53.8	65.6	69.7	71.9	70.3	62.9	54.4	49.6	45.1		
		MCWB	38.5	39.0	40.8	43.9	52.4	56.9	59.5	60.4	56.0	49.2	47.2	42.4		
	2%	DB	38.9	40.4	45.4	48.3	57.7	63.9	65.7	65.6	59.4	52.2	46.4	42.8		
		MCWB	36.8	37.4	39.8	41.8	48.6	54.6	57.3	58.4	53.8	48.4	43.9	39.2		
	5%	DB	37.2	38.6	40.1	45.6	54.5	61.0	62.9	63.0	57.2	50.2	44.8	39.5		
		MCWB	35.4	36.0	36.7	40.1	46.7	52.6	56.4	56.7	52.3	47.1	42.1	37.0		
	10%	DB	36.1	36.9	37.2	43.1	51.9	57.1	60.6	60.7	55.3	48.1	42.7	37.4		
		MCWB	34.5	34.5	34.5	38.5	45.5	50.6	55.6	55.8	51.4	45.3	40.4	35.6		
	0.4%	WB	38.6	40.1	42.7	45.1	53.4	57.9	60.3	61.4	58.0	51.0	47.4	42.8		
		MCDB	40.7	42.9	50.1	51.4	64.1	65.7	68.0	67.7	61.8	52.9	48.9	45.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.3	38.1	39.6	42.3	49.8	55.6	58.5	59.0	55.2	49.4	44.9	39.6		
		MCDB	38.8	40.2	44.1	47.5	57.3	63.2	64.3	64.0	58.1	51.5	46.3	42.3		
	5%	WB	35.9	36.4	37.0	40.7	47.5	53.4	57.2	57.5	53.6	47.1	42.3	37.8		
		MCDB	37.3	38.3	40.4	45.2	53.3	59.5	62.0	61.8	56.0	49.6	44.4	40.0		
	10%	WB	34.1	34.9	35.0	39.0	45.9	51.5	55.8	56.1	52.3	45.8	40.3	36.2		
		MCDB	35.6	36.8	38.0	43.1	50.5	56.2	60.0	59.9	54.8	47.9	42.8	37.9		
	5% DB	MDBR	10.9	10.5	12.0	12.2	12.6	12.6	9.9	9.5	10.1	9.9	9.5	10.8		
		MCDBR	8.3	8.9	12.5	16.0	18.7	19.4	15.6	14.0	12.0	10.3	8.5	7.9		
		MCWBR	7.5	7.4	9.4	10.9	11.1	11.1	9.4	8.4	8.1	7.7	7.2	6.9		
		MCWBR	8.2	9.1	11.8	14.9	16.8	17.5	14.0	12.6	10.5	9.3	8.3	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.273	0.307	0.317	0.361	0.382	0.369	0.367	0.366	0.340	0.311	0.301	0.272		
		taud	2.173	2.264	2.276	2.246	2.288	2.405	2.458	2.459	2.496	2.436	2.136	2.053		
	Ebn at Noon		178	229	263	267	270	275	273	265	256	229	158	129		
		Edh at Noon	16	23	30	36	38	34	32	30	24	19	16	13		
(44) All-Sky Solar Radiation	RadAvg		141	327	834	1241	1517	1627	1348	1117	792	432	185	87		
	RadStd		20	53	130	137	153	157	138	124	91	43	23	8		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page