

TOGIK, AK, USA

WMO: 703606

Lat: 59.067N

Lon: 160.367W

Elev: 6

StdP: 101.25

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 25629

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.5	-24.7	-33.0	0.2	-25.6	-32.0	0.2	-23.9	16.2	2.6	14.5	0.0	3.4	10	0.836

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	20.0	14.8	17.9	13.5	17.0	13.0	15.5	18.4	14.5	17.1	13.6	16.0	5.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.0	10.0	16.5	12.9	9.3	15.4	12.4	9.0	14.9	43.1	18.5	40.3	17.1	38.0	15.9	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.1	10.7	DB	-30.9	23.7	3.2	2.2	-33.2	25.3	-35.0	26.5	-36.8	27.7	-39.2	29.3	(4)
(5)			WB	-30.8	16.3	2.6	1.6	-32.6	17.5	-34.1	18.5	-35.5	19.4	-37.4	20.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.4	-7.9	-6.7	-6.9	-0.3	5.5	10.1	12.2	11.7	8.5	2.2	-4.3	-7.6	(6)
(7)		DBStd	9.47	8.33	7.99	7.03	4.40	3.41	2.69	2.25	2.13	2.78	4.62	6.50	8.33	(7)
(8)		HDD10.0	3317	554	467	526	311	143	31	5	7	58	242	429	545	(8)
(9)		HDD18.3	6173	812	701	784	561	398	247	190	204	295	499	679	803	(9)
(10)		CDD10.0	187	0	0	0	0	4	33	74	62	13	1	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	4	0	0	0	0	1	2	1	1	0	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	1	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.9	5.0	5.5	5.2	5.1	4.7	4.3	4.4	4.6	4.8	5.0	5.0	5.4	(14)
(15)	Precipitation	PrecAvg	830	66	62	51	42	48	51	70	81	105	93	88	74	(15)
(16)		PrecMax	1219	152	162	142	102	92	89	114	129	199	184	175	128	(16)
(17)		PrecMin	636	19	7	10	9	13	8	30	20	13	16	13	15	(17)
(18)		PrecStd	135	29	32	33	20	20	18	22	27	41	39	42	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	4.1	6.5	11.6	20.0	22.6	22.3	21.1	17.2	12.1	9.6	6.1	(19)
(20)			MCWB	3.3	2.5	3.2	6.1	11.6	14.3	16.3	15.1	11.8	8.8	7.4	3.6	(20)
(21)		2%	DB	3.9	2.9	3.9	7.9	15.9	19.0	20.1	18.6	15.0	10.8	7.4	4.0	(21)
(22)			MCWB	2.2	1.6	1.6	4.5	9.2	13.5	15.8	14.5	11.6	8.9	5.8	2.4	(22)
(23)		5%	DB	2.7	2.4	2.5	6.3	12.7	17.2	17.9	17.2	13.7	9.1	6.0	2.9	(23)
(24)			MCWB	1.4	1.3	0.9	3.4	8.4	12.6	13.9	13.5	10.9	7.8	4.5	1.7	(24)
(25)		10%	DB	2.1	2.0	2.0	4.8	11.1	15.1	17.0	16.0	12.6	8.0	3.9	2.3	(25)
(26)			MCWB	1.1	1.1	0.7	2.7	7.5	11.7	13.4	13.0	10.4	6.7	3.0	1.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.9	3.3	4.1	7.0	11.7	15.8	18.1	16.6	13.6	10.2	7.7	4.2	(27)
(28)			MCDB	5.7	4.4	6.5	10.9	18.7	20.3	20.6	19.5	15.2	11.1	9.7	5.8	(28)
(29)		2%	WB	2.5	2.1	2.0	5.0	10.0	14.3	16.0	15.2	12.4	9.0	6.2	2.9	(29)
(30)			MCDB	3.6	2.7	3.4	7.8	14.3	18.0	19.1	17.5	13.8	10.2	7.4	3.8	(30)
(31)		5%	WB	1.7	1.4	1.2	3.9	8.7	13.0	14.7	14.2	11.5	8.0	4.6	1.9	(31)
(32)			MCDB	2.5	2.1	2.4	6.0	12.4	16.6	17.4	16.3	13.0	8.9	6.0	2.9	(32)
(33)		10%	WB	0.8	0.7	0.5	2.9	7.8	11.8	13.7	13.4	10.7	7.3	3.2	1.2	(33)
(34)			MCDB	1.8	1.6	1.6	4.5	10.3	14.5	16.3	15.5	12.3	8.2	4.0	2.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.1	6.3	7.3	6.1	7.1	6.9	6.1	6.1	6.5	6.2	6.3	6.4	(35)
(36)			MCDBR	3.9	4.5	5.7	8.1	12.2	11.6	10.0	9.2	7.9	5.1	4.6	4.1	(36)
(37)			MCWBR	3.0	3.7	4.4	5.5	7.2	6.6	6.1	5.8	5.3	3.9	3.7	3.5	(37)
(38)		5% WB	MCDBR	3.7	4.2	4.7	7.5	10.7	10.4	9.0	7.7	5.9	4.1	4.4	3.6	(38)
(39)			MCWBR	3.1	3.7	3.8	5.3	6.6	6.3	5.9	5.2	4.5	3.6	3.7	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.258	0.332	0.322	0.389	0.417	0.378	0.372	0.373	0.335	0.311	0.285	0.260	(40)	
(41)		taud	2.112	2.031	2.115	2.006	2.106	2.354	2.415	2.411	2.488	2.378	2.101	1.982	(41)	
(42)		Ebn at Noon	542	642	802	800	808	856	853	824	804	700	482	367	(42)	
(43)		Edh at Noon	47	88	108	145	141	112	103	97	76	62	48	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.41	1.06	2.76	4.22	5.01	5.16	4.39	3.45	2.44	1.30	0.50	0.23	(44)	
(45)		RadStd	0.08	0.19	0.40	0.51	0.62	0.42	0.47	0.43	0.33	0.15	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page