

SELDOVIA, AK, USA

WMO: 703621

Lat: 59.443N

Lon: 151.702W

Elev: 29

StdP: 14.68

Time Zone: -9.00 (NAK)

Period: 98-19

WBAN: 25516

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.9	(c) 9.4	(d) -3.9	(e) 4.5	(f) 12.6	(g) -0.1	(h) 5.5	(i) 13.8	(j) 20.2	(k) 30.6	(l) 18.2	(m) 27.3	(n) 3.8	(o) 180	(p) 0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.8	(c) 67.4	(d) 58.3	(e) 64.3	(f) 56.4	(g) 62.5	(h) 55.3	(i) 59.1	(j) 65.9	(k) 57.5	(l) 63.2	(m) 56.1	(n) 61.0	(o) 6.4	(p) 30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.4	65.3	61.3	54.4	63.1	59.8	53.7	61.5	58.8	25.7	66.0	24.7	63.4	23.8	61.0	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.0	14.3	12.0	2.9	72.6	4.8	4.0	-0.6	75.5	-3.4	77.8	-6.1	80.0	-9.6	82.9		
			1.7	61.7	4.8	2.3	-1.8	63.4	-4.6	64.7	-7.3	66.1	-10.9	67.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.6	26.6	28.9	29.2	36.6	44.2	50.7	55.2	54.4	48.7	40.4	31.4	28.6
	DBStd	12.02	9.26	8.02	7.21	4.61	4.11	3.62	3.44	3.40	4.01	5.85	7.34	8.26
	HDD50	4179	726	592	646	403	184	33	1	3	68	301	557	665
	HDD65	9262	1191	1012	1111	852	645	430	303	329	489	763	1007	1130
	CDD50	391	0	0	0	0	4	53	163	140	29	2	0	0
	CDD65	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH74	3	0	0	0	0	0	0	2	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.7	3.5	3.7	4.0	3.6	4.0	4.1	4.0	3.5	3.4	3.3	3.8	3.7
Precipitation	PrecAvg	24.8	2.1	1.9	1.3	1.1	0.8	1.1	1.8	2.6	3.7	2.8	2.6	3.0
	PrecMax	34.3	7.1	6.1	2.8	3.8	2.2	2.0	3.6	4.5	6.7	8.1	7.8	5.0
	PrecMin	15.0	0.0	0.3	0.1	0.2	0.3	0.3	0.6	0.3	1.2	1.2	0.3	0.4
	PrecStd	3.9	1.5	1.3	0.8	0.8	0.4	0.5	0.8	1.0	1.4	1.4	1.9	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.8	44.7	46.1	53.2	62.5	69.9	72.3	70.8	61.4	57.2	48.9	50.4
		MCWB	41.3	40.5	41.5	45.3	50.4	58.2	60.6	61.0	54.0	51.3	45.0	44.3
	2%	DB	42.6	41.4	43.0	48.7	57.8	64.3	68.1	66.1	58.8	52.3	45.8	44.1
		MCWB	39.8	38.5	39.3	42.2	48.1	55.0	58.9	58.0	53.0	48.2	43.7	40.8
	5%	DB	39.7	39.2	40.4	46.2	54.5	61.5	65.2	63.5	56.9	50.3	44.1	41.4
		MCWB	37.9	36.8	37.3	40.8	46.6	53.1	57.4	56.4	52.0	46.6	42.0	38.7
	10%	DB	37.3	37.4	38.2	44.6	52.2	58.6	62.9	61.3	55.1	48.6	41.8	38.8
		MCWB	36.1	35.4	35.5	39.9	45.6	51.6	56.0	55.2	51.2	45.2	40.2	37.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.5	41.3	42.4	45.5	51.6	59.1	61.8	61.8	56.2	52.2	46.4	44.6
		MCDB	45.4	43.6	45.6	51.0	59.4	67.5	71.3	70.0	59.3	53.9	47.6	48.8
	2%	WB	40.2	39.1	39.9	43.1	49.3	56.1	59.3	59.1	54.2	49.3	44.4	41.5
		MCDB	42.1	41.3	42.6	47.6	56.0	63.2	66.8	64.8	56.8	51.8	45.7	43.7
	5%	WB	38.2	37.4	37.9	41.5	47.8	54.0	57.9	57.4	53.1	47.5	42.5	39.2
		MCDB	39.7	38.9	39.9	45.5	53.5	60.1	64.3	62.2	55.5	49.8	44.0	41.1
	10%	WB	36.4	36.0	36.1	40.2	46.3	52.4	56.5	56.0	52.0	46.1	40.2	37.3
		MCDB	37.4	37.3	37.8	44.0	51.1	57.5	62.0	60.2	54.5	48.0	41.7	38.6
Mean Daily Temperature Range	5% DB	MDBR	8.8	9.2	10.6	11.3	13.1	12.8	11.8	11.8	11.4	10.4	8.5	8.4
		MCDBR	9.6	9.2	10.7	14.3	18.5	19.6	17.8	16.0	13.3	10.6	9.8	10.9
		MCWBR	7.3	7.0	7.9	9.4	10.7	11.4	10.2	9.6	9.1	7.8	7.8	8.0
	5% WB	MCDBR	9.5	8.7	10.2	13.1	16.1	16.8	16.0	14.1	11.0	9.4	9.2	10.0
		MCWBR	7.5	6.9	8.0	9.0	9.8	10.3	9.6	9.1	8.2	7.5	7.7	8.0
Clear-Sky Solar Irradiance	taub		0.261	0.307	0.312	0.357	0.374	0.362	0.367	0.360	0.337	0.319	0.280	0.267
	taud		2.237	2.301	2.383	2.299	2.316	2.439	2.471	2.489	2.518	2.400	2.180	2.026
	Ebn at Noon		175	224	264	268	271	277	272	266	254	218	157	111
	Edh at Noon		13	21	26	34	36	33	31	28	23	19	14	11
All-Sky Solar Radiation	RadAvg		111	294	711	1141	1544	1696	1506	1198	782	384	156	66
	RadStd		14	48	98	154	141	128	127	150	116	41	27	8

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.60	+3.44	N/A	N/A	+1.51	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+1.51	+4.21	+3.92	N/A	N/A	N/A	-405	-517	N/A	N/A

Nomenclature: See separate page