

HUSLIA, AK, USA

WMO: 703655

Lat: 65.698N

Lon: 156.351W

Elev: 180

StdP: 14.60

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26552

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-45.4	-39.4	-29.3	1.1	-21.3	-28.5	1.1	-20.0	22.9	10.7	20.7	10.5	0.3	350	0.723

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	77.7	59.5	73.8	57.4	71.7	56.4	61.3	73.7	59.3	70.8	57.6	67.6	6.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.5	66.0	63.8	54.3	63.2	63.1	52.4	58.9	61.7	27.2	73.7	25.9	71.0	24.8	67.7	66.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.8	17.6	15.7	-43.9	82.3	10.4	3.1	-51.4	84.6	-57.4	86.4	-63.3	88.2	-70.8	90.4		
			-29.4	63.2	3.2	1.7	-31.7	64.5	-33.6	65.5	-35.3	66.4	-37.6	67.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	-2.5	6.0	7.8	25.7	44.8	57.4	59.3	53.1	43.4	24.7	7.1	1.5
	DBStd	25.59	21.23	15.29	13.81	12.50	10.29	6.50	5.95	5.89	7.33	11.03	13.86	16.31
	HDD50	8956	1627	1232	1310	732	211	15	6	33	215	786	1287	1502
	HDD65	13729	2092	1652	1775	1179	627	239	192	370	648	1251	1737	1967
	CDD50	731	0	0	0	4	50	235	295	130	17	0	0	0
	CDD65	28	0	0	0	0	1	10	16	1	0	0	0	0
	CDH74	331	0	0	0	0	17	116	180	18	0	0	0	0
	CDH80	53	0	0	0	0	1	16	35	1	0	0	0	0
	WSAvg	6.0	6.2	6.7	6.8	7.0	6.1	5.3	5.4	5.1	6.0	5.7	5.7	6.0
	PrecAvg	16.7	1.1	1.1	0.8	0.6	0.7	1.4	2.2	2.6	2.0	1.6	1.3	1.2
Precipitation	PrecMax	21.5	2.5	3.0	2.5	2.1	1.3	3.9	3.9	6.1	4.2	4.5	3.3	2.8
	PrecMin	12.6	0.1	0.1	0.1	0.1	0.2	0.5	1.3	1.0	0.9	0.6	0.1	0.4
	PrecStd	2.7	0.6	0.7	0.5	0.4	0.4	0.6	0.7	1.0	0.9	0.8	0.9	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.0	36.4	39.1	63.3	75.4	81.5	84.0	76.6	64.5	48.3	36.2	34.2
		MCWB	32.9	32.9	33.8	47.3	53.9	59.8	63.4	60.5	52.0	43.3	33.3	32.7
	2%	DB	32.0	34.1	35.6	52.4	70.3	77.0	78.9	71.8	61.4	43.6	33.9	30.7
		MCWB	30.3	31.6	31.9	41.4	52.7	57.3	60.8	58.3	50.2	39.7	31.4	29.8
	5%	DB	28.0	30.4	31.2	46.2	64.4	73.3	74.8	66.3	57.2	40.8	30.3	27.0
		MCWB	26.1	28.6	28.3	37.8	49.8	56.0	59.0	55.6	48.6	37.6	29.0	25.1
	10%	DB	24.6	27.2	27.4	42.9	61.2	70.5	72.0	63.6	54.4	37.7	27.1	22.0
		MCWB	22.4	24.8	24.1	35.4	47.6	54.9	57.7	54.1	47.9	34.5	24.9	20.4
	0.4%	WB	33.2	33.7	35.2	47.3	55.6	62.3	65.0	61.9	53.8	45.7	33.4	32.7
		MCDB	35.2	35.4	37.6	63.5	74.8	77.3	80.0	72.3	60.8	47.0	34.8	33.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	30.7	31.8	31.6	41.7	53.3	59.4	62.3	59.2	51.6	40.8	31.5	29.9
		MCDB	32.4	33.8	34.6	51.9	68.2	74.0	75.4	67.7	58.5	43.7	32.9	30.9
	5%	WB	27.4	28.8	28.2	38.3	51.0	57.5	60.3	57.4	50.1	38.2	29.1	25.7
		MCDB	28.5	30.6	30.9	45.7	63.4	70.0	72.3	65.2	56.6	40.7	30.5	27.2
	10%	WB	23.7	25.0	24.4	35.7	48.8	56.0	58.7	55.4	48.3	35.2	25.0	21.4
		MCDB	26.1	27.3	27.4	42.0	59.4	68.3	69.4	62.0	54.3	38.0	27.3	22.7
Mean Daily Temperature Range	5% DB	MDBR	12.1	13.9	17.0	17.7	19.2	17.7	15.9	14.8	12.9	10.2	11.2	11.4
		MCDBR	11.0	12.2	16.1	18.8	24.7	23.1	22.9	20.1	18.5	9.9	9.2	10.2
		MCWBR	10.1	10.8	12.8	12.1	12.0	9.7	9.7	9.9	10.5	7.4	8.4	9.8
		MCDBR	11.8	12.2	14.3	17.8	22.7	20.3	20.5	16.8	16.0	9.1	9.2	10.0
	5% WB	MCWBR	10.9	10.9	11.7	11.5	11.1	9.3	9.0	8.8	9.6	7.1	8.5	9.8
Clear-Sky Solar Irradiance	taub		0.168	0.252	0.259	0.342	0.339	0.359	0.362	0.358	0.306	0.273	N/A	0.171
	taud		1.931	2.140	2.265	2.094	2.388	2.389	2.415	2.440	2.543	2.354	N/A	1.937
	Ebn at Noon		103	199	262	257	274	270	265	254	248	194	N/A	20
	Edh at Noon		6	17	24	38	32	33	31	27	20	14	N/A	2
All-Sky Solar Radiation	RadAvg		40	245	827	1506	1726	1815	1483	1107	686	259	66	7
	RadStd		4	22	52	86	174	152	115	126	83	39	9	0

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page