

ANGOON, AK, USA

WMO: 703830

Lat: 57.499N

Lon: 134.586W

Elev: 28

StdP: 14.68

Time Zone: -9.00 (NAK)

Period: 06-19

WBAN: 25310

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.9	16.4	1.6	6.0	17.0	5.1	7.1	20.1	16.7	27.0	15.2	30.4	7.5	40	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	77.0	71.1	70.2	62.8	64.7	58.3	71.9	73.8	61.6	66.6	58.7	63.1	2.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.2	115.2	74.3	59.3	75.5	62.4	56.5	68.2	60.0	35.5	72.4	27.5	69.1	25.4	63.1	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.8	11.8	10.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	8.9	70.3	3.4	11.6	6.4	4.5	85.4	2.6	91.9	0.1	100.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.1	34.4	33.0	35.8	42.3	49.2	54.5	57.0	56.4	52.2	45.6	36.2	32.4
	DBStd	10.84	8.00	7.53	5.50	4.87	4.39	5.93	3.56	3.02	4.11	5.54	7.59	7.01
	HDD50	2861	492	479	441	241	64	6	0	0	18	159	416	545
	HDD65	7644	953	897	906	685	491	330	251	266	387	605	863	1010
	CDD50	726	8	3	0	9	40	140	217	200	83	22	3	1
	CDD65	32	4	0	0	3	2	15	3	0	2	3	0	0
	CDH74	320	86	27	0	39	27	86	8	0	29	17	0	1
	CDH80	156	66	17	0	24	16	13	0	0	16	4	0	0
Wind	WSAvg	2.7	4.0	3.6	3.9	2.9	1.8	1.7	1.4	1.3	1.4	2.5	4.1	4.4
Precipitation	PrecAvg	104.8	11.5	8.6	8.4	6.4	4.6	3.8	4.8	6.7	10.7	13.4	12.9	13.0
	PrecMax	142.7	21.4	17.8	15.8	9.8	11.5	7.0	8.9	14.6	19.3	20.9	23.1	28.2
	PrecMin	75.3	3.5	3.1	3.0	0.6	0.3	1.4	0.4	1.7	3.9	5.9	5.9	5.9
	PrecStd	17.0	3.6	3.9	3.3	2.3	2.6	1.4	2.0	3.0	3.7	3.4	4.1	5.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.0	61.4	51.6	81.8	76.0	81.8	99.4	70.9	72.3	75.5	56.0	48.4
		MCWB	85.5	56.6	45.2	68.9	64.2	75.4	81.6	58.6	69.5	72.7	54.6	44.0
	2%	DB	47.5	45.9	47.0	54.1	63.1	76.0	72.5	66.4	62.6	61.7	53.5	45.4
		MCWB	44.8	42.7	42.3	45.4	53.2	71.5	67.5	58.8	57.1	59.8	52.6	42.8
	5%	DB	44.7	43.5	44.8	50.9	59.2	69.8	66.2	63.9	59.7	54.9	49.1	42.7
		MCWB	42.5	41.0	41.2	44.2	50.9	64.0	59.0	58.1	55.9	53.0	47.8	40.9
	10%	DB	42.3	41.6	42.9	48.4	56.3	62.0	63.1	62.0	57.4	52.0	46.1	40.2
		MCWB	40.8	39.8	39.7	43.2	49.8	55.6	57.3	57.1	54.5	49.9	44.5	38.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.1	51.4	46.2	60.5	64.4	76.9	73.9	61.0	68.4	72.3	55.0	45.8
		MCDB	56.3	53.3	50.5	64.4	70.9	79.8	74.6	67.0	69.7	74.7	55.5	47.1
	2%	WB	45.0	43.1	43.4	46.4	54.5	73.5	61.8	59.5	60.1	59.0	52.5	43.0
		MCDB	46.8	45.1	46.1	50.5	59.4	75.1	69.0	64.2	60.4	60.3	53.3	44.9
	5%	WB	42.4	41.5	41.8	45.0	52.0	61.9	59.2	58.5	56.8	53.4	48.1	40.8
		MCDB	43.9	43.3	44.3	49.2	57.6	68.5	64.5	62.5	58.3	54.3	48.8	42.6
	10%	WB	40.9	39.9	40.3	43.9	50.5	56.2	57.8	57.5	54.9	50.3	44.7	39.0
		MCDB	42.0	41.3	42.5	47.6	55.5	61.1	62.0	60.8	56.5	51.6	45.9	40.1
Mean Daily Temperature Range	5% DB	MDBR	6.5	9.5	9.6	12.1	12.4	10.5	9.4	9.3	9.2	8.0	6.2	5.8
		MCDBR	11.0	13.5	11.9	18.1	19.7	18.0	14.8	13.2	13.2	10.9	6.6	8.3
		MCWBR	6.0	9.2	7.9	10.6	10.6	8.0	7.7	6.8	7.8	8.2	5.1	6.3
	5% WB	MCDBR	8.2	12.3	11.2	14.8	16.9	15.7	12.7	11.0	9.9	9.9	6.3	7.8
		MCWBR	6.3	9.6	7.9	9.5	9.6	7.5	6.9	6.1	7.5	8.5	5.2	6.1
Clear-Sky Solar Irradiance	taub	0.294	0.320	0.332	0.385	0.378	0.382	0.385	0.366	0.360	0.332	0.300	0.275	
	taud	2.252	2.319	2.362	2.226	2.365	2.403	2.435	2.513	2.478	2.440	2.277	2.193	
	Ebn at Noon	179	229	261	261	272	272	269	267	250	224	174	148	
	Edh at Noon	16	23	28	38	35	34	33	28	25	20	15	12	
All-Sky Solar Radiation	RadAvg	115	332	677	1142	1448	1466	1223	1048	669	356	154	81	
	RadStd	17	66	103	139	163	125	159	147	125	52	25	13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	+2.00	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page