

ANGOON, AK, USA

WMO: 703830

Lat: 57.499N

Lon: 134.586W

Elev: 9

StdP: 101.22

Time Zone: -9.00 (NAK)

Period: 06-19

WBAN: 25310

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.6	-8.7	-16.9	0.9	-8.3	-15.0	1.0	-6.6	7.5	-2.8	6.8	-0.9	3.4	40	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	25.0	21.7	21.2	17.1	18.2	14.6	22.1	23.2	16.5	19.2	14.8	17.3	1.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.8	16.5	23.5	15.2	10.8	16.9	13.6	9.7	15.6	64.8	22.4	46.0	20.6	41.3	17.3	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.2	5.3	4.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-12.9	21.3	1.9	6.4	-14.2	25.9	-15.3	29.7	-16.3	33.3	-17.7	37.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	1.3	0.5	2.1	5.7	9.6	12.5	13.9	13.6	11.2	7.5	2.4	0.2
	DBStd	6.02	4.45	4.18	3.05	2.70	2.44	3.29	1.98	1.68	2.28	3.08	4.22	3.89
	HDD10.0	1589	273	266	245	134	36	3	0	0	10	88	231	303
	HDD18.3	4247	529	498	503	381	273	183	139	148	215	336	479	561
	CDD10.0	403	4	2	0	5	22	78	121	111	46	12	2	1
	CDD18.3	18	2	0	0	2	1	8	2	0	1	2	0	0
	CDH23.3	178	48	15	0	22	15	48	4	0	16	9	0	1
	CDH26.7	87	37	9	0	13	9	7	0	0	9	2	0	0
Wind	WSAvg	1.2	1.8	1.6	1.7	1.3	0.8	0.7	0.6	0.6	0.6	1.1	1.8	2.0
Precipitation	PrecAvg	2661	293	218	213	163	117	96	121	171	271	341	328	329
	PrecMax	3625	544	451	401	249	293	179	225	372	489	531	587	716
	PrecMin	1912	89	78	76	16	8	35	11	43	100	149	151	151
	PrecStd	433	91	100	84	58	66	36	52	77	93	86	105	137
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.3	16.3	10.9	27.7	24.4	27.7	37.5	21.6	22.4	24.2	13.3	9.1
		MCWB	29.7	13.7	7.3	20.5	17.9	24.1	27.6	14.8	20.8	22.6	12.5	6.6
	2%	DB	8.6	7.7	8.4	12.3	17.3	24.5	22.5	19.1	17.0	16.5	11.9	7.4
		MCWB	7.1	5.9	5.7	7.5	11.8	21.9	19.7	14.9	14.0	15.4	11.4	6.0
	5%	DB	7.0	6.4	7.1	10.5	15.1	21.0	19.0	17.7	15.4	12.7	9.5	5.9
		MCWB	5.9	5.0	5.1	6.8	10.5	17.8	15.0	14.5	13.3	11.7	8.8	4.9
	10%	DB	5.7	5.3	6.0	9.1	13.5	16.7	17.3	16.6	14.1	11.1	7.8	4.6
		MCWB	4.9	4.3	4.3	6.2	9.9	13.1	14.1	13.9	12.5	9.9	6.9	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	10.8	7.9	15.8	18.0	25.0	23.3	16.1	20.2	22.4	12.8	7.7
		MCDB	13.5	11.8	10.3	18.0	21.6	26.6	23.7	19.5	21.0	23.7	13.0	8.4
	2%	WB	7.2	6.1	6.3	8.0	12.5	23.0	16.6	15.3	15.6	15.0	11.4	6.1
		MCDB	8.2	7.3	7.8	10.3	15.2	23.9	20.6	17.9	15.8	15.7	11.8	7.2
	5%	WB	5.8	5.3	5.4	7.2	11.1	16.6	15.1	14.7	13.8	11.9	9.0	4.9
		MCDB	6.6	6.3	6.8	9.5	14.2	20.3	18.1	16.9	14.6	12.4	9.3	5.9
	10%	WB	4.9	4.4	4.6	6.6	10.3	13.4	14.3	14.1	12.7	10.1	7.0	3.9
		MCDB	5.6	5.2	5.8	8.7	13.0	16.2	16.7	16.0	13.6	10.9	7.7	4.5
Mean Daily Temperature Range	5% DB	MDBR	3.6	5.3	5.3	6.7	6.9	5.8	5.2	5.2	5.1	4.5	3.4	3.2
		MCDBR	6.1	7.5	6.6	10.1	10.9	10.0	8.2	7.3	7.4	6.1	3.7	4.6
		MCWBR	3.3	5.1	4.4	5.9	5.9	4.4	4.3	3.8	4.3	4.6	2.8	3.5
	5% WB	MCDBR	4.6	6.8	6.2	8.2	9.4	8.7	7.0	6.1	5.5	5.5	3.5	4.3
		MCWBR	3.5	5.3	4.4	5.3	5.3	4.2	3.9	3.4	4.1	4.7	2.9	3.4
Clear-Sky Solar Irradiance	taub	0.294	0.320	0.332	0.385	0.378	0.382	0.385	0.366	0.360	0.332	0.300	0.275	
	taud	2.252	2.319	2.362	2.226	2.365	2.403	2.435	2.513	2.478	2.440	2.277	2.193	
	Ebn at Noon	565	722	822	822	857	858	847	842	787	705	549	467	
	Edh at Noon	49	72	89	119	111	108	103	89	80	63	47	39	
All-Sky Solar Radiation	RadAvg	0.36	1.05	2.13	3.60	4.57	4.62	3.85	3.30	2.11	1.12	0.49	0.26	
	RadStd	0.05	0.21	0.33	0.44	0.44	0.52	0.39	0.50	0.46	0.39	0.16	0.08	0.04

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	N/A	+1.11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page