

BURWASH, YT, Canada

WMO: 710010

Lat: 61.3701N

Lon: 139.0323W

Elev: 2642

StdP: 13.35

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-44.6	-37.7	-49.1	0.3	-43.2	-45.1	0.4	-37.3	29.7	34.6	27.1	33.1	0.4	270	0.823

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	74.9	56.2	71.4	54.7	68.0	53.4	57.9	71.6	56.2	68.4	54.6	65.5	8.7	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.4	64.5	59.8	50.5	60.0	58.7	48.8	56.3	57.8	26.1	72.1	24.9	68.4	23.9	65.6	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	23.1	20.2	DB	-47.0	79.9	6.8	3.7	-51.8	82.6	-55.8	84.8	-59.6	86.8	-64.5	89.5
			WB	-46.5	60.8	5.4	2.4	-50.4	62.5	-53.5	63.9	-56.6	65.2	-60.5	67.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.5	-4.6	3.7	11.0	29.6	42.7	52.4	55.5	51.5	42.0	26.9	7.4	-2.0	
	DBStd	24.54	18.78	15.82	14.40	9.14	6.17	5.16	4.19	5.28	6.96	10.17	15.01	17.08	
	HDD50	8993	1692	1295	1209	611	239	32	6	46	255	717	1279	1612	
	HDD65	14072	2157	1715	1674	1061	692	380	295	420	691	1181	1729	2077	
	CDD50	396	0	0	0	0	12	102	177	91	13	1	0	0	
	CDD65	2	0	0	0	0	0	1	1	0	0	0	0	0	
	CDH74	144	0	0	0	0	3	44	52	45	0	0	0	0	
	CDH80	13	0	0	0	0	0	7	2	4	0	0	0	0	
Wind	WSAvg	7.1	4.8	5.7	6.6	8.0	8.8	7.8	7.6	7.5	8.7	7.9	6.3	5.4	
Precipitation	PrecAvg	11.9	0.5	0.3	0.4	0.5	1.1	2.0	2.7	1.7	1.1	0.7	0.5	0.4	
	PrecMax	16.6	1.9	0.9	2.1	1.8	2.8	3.6	5.3	3.9	1.7	1.3	1.5	1.5	
	PrecMin	8.2	0.1	0.0	0.0	0.0	0.0	0.5	0.4	0.5	0.3	0.1	0.0	0.0	
	PrecStd	2.1	0.4	0.2	0.4	0.4	0.7	0.9	1.4	0.8	0.4	0.4	0.4	0.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	40.5	46.7	59.3	72.6	79.3	79.2	79.4	65.2	55.1	41.5	41.6	
		MCWB	36.3	34.1	37.4	44.8	51.1	57.9	58.0	58.5	51.0	45.6	35.6	35.0	
	2%	DB	37.0	36.6	40.4	51.8	66.9	73.5	74.7	73.5	60.8	48.9	38.6	35.9	
		MCWB	32.4	31.3	33.4	39.9	48.9	54.5	56.4	57.2	48.7	40.8	33.8	31.4	
	5%	DB	32.6	33.1	36.8	47.3	62.3	69.8	71.1	68.9	57.7	45.2	35.3	32.3	
		MCWB	28.8	28.7	30.6	37.0	46.7	53.3	55.6	54.5	46.9	38.4	30.8	28.7	
	10%	DB	26.9	29.7	33.0	44.3	57.6	65.6	67.8	64.6	55.1	42.3	31.3	27.8	
		MCWB	24.5	26.2	27.8	35.1	44.1	51.4	54.2	52.6	45.5	36.3	28.0	25.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.8	34.9	37.7	45.0	52.6	59.6	60.1	59.9	52.3	46.4	36.5	35.4
			MCDB	41.4	40.0	45.9	58.3	69.2	76.5	73.4	75.8	62.6	54.2	40.6	40.2
		2%	WB	32.6	31.6	33.9	40.4	49.7	56.2	58.1	57.5	49.8	41.7	34.1	31.6
			MCDB	36.8	36.1	40.0	50.5	64.6	69.9	70.7	71.7	58.8	47.8	38.5	35.2
5%		WB	28.8	28.9	30.7	37.7	47.3	54.1	56.5	55.4	47.8	39.0	30.9	28.7	
		MCDB	32.5	32.9	36.3	46.5	60.6	67.0	68.4	67.2	56.4	44.4	34.9	32.0	
10%		WB	24.3	26.0	28.0	35.5	45.1	52.2	55.1	53.3	46.1	36.5	27.6	24.6	
		MCDB	27.1	29.9	32.7	43.4	56.4	63.9	65.7	63.0	54.1	41.9	31.2	27.7	
Mean Daily Temperature Range	5% DB	MDBR	19.7	25.7	28.4	24.0	24.4	22.6	21.4	22.5	20.9	18.3	18.5	19.5	
		MCDBR	22.0	21.7	25.0	26.3	35.4	31.4	30.6	33.1	25.2	20.4	21.9	22.9	
		MCWBR	18.1	17.8	18.7	16.5	19.7	15.8	15.7	18.4	15.7	14.5	18.1	19.5	
	5% WB	MCDBR	21.0	20.6	24.3	25.0	31.4	28.2	26.5	30.4	23.0	18.7	21.4	22.4	
		MCWBR	17.4	17.1	18.3	16.0	17.9	14.6	14.0	17.2	14.7	13.4	17.9	19.5	
Clear-Sky Solar Irradiance	taub	0.229	0.250	0.264	0.334	0.362	0.372	0.367	0.358	0.298	0.267	0.205	0.173		
	taud	1.978	2.181	2.208	2.048	2.183	2.259	2.312	2.340	2.469	2.312	2.038	1.906		
	Ebn at Noon	148	234	274	269	271	270	269	261	263	226	163	120		
	Edh at Noon	13	21	29	43	41	38	36	32	23	18	11	8		
All-Sky Solar Radiation	RadAvg	103	361	915	1536	1867	1818	1675	1359	886	418	142	54		
	RadStd	6	22	53	93	69	103	86	80	65	35	8	3		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	+3.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		N/A	+2.88	+2.90	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page