

BURWASH, YT, Canada

WMO: 710010

Lat: 61.3701N

Lon: 139.0323W

Elev: 805

StdP: 92.02

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.6	-38.7	-45.1	0.0	-41.8	-42.8	0.1	-38.5	13.3	1.4	12.1	0.6	0.2	270	0.823

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	23.8	13.4	21.9	12.6	20.0	11.9	14.4	22.0	13.4	20.2	12.5	18.6	3.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	9.2	15.5	10.3	8.6	14.8	9.3	8.0	14.3	42.8	22.3	40.0	20.2	37.7	18.7	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.8	10.3	9.0	-43.9	26.6	3.8	2.1	-46.6	28.1	-48.8	29.3	-50.9	30.5	-53.6	32.0		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-43.6	16.0	3.0	1.3	-45.8	16.9	-47.5	17.7	-49.2	18.5	-51.4	19.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.1	-20.3	-15.7	-11.7	-1.3	5.9	11.3	13.1	10.8	5.5	-2.8	-13.7	-18.9
	DBStd	13.63	10.43	8.79	8.00	5.08	3.43	2.86	2.33	2.93	3.87	5.65	8.34	9.49
	HDD10.0	4996	940	719	672	339	133	18	3	26	142	398	711	896
	HDD18.3	7818	1198	953	930	589	384	211	164	233	384	656	961	1154
	CDD10.0	220	0	0	0	0	7	57	98	51	7	1	0	0
	CDD18.3	1	0	0	0	0	0	1	1	0	0	0	0	0
	CDH23.3	80	0	0	0	0	2	24	29	25	0	0	0	0
	CDH26.7	7	0	0	0	0	0	4	1	2	0	0	0	0
Wind	WSAvg	3.2	2.1	2.6	2.9	3.6	3.9	3.5	3.4	3.4	3.9	3.6	2.8	2.4
Precipitation	PrecAvg	302	13	8	10	12	29	50	69	44	27	17	13	10
	PrecMax	421	49	23	54	45	71	92	134	98	43	34	37	39
	PrecMin	209	2	1	1	0	0	13	9	12	8	3	1	1
	PrecStd	54	10	6	11	10	17	23	36	21	9	9	9	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.8	4.7	8.2	15.2	22.5	26.3	26.2	26.3	18.4	12.8	5.3	5.3
		MCWB	2.4	1.2	3.0	7.1	10.6	14.4	14.4	14.7	10.6	7.5	2.0	1.6
	2%	DB	2.8	2.5	4.7	11.0	19.4	23.1	23.7	23.1	16.0	9.4	3.6	2.1
		MCWB	0.2	-0.4	0.8	4.4	9.4	12.5	13.6	14.0	9.3	4.9	1.0	-0.3
	5%	DB	0.4	0.6	2.6	8.5	16.8	21.0	21.7	20.5	14.3	7.3	1.8	0.1
		MCWB	-1.8	-1.8	-0.8	2.8	8.2	11.8	13.1	12.5	8.3	3.5	-0.7	-1.8
	10%	DB	-2.8	-1.3	0.6	6.8	14.2	18.7	19.9	18.1	12.8	5.7	-0.4	-2.3
		MCWB	-4.2	-3.2	-2.3	1.7	6.7	10.8	12.3	11.4	7.5	2.4	-2.2	-3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	1.6	3.2	7.2	11.5	15.4	15.6	15.5	11.3	8.0	2.5	1.9
		MCDB	5.2	4.5	7.7	14.6	20.6	24.7	23.0	24.3	17.0	12.4	4.8	4.5
	2%	WB	0.3	-0.2	1.0	4.6	9.8	13.4	14.5	14.2	9.9	5.4	1.2	-0.2
		MCDB	2.7	2.3	4.5	10.3	18.1	21.0	21.5	22.1	14.9	8.8	3.6	1.8
	5%	WB	-1.8	-1.7	-0.7	3.1	8.5	12.3	13.6	13.0	8.8	3.9	-0.6	-1.8
		MCDB	0.3	0.5	2.4	8.0	15.9	19.5	20.2	19.6	13.6	6.9	1.6	0.0
	10%	WB	-4.3	-3.3	-2.2	2.0	7.3	11.2	12.8	11.8	7.8	2.5	-2.4	-4.1
		MCDB	-2.7	-1.2	0.4	6.3	13.5	17.7	18.7	17.2	12.3	5.5	-0.4	-2.4
Mean Daily Temperature Range	5% DB	MDBR	10.9	14.3	15.8	13.3	13.5	12.6	11.9	12.5	11.6	10.2	10.3	10.8
		MCDBR	12.2	12.0	13.9	14.6	19.6	17.4	17.0	18.4	14.0	11.3	12.2	12.7
		MCWBR	10.1	9.9	10.4	9.2	11.0	8.8	8.7	10.2	8.7	8.0	10.1	10.8
	5% WB	MCDBR	11.6	11.5	13.5	13.9	17.4	15.7	14.7	16.9	12.8	10.4	11.9	12.4
		MCWBR	9.7	9.5	10.2	8.9	10.0	8.1	7.8	9.5	8.2	7.5	9.9	10.8
Clear-Sky Solar Irradiance	taub	0.229	0.250	0.264	0.334	0.362	0.372	0.367	0.358	0.298	0.267	0.205	0.173	
	taud	1.978	2.181	2.208	2.048	2.183	2.259	2.312	2.340	2.469	2.312	2.038	1.906	
	Ebn at Noon	468	739	863	847	854	852	847	823	828	713	513	379	
	Edh at Noon	41	66	92	134	128	121	112	100	73	57	36	25	
All-Sky Solar Radiation	RadAvg	0.32	1.14	2.88	4.84	5.88	5.73	5.28	4.28	2.79	1.32	0.45	0.17	
	RadStd	0.02	0.07	0.17	0.29	0.22	0.33	0.27	0.25	0.21	0.11	0.02	0.01	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	+1.95	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	+1.60	+1.61	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page