

ALLIANCE AGCM, AB, Canada

WMO: 710060

Lat: 52.3154N

Lon: 111.7787W

Elev: 737

StdP: 92.78

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-30.4	-27.4	-33.7	0.2	-30.2	-30.7	0.2	-27.4	13.0	-1.7	11.6	-4.5	3.0	150	0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	29.1	16.9	27.1	16.2	25.4	15.8	18.9	25.4	17.8	24.4	16.9	23.4	4.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	13.0	21.6	15.5	12.0	20.4	14.5	11.3	19.3	56.9	25.3	53.1	24.4	50.3	23.4	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.3	9.0	-35.1	32.6	3.0	2.4	-37.2	34.3	-39.0	35.7	-40.6	37.0	-42.8	38.7		
(5)			-35.2	21.4	2.9	1.3	-37.3	22.4	-39.1	23.1	-40.7	23.9	-42.8	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.3	-9.7	-10.6	-4.1	3.3	10.6	14.6	17.1	16.2	11.3	4.4	-4.0	-10.7	(6)
(7)		DBStd	11.92	8.64	8.31	7.85	5.27	4.38	3.19	2.63	3.13	4.65	4.99	7.18	7.81	(7)
(8)		HDD10.0	3167	609	578	438	206	46	4	0	1	39	183	421	641	(8)
(9)		HDD18.3	5533	868	811	697	450	239	118	54	79	214	432	671	899	(9)
(10)		CDD10.0	717	0	0	0	6	66	142	222	193	78	9	1	0	(10)
(11)		CDD18.3	41	0	0	0	0	1	6	18	13	3	0	0	0	(11)
(12)		CDH23.3	913	0	0	0	3	70	109	320	290	118	3	0	0	(12)
(13)		CDH26.7	218	0	0	0	0	9	15	87	75	33	0	0	0	(13)
(14)	Wind	WSAvg	4.1	4.5	4.2	4.3	4.7	4.5	4.0	3.6	3.3	3.7	4.2	4.1	4.1	(14)
(15)	Precipitation	PrecAvg	408	21	13	18	30	42	73	71	55	33	18	18	17	(15)
(16)		PrecMax	547	61	24	43	71	104	110	151	125	83	48	61	30	(16)
(17)		PrecMin	261	4	2	1	4	10	17	18	6	1	4	3	2	(17)
(18)		PrecStd	85	13	7	10	16	24	26	30	24	22	10	13	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	8.1	14.6	22.1	28.0	28.6	31.8	31.2	30.2	23.0	14.7	7.6	(19)
(20)			MCWB	3.4	3.7	7.7	9.8	13.7	16.8	18.7	17.0	15.6	12.2	7.7	3.6	(20)
(21)		2%	DB	5.3	4.7	11.0	18.9	25.3	26.2	29.1	28.6	26.6	18.5	10.3	4.7	(21)
(22)			MCWB	2.4	1.6	5.3	8.9	12.7	15.7	18.1	17.0	14.4	10.2	5.2	1.5	(22)
(23)		5%	DB	3.7	2.7	7.6	15.5	22.9	24.3	26.6	26.6	23.8	15.5	6.9	2.2	(23)
(24)			MCWB	1.4	0.5	3.7	6.9	11.8	15.2	17.4	16.4	13.6	8.6	2.9	-0.2	(24)
(25)		10%	DB	2.1	0.9	5.0	12.6	20.4	22.2	24.7	24.5	20.7	12.6	4.9	-0.3	(25)
(26)			MCWB	0.0	-0.7	2.0	5.5	10.7	14.0	16.9	16.0	12.4	7.0	1.8	-1.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	3.9	8.2	11.0	15.0	18.6	21.3	20.1	16.8	13.4	8.3	4.0	(27)
(28)			MCD B	6.8	8.0	14.1	21.0	25.0	25.5	27.4	25.7	26.8	21.8	14.8	6.9	(28)
(29)		2%	WB	2.6	1.8	5.6	9.0	13.6	17.1	19.3	18.6	15.2	11.0	5.6	1.6	(29)
(30)			MCD B	5.0	4.1	9.9	18.1	22.8	23.4	25.8	24.8	24.5	15.8	9.8	4.3	(30)
(31)		5%	WB	1.5	0.6	3.7	7.4	12.5	15.9	18.3	17.4	14.0	9.1	3.6	-0.1	(31)
(32)			MCD B	3.7	2.6	7.3	14.3	21.4	22.3	24.9	24.3	21.9	14.5	6.4	2.1	(32)
(33)		10%	WB	0.1	-0.7	2.2	6.0	11.3	14.9	17.4	16.4	12.9	7.5	2.1	-1.9	(33)
(34)			MCD B	2.0	0.9	4.8	11.8	19.1	20.8	23.6	23.1	20.5	12.4	4.2	-0.1	(34)
(35)	Mean Daily Temperature Range	MDBR	9.8	9.9	10.1	12.2	13.9	12.5	13.2	13.6	13.9	11.9	9.7	9.2	(35)	
(36)		5% DB	MCD BR	9.7	11.0	12.8	17.7	18.0	15.6	17.4	18.2	19.3	16.6	12.2	10.7	(36)
(37)			MCWBR	7.5	8.6	8.0	9.1	8.1	6.8	8.0	8.2	8.8	9.2	7.9	8.2	(37)
(38)		5% WB	MCD BR	10.0	10.9	12.5	16.2	16.3	13.6	15.1	15.5	17.4	15.4	11.5	10.6	(38)
(39)			MCWBR	8.0	8.6	8.1	8.7	7.6	6.7	7.7	7.8	8.4	8.8	7.8	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.269	0.301	0.291	0.333	0.357	0.365	0.359	0.374	0.318	0.285	0.260	0.250	(40)	
(41)		taud	2.277	2.245	2.431	2.357	2.336	2.350	2.404	2.341	2.458	2.532	2.460	2.324	(41)	
(42)		Ebn at Noon	733	808	912	904	894	887	886	851	869	840	764	701	(42)	
(43)		Edh at Noon	63	88	89	109	118	117	109	110	87	65	52	50	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.11	2.16	3.59	4.76	5.78	6.01	6.37	5.18	3.65	2.19	1.12	0.83	(44)	
(45)		RadStd	0.10	0.17	0.27	0.44	0.38	0.40	0.31	0.40	0.38	0.28	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (79 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page